

PLOCK, Poland

WMO: 123600

Lat: 52.5883N

Lon: 19.7258E

Elev: 357

StdP: 14.51

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.8	9.2	-0.7	5.4	4.3	4.1	6.9	10.1	23.4	40.1	21.3	37.6	5.1	70	0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.2	85.3	68.1	81.9	66.5	78.8	64.8	70.2	81.1	68.4	78.0	66.7	75.6	7.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.7	99.5	74.2	64.9	93.5	72.6	63.3	88.1	71.2	34.3	81.5	32.8	78.3	31.5	75.6	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.0	16.9	15.1	DB	0.0	91.3	7.4	2.9	-5.3	93.4	-9.6	95.0	-13.8	96.7	-19.1	98.7	(4)
			WB	-0.6	73.5	7.2	1.9	-5.8	74.8	-10.0	75.9	-14.1	77.0	-19.3	78.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	28.5	31.0	37.5	48.0	56.4	62.0	66.3	65.6	57.1	48.1	39.2	31.9
	DBStd	15.22	10.00	9.21	7.98	7.60	6.94	5.96	5.68	5.38	5.98	7.08	7.18	9.14
	HDD50	2752	668	531	391	124	19	0	0	9	121	327	562	
	HDD65	6534	1133	951	852	513	278	126	53	59	244	524	774	1027
	CDD50	1921	0	0	4	63	218	361	504	482	223	63	3	0
	CDD65	227	0	0	0	1	12	37	92	76	9	0	0	0
	CDH74	2052	0	0	0	28	135	356	814	632	87	0	0	0
	CDH80	504	0	0	0	4	16	81	232	156	15	0	0	0
Wind	WSAvg	7.4	8.7	8.4	8.7	7.7	6.8	6.4	6.1	5.8	6.3	7.2	8.0	8.6
Precipitation	PrecAvg	20.7	1.2	1.1	1.3	1.3	2.0	2.3	3.1	2.3	1.8	1.3	1.5	1.4
	PrecMax	31.4	3.5	3.5	2.4	3.4	5.9	5.2	7.6	5.3	6.1	3.7	4.3	3.4
	PrecMin	13.1	0.1	0.1	0.5	0.1	0.7	0.6	0.6	0.4	0.2	0.2	0.1	0.2
	PrecStd	3.7	0.7	0.6	0.6	0.8	1.1	1.2	1.7	1.3	1.4	0.9	0.8	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.5	51.4	61.6	77.7	82.3	86.9	90.4	88.8	82.5	70.2	57.4	51.6
		MCWB	45.7	46.5	50.8	60.3	64.9	69.6	69.1	70.1	65.0	60.7	53.4	49.3
	2%	DB	45.9	48.5	56.6	71.0	78.1	82.0	85.9	84.2	76.0	65.4	53.8	48.2
		MCWB	43.2	45.1	48.1	56.5	63.5	67.1	68.3	67.6	62.2	58.0	50.7	45.7
	5%	DB	43.1	45.5	52.5	65.6	74.3	77.9	82.1	80.7	71.7	61.8	51.1	45.5
		MCWB	40.9	42.6	46.1	53.5	61.4	64.6	66.9	66.1	60.5	56.1	48.5	43.3
	10%	DB	40.4	42.6	48.7	61.3	70.1	74.4	78.5	77.2	68.2	58.5	48.6	42.7
		MCWB	38.5	40.0	44.0	51.2	58.8	62.9	65.2	64.1	58.8	54.1	46.3	40.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	47.7	52.8	61.1	67.1	72.0	72.7	71.9	66.4	62.0	54.3	49.7
		MCDB	48.7	49.8	59.9	75.7	78.9	83.0	84.2	84.6	78.0	68.3	56.7	51.2
	2%	WB	43.5	45.3	49.3	57.9	64.8	68.8	70.6	69.6	64.0	58.9	51.4	46.1
		MCDB	45.6	48.1	55.0	69.2	75.7	79.1	81.3	80.8	72.5	63.5	53.4	47.7
	5%	WB	41.1	42.7	46.7	54.8	62.6	66.5	68.7	67.6	62.0	56.7	48.7	43.3
		MCDB	43.0	45.3	51.6	63.5	71.7	75.3	77.9	77.1	69.4	60.8	50.7	45.1
	10%	WB	38.6	40.1	44.2	52.2	60.3	64.2	67.0	65.9	60.0	54.5	46.5	41.0
		MCDB	40.3	42.4	48.4	59.0	68.2	72.0	75.5	73.9	66.3	58.2	48.2	42.6
Mean Daily Temperature Range	5% DB	MDBR	7.7	9.1	12.1	16.8	18.1	17.9	18.2	18.2	15.8	12.4	7.9	7.2
		MCDBR	8.5	11.7	18.6	24.6	24.1	24.0	24.2	23.8	22.3	17.3	11.3	8.7
		MCWBR	7.3	9.2	11.9	12.6	12.0	11.8	9.7	10.2	10.8	10.7	8.9	7.5
	5% WB	MCDBR	8.5	11.3	17.2	21.7	21.5	21.5	20.3	20.8	19.4	16.0	10.7	8.4
		MCWBR	7.5	9.2	11.9	11.7	11.8	11.7	9.4	9.9	10.4	10.6	8.9	7.6
Clear-Sky Solar Irradiance	taub	0.313	0.343	0.375	0.426	0.416	0.410	0.443	0.431	0.391	0.367	0.350	0.311	
	taud	2.245	2.247	2.228	2.141	2.227	2.277	2.201	2.235	2.319	2.365	2.307	2.280	
	Ebn at Noon	208	238	254	255	265	268	255	251	248	228	193	187	
	Edh at Noon	21	28	35	43	42	40	43	39	32	25	20	17	
All-Sky Solar Radiation	RadAvg	208	426	821	1313	1651	1727	1598	1407	1002	552	232	150	
	RadStd	38	71	108	172	167	156	188	120	141	84	27	20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.04	N/A	N/A	+1.24	+0.92	N/A	N/A	-322	+149	N/A
Regional (27 neighbors)		+0.86	N/A	N/A	N/A	N/A	N/A	N/A	-302	+144	+47

Nomenclature: See separate page