

SIEDLCE, Poland

WMO: 123850

Lat: 52.1811N

Lon: 22.2447E

Elev: 155

StdP: 99.48

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.5	-13.7	-19.9	0.7	-16.9	-16.5	0.9	-13.1	10.6	4.8	9.2	2.7	2.0	70	0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	29.8	20.4	27.9	19.4	26.2	18.5	21.5	27.4	20.5	26.0	19.5	24.5	3.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.5	14.5	23.8	18.6	13.7	22.8	17.7	12.9	21.9	63.1	27.5	59.7	26.1	56.3	24.4	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.1	6.3	-20.5	32.6	4.2	1.4	-23.5	33.7	-26.0	34.5	-28.3	35.3	-31.4	36.3		
(5)			-20.8	23.0	4.1	0.9	-23.7	23.6	-26.1	24.2	-28.4	24.7	-31.4	25.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	-2.7	-1.4	2.5	8.5	13.3	16.5	18.9	18.2	13.3	8.2	3.5	-0.9	(6)
(7)		DBStd	8.69	5.75	5.49	4.63	4.26	3.90	3.44	3.14	3.14	3.47	4.15	4.45	5.25	(7)
(8)		HDD10.0	1667	393	318	235	77	13	0	0	0	9	84	198	338	(8)
(9)		HDD18.3	3813	652	552	492	296	163	76	32	42	154	314	446	596	(9)
(10)		CDD10.0	1011	0	0	2	32	114	195	274	253	109	29	3	0	(10)
(11)		CDD18.3	115	0	0	0	1	6	21	48	37	3	0	0	0	(11)
(12)		CDH23.3	1218	0	0	0	12	82	224	486	373	41	0	0	0	(12)
(13)		CDH26.7	300	0	0	0	2	9	46	138	100	6	0	0	0	(13)
(14)	Wind	WSAvg	3.0	3.5	3.4	3.5	3.1	2.7	2.6	2.5	2.4	2.5	3.0	3.3	3.5	(14)
(15)	Precipitation	PrecAvg	530	27	23	27	35	56	74	66	62	49	39	39	35	(15)
(16)		PrecMax	727	59	53	59	91	114	194	167	195	110	180	83	90	(16)
(17)		PrecMin	395	6	1	5	6	14	30	18	3	13	4	8	5	(17)
(18)		PrecStd	94	14	12	12	19	24	33	35	35	25	34	17	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.1	10.6	17.0	25.0	27.8	30.4	32.4	32.1	27.4	21.5	14.8	10.2	(19)
(20)			MCWB	7.3	7.5	10.4	15.2	18.1	20.9	21.1	20.8	18.1	15.9	11.8	8.9	(20)
(21)		2%	DB	6.9	8.7	13.8	21.6	25.8	27.8	30.1	29.3	24.2	18.6	12.6	8.2	(21)
(22)			MCWB	5.4	6.6	8.8	13.4	17.3	19.6	20.6	20.3	17.2	14.3	10.6	7.1	(22)
(23)		5%	DB	5.5	7.0	11.5	18.7	23.5	26.0	28.1	27.2	22.1	16.4	10.8	6.6	(23)
(24)			MCWB	4.3	5.4	7.4	11.7	16.4	18.6	19.7	19.1	16.3	13.2	9.4	5.7	(24)
(25)		10%	DB	4.0	5.3	9.1	16.5	21.3	24.0	26.1	25.2	20.1	14.6	9.4	5.2	(25)
(26)			MCWB	3.0	3.9	6.2	10.5	15.0	17.4	18.9	18.1	15.1	12.2	8.2	4.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	8.2	11.3	15.7	19.6	22.2	22.7	22.6	19.6	16.6	12.4	9.1	(27)
(28)			MCDWB	8.6	9.7	16.0	23.9	25.7	28.1	29.4	29.0	25.0	20.2	14.1	10.1	(28)
(29)		2%	WB	5.7	6.9	9.4	14.2	18.1	20.7	21.6	21.2	18.0	15.0	10.8	7.3	(29)
(30)			MCDWB	6.8	8.5	13.0	20.0	24.0	26.0	27.6	27.3	22.7	17.5	12.3	8.0	(30)
(31)		5%	WB	4.4	5.5	7.8	12.6	16.9	19.4	20.7	20.1	16.8	13.6	9.5	5.7	(31)
(32)			MCDWB	5.4	6.9	10.6	17.6	22.3	24.3	26.1	25.4	20.8	16.0	10.6	6.5	(32)
(33)		10%	WB	3.1	4.0	6.5	11.1	15.7	18.2	19.7	19.0	15.8	12.2	8.2	4.4	(33)
(34)			MCDWB	3.9	5.2	8.9	15.1	20.4	22.7	24.7	23.6	19.3	14.3	9.2	5.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.5	5.4	7.4	10.1	11.1	10.7	10.9	11.2	9.7	7.7	4.7	4.3	(35)
(36)			MCDBR	4.6	6.7	11.3	14.6	14.2	13.6	14.3	14.3	13.3	10.7	6.9	4.9	(36)
(37)			MCWBR	4.1	5.0	6.9	7.5	7.0	6.5	5.9	6.2	7.0	6.7	5.2	4.1	(37)
(38)		5% WB	MCDWB	4.5	6.3	10.1	13.2	12.8	11.8	12.2	12.2	11.7	9.7	6.1	4.7	(38)
(39)			MCWBR	4.1	5.1	6.7	7.2	6.7	6.3	5.7	5.8	6.5	6.5	4.8	4.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.311	0.340	0.375	0.427	0.412	0.408	0.438	0.433	0.394	0.363	0.352	0.310	(40)	
(41)		taud	2.221	2.206	2.218	2.131	2.241	2.279	2.212	2.220	2.297	2.359	2.281	2.264	(41)	
(42)		Ebn at Noon	664	755	805	803	840	846	810	791	779	728	610	600	(42)	
(43)		Edh at Noon	68	93	112	138	130	126	133	125	103	80	66	56	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.71	1.44	2.67	4.07	5.20	5.51	5.18	4.54	3.18	1.78	0.73	0.48	(44)	
(45)		RadStd	0.13	0.23	0.37	0.53	0.51	0.45	0.57	0.37	0.48	0.31	0.07	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.43	N/A	N/A	N/A	+0.64	+0.71	N/A	-140	+52	N/A
(47) Regional (19 neighbors)		+0.50	N/A	N/A	N/A	+0.43	N/A	N/A	-165	+83	+30

Nomenclature: See separate page