

TERESPOL, Poland

WMO: 123990

Lat: 52.0786N

Lon: 23.6219E

Elev: 137

StdP: 99.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.8	-14.2	-20.3	0.6	-17.6	-16.8	0.9	-13.4	8.4	2.3	7.7	0.5	1.9	0	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	30.2	20.6	28.4	19.8	26.7	18.9	21.8	27.8	20.8	26.5	19.9	24.9	3.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.8	24.3	18.9	13.9	23.4	18.0	13.2	22.4	64.4	27.9	60.7	26.5	57.5	25.0	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.4	5.6	DB	-20.7	33.0	4.2	1.5	-23.7	34.1	-26.2	34.9	-28.5	35.8	-31.6	36.8	(4)
(5)			WB	-21.0	23.4	4.0	0.9	-23.8	24.0	-26.2	24.6	-28.4	25.1	-31.3	25.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	-3.3	-1.7	2.5	9.0	13.7	17.1	19.3	18.4	13.4	8.3	3.9	-0.7	(6)	
	DBStd	8.90	5.84	5.37	4.70	4.17	3.95	3.44	3.23	3.27	3.70	4.18	4.14	5.21	(7)	
	HDD10.0	1663	412	328	234	67	11	0	0	0	11	83	187	331	(8)	
	HDD18.3	3770	671	561	490	279	150	65	28	39	153	311	434	589	(9)	
	CDD10.0	1073	0	0	2	38	126	212	287	262	113	31	3	0	(10)	
	CDD18.3	138	0	0	0	1	7	27	57	42	5	0	0	0	(11)	
	CDH23.3	1432	0	0	0	15	98	277	529	451	61	1	0	0	(12)	
	CDH26.7	387	0	0	0	2	14	63	157	141	10	0	0	0	(13)	
(14) Wind	WSAvg	2.7	3.1	3.0	3.3	2.9	2.7	2.5	2.4	2.3	2.3	2.7	2.9	2.9	(14)	
(15) Precipitation	PrecAvg	601	33	33	30	40	57	69	85	68	54	43	45	41	(15)	
	PrecMax	848	97	80	69	88	104	146	214	172	132	246	92	81	(16)	
	PrecMin	377	2	1	3	10	9	13	5	14	7	3	12	5	(17)	
	PrecStd	115	21	18	16	18	23	34	51	38	30	41	20	19	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.6	10.4	17.2	25.3	28.5	30.7	32.6	32.8	28.0	21.8	15.3	10.2	(19)	
		MCWB	6.5	7.2	10.8	15.9	18.5	21.0	21.5	21.1	18.5	16.4	12.0	8.9	(20)	
	2%	DB	6.4	8.1	13.8	21.8	26.0	28.5	30.3	30.2	25.0	19.0	12.8	8.1	(21)	
		MCWB	4.9	6.0	8.1	13.6	17.4	19.7	20.7	20.8	17.7	14.3	10.5	7.0	(22)	
	5%	DB	4.9	6.4	11.5	19.0	23.9	26.5	28.3	27.9	22.7	16.8	11.0	6.7	(23)	
		MCWB	3.8	4.8	7.3	11.9	16.6	18.8	20.1	19.8	16.6	13.3	9.5	5.6	(24)	
	10%	DB	3.5	4.7	9.2	16.8	21.7	24.6	26.3	25.6	20.5	14.8	9.5	5.4	(25)	
		MCWB	2.6	3.4	6.3	10.7	15.2	17.8	19.2	18.5	15.4	12.2	8.3	4.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	7.8	11.3	16.3	19.9	22.1	23.3	23.2	19.8	16.8	12.4	9.1	(27)	
		MCDB	8.2	9.4	16.4	24.8	26.2	28.7	29.4	29.5	25.7	20.6	14.3	10.1	(28)	
	2%	WB	5.1	6.3	9.4	14.5	18.5	20.9	22.1	21.5	18.4	15.1	10.9	7.2	(29)	
		MCDB	6.2	7.8	12.9	20.2	24.4	26.8	27.8	27.8	23.6	18.1	12.4	8.0	(30)	
	5%	WB	3.9	4.8	7.9	12.9	17.3	19.8	21.1	20.4	17.2	13.7	9.7	5.8	(31)	
		MCDB	4.7	6.2	10.5	17.5	22.5	24.8	26.3	26.2	21.6	16.1	10.9	6.6	(32)	
	10%	WB	2.6	3.4	6.5	11.4	16.0	18.6	20.1	19.3	15.9	12.4	8.3	4.5	(33)	
		MCDB	3.4	4.7	8.9	15.4	20.8	23.1	24.8	24.2	19.5	14.5	9.4	5.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.6	5.4	7.7	10.1	11.0	10.9	10.8	11.6	10.3	8.2	5.0	4.4	(35)	
		MCDBR	4.7	7.1	11.9	14.3	14.3	13.9	13.8	14.8	14.1	11.3	7.5	5.2	(36)	
	5% WB	MCWBR	4.1	5.3	7.2	7.2	7.0	6.5	5.7	6.4	7.4	7.0	5.5	4.4	(37)	
		MCWBR	4.4	6.6	10.4	12.7	12.8	12.3	11.8	13.2	12.3	10.4	6.7	5.1	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.310	0.339	0.375	0.426	0.412	0.407	0.437	0.433	0.394	0.362	0.350	0.308	(40)	
		taud	2.218	2.191	2.212	2.145	2.250	2.291	2.222	2.227	2.300	2.367	2.283	2.258	(41)	
	Ebn at Noon	Ebn at Noon	668	757	806	805	840	848	812	791	780	731	615	604	(42)	
		Edh at Noon	69	94	113	136	129	125	132	125	103	80	66	57	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.73	1.47	2.71	4.08	5.21	5.53	5.22	4.59	3.19	1.79	0.74	0.49	(44)	
	RadStd	RadStd	0.13	0.22	0.38	0.51	0.50	0.44	0.54	0.36	0.48	0.32	0.07	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)		+0.50	N/A	N/A	N/A	+0.51	+0.53	N/A	-162	+85	+32

Nomenclature: See separate page