

LEGNICA, Poland

WMO: 124150

Lat: 51.1925N

Lon: 16.2076E

Elev: 407

StdP: 14.48

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.4	13.5	3.1	6.5	9.0	8.3	8.5	14.5	27.5	42.6	25.2	43.0	4.2	70	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	86.9	67.9	83.5	66.7	80.4	65.6	70.1	82.3	68.4	79.7	66.9	77.0	7.5	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.1	97.7	74.5	64.6	92.7	72.6	63.2	88.1	71.1	34.3	82.6	32.9	79.9	31.6	77.3	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.4	19.2	16.7	DB	1.7	93.2	7.2	3.5	-3.5	95.7	-7.7	97.7	-11.8	99.6	-17.1	102.1	(4)
(5)			WB	1.2	73.5	7.1	1.8	-3.9	74.8	-8.0	75.9	-12.0	76.9	-17.2	78.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	31.5	34.0	39.9	48.9	56.7	62.6	66.6	66.0	58.0	49.7	40.9	34.3	(6)	
	DBStd	14.32	9.79	9.20	7.51	7.16	6.43	6.07	5.50	5.32	5.86	7.23	7.21	8.71	(7)	
	HDD50	2331	575	449	320	104	14	0	0	0	5	96	281	487	(8)	
	HDD65	6017	1039	867	777	484	267	115	46	52	220	476	723	951	(9)	
	CDD50	2034	1	2	7	71	222	379	516	496	245	86	8	1	(10)	
	CDD65	244	0	0	0	1	9	44	96	83	10	1	0	0	(11)	
	CDH74	2698	0	0	0	23	141	504	1037	858	130	5	0	0	(12)	
	CDH80	765	0	0	0	1	20	133	345	241	25	0	0	0	(13)	
(14) Wind	WSAvg	7.5	8.8	8.8	8.8	7.5	6.8	6.7	6.6	6.2	6.5	7.2	7.6	8.6	(14)	
(15) Precipitation	PrecAvg	25.1	1.5	1.3	1.8	1.4	2.5	3.0	4.1	2.9	2.2	1.6	1.6	1.4	(15)	
	PrecMax	33.0	3.0	2.5	3.6	2.5	4.6	7.5	12.0	11.3	4.8	4.3	3.9	2.6	(16)	
	PrecMin	17.5	0.2	0.1	0.7	0.1	1.1	1.2	0.5	0.8	0.6	0.2	0.0	0.5	(17)	
	PrecStd	4.2	0.7	0.7	0.8	0.6	0.9	1.6	2.4	2.1	1.3	1.0	0.8	0.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	57.1	65.1	77.3	82.8	89.3	92.7	91.0	84.0	73.7	61.4	54.8	(19)	
		MCWB	49.4	48.8	52.8	61.4	65.8	71.2	69.3	68.3	64.6	61.1	54.8	49.6	(20)	
	2%	DB	50.5	52.7	59.7	71.5	78.0	83.7	87.5	85.6	77.5	68.8	57.4	51.5	(21)	
		MCWB	46.0	47.0	49.7	57.4	64.4	68.1	67.8	67.3	62.7	59.2	52.1	47.0	(22)	
	5%	DB	46.9	49.7	55.4	66.9	74.1	79.8	83.9	82.2	73.6	64.7	54.4	48.6	(23)	
		MCWB	43.1	44.5	48.4	54.9	61.7	65.8	66.6	66.2	61.4	57.2	49.8	44.9	(24)	
	10%	DB	43.8	46.6	51.6	62.7	70.4	76.0	80.1	78.9	69.7	61.1	51.5	45.7	(25)	
		MCWB	40.6	42.5	45.8	52.8	59.5	63.7	65.7	64.6	60.3	55.4	48.1	42.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.5	50.1	54.1	62.4	68.3	72.8	71.9	71.5	67.0	62.9	55.6	50.4	(27)	
		MCDB	53.6	55.3	62.9	75.6	79.0	85.7	85.6	85.9	77.9	71.1	60.6	54.4	(28)	
	2%	WB	46.1	47.6	51.0	58.8	65.4	70.0	69.9	69.3	64.9	60.0	52.5	47.4	(29)	
		MCDB	49.7	52.1	58.0	69.3	75.6	80.9	82.2	81.1	73.8	66.8	56.5	51.0	(30)	
	5%	WB	43.3	45.1	48.6	55.9	63.2	67.1	68.3	67.7	63.2	57.8	50.3	45.0	(31)	
		MCDB	46.8	49.2	54.7	64.9	72.4	77.0	79.9	78.2	71.1	63.4	53.7	48.3	(32)	
	10%	WB	40.7	42.4	46.2	53.3	60.7	64.9	66.8	66.1	61.2	56.0	48.2	42.6	(33)	
		MCDB	43.6	46.4	51.1	61.4	68.6	73.1	77.1	75.6	68.5	60.7	51.1	45.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	10.8	13.4	18.0	18.8	18.8	19.4	20.1	16.9	14.5	10.4	9.1	(35)	
		MCDBR	11.9	14.9	21.9	26.4	26.2	26.5	27.6	26.7	25.2	21.2	14.9	12.0	(36)	
	5% WB	MCWBR	8.9	10.7	13.8	14.1	13.8	12.6	10.1	10.8	12.1	12.9	10.7	9.3	(37)	
		MCWBR	11.7	13.9	19.9	24.0	24.1	24.1	23.1	22.8	21.0	19.3	14.0	11.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.314	0.339	0.380	0.426	0.422	0.419	0.440	0.432	0.393	0.367	0.341	0.308	(40)	
		taud	2.332	2.305	2.231	2.158	2.216	2.256	2.209	2.245	2.327	2.363	2.379	2.370	(41)	
	Ebn at Noon		221	246	256	257	265	266	257	253	250	233	209	205	(42)	
		Edh at Noon	21	28	36	43	43	41	43	39	32	26	20	17	(43)	
(44) All-Sky Solar Radiation	RadAvg		243	467	807	1307	1597	1688	1596	1419	1012	579	277	181	(44)	
	RadStd		41	83	111	174	184	151	186	130	136	80	40	21	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	+1.39	+0.68	N/A	N/A	N/A	N/A	N/A	
(47) Regional (41 neighbors)		+0.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+104	+36	

Nomenclature: See separate page