

LEGNICA, Poland

WMO: 124150

Lat: 51.1925N

Lon: 16.2076E

Elev: 124

StdP: 99.84

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.7	-10.3	-16.1	0.9	-12.8	-13.2	1.2	-9.7	12.3	5.9	11.3	6.1	1.9	70	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	30.5	20.0	28.6	19.3	26.9	18.7	21.2	27.9	20.2	26.5	19.4	25.0	3.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	14.0	23.6	18.1	13.2	22.5	17.3	12.6	21.7	61.9	28.1	58.6	26.6	55.6	25.2	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.0	8.6	7.5	-16.8	34.0	4.0	1.9	-19.7	35.4	-22.1	36.5	-24.3	37.6	-27.3	39.0		
(5)			-17.1	23.1	3.9	1.0	-19.9	23.8	-22.2	24.4	-24.5	24.9	-27.3	25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	-0.3	1.1	4.4	9.4	13.7	17.0	19.2	18.9	14.4	9.8	4.9	1.3
	DBStd	7.96	5.44	5.11	4.17	3.98	3.57	3.37	3.06	2.96	3.26	4.02	4.00	4.84
	HDD10.0	1295	319	249	178	58	8	0	0	0	3	53	156	271
	HDD18.3	3343	577	482	432	269	148	64	26	29	122	264	402	528
	CDD10.0	1130	1	1	4	39	123	211	287	276	136	48	4	1
	CDD18.3	136	0	0	0	1	5	24	53	46	6	1	0	0
	CDH23.3	1499	0	0	0	13	78	280	576	477	72	3	0	0
	CDH26.7	425	0	0	0	1	11	74	192	134	14	0	0	0
Wind	WSAvg	3.4	4.0	3.9	3.9	3.3	3.0	3.0	3.0	2.8	2.9	3.2	3.4	3.8
Precipitation	PrecAvg	638	37	32	46	35	64	76	103	74	55	40	40	35
	PrecMax	838	76	64	91	64	117	190	306	288	123	109	98	67
	PrecMin	444	6	2	18	3	29	31	12	20	15	5	1	13
	PrecStd	106	18	17	20	16	24	40	62	53	32	25	21	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	13.9	18.4	25.2	28.2	31.8	33.7	32.8	28.9	23.2	16.3	12.7
		MCWB	9.7	9.3	11.5	16.3	18.8	21.8	20.7	20.2	18.1	16.2	12.7	9.8
	2%	DB	10.3	11.5	15.4	21.9	25.6	28.7	30.9	29.8	25.3	20.4	14.1	10.9
		MCWB	7.8	8.3	9.8	14.1	18.0	20.0	19.9	19.6	17.0	15.1	11.2	8.3
	5%	DB	8.3	9.8	13.0	19.4	23.4	26.5	28.8	27.9	23.1	18.1	12.4	9.2
		MCWB	6.2	7.0	9.1	12.7	16.5	18.8	19.2	19.0	16.3	14.0	9.9	7.1
	10%	DB	6.6	8.1	10.9	17.1	21.4	24.4	26.7	26.1	21.0	16.2	10.8	7.6
		MCWB	4.8	5.9	7.7	11.5	15.3	17.6	18.7	18.1	15.7	13.0	8.9	5.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	10.0	12.3	16.9	20.2	22.7	22.2	21.9	19.5	17.2	13.1	10.2
		MCDB	12.0	12.9	17.2	24.2	26.1	29.8	29.8	29.9	25.5	21.7	15.9	12.4
	2%	WB	7.8	8.7	10.6	14.9	18.5	21.1	21.0	20.7	18.3	15.5	11.4	8.5
		MCDB	9.8	11.2	14.4	20.7	24.2	27.2	27.9	27.3	23.2	19.3	13.6	10.6
	5%	WB	6.3	7.3	9.2	13.3	17.3	19.5	20.2	19.8	17.3	14.3	10.1	7.2
		MCDB	8.2	9.6	12.6	18.3	22.5	25.0	26.6	25.7	21.7	17.4	12.1	9.1
	10%	WB	4.9	5.8	7.9	11.9	15.9	18.3	19.3	18.9	16.2	13.3	9.0	5.9
		MCDB	6.5	8.0	10.6	16.3	20.3	22.9	25.1	24.2	20.3	15.9	10.6	7.5
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.0	7.4	10.0	10.5	10.8	11.2	9.4	8.1	5.8	5.1	
		MCDBR	6.6	8.3	12.2	14.7	14.6	14.7	15.3	14.8	14.0	11.8	8.3	6.6
		MCWBR	5.0	5.9	7.6	7.8	7.6	7.0	5.6	6.0	6.7	7.1	5.9	5.1
	5% WB	MCDBR	6.5	7.7	11.1	13.3	13.4	13.4	12.8	12.6	11.7	10.7	7.8	6.5
		MCWBR	5.0	5.8	7.3	7.5	7.4	6.8	5.4	5.5	6.1	6.8	5.8	5.2
Clear-Sky Solar Irradiance	taub	0.314	0.339	0.380	0.426	0.422	0.419	0.440	0.432	0.393	0.367	0.341	0.308	
	taud	2.332	2.305	2.231	2.158	2.216	2.256	2.209	2.245	2.327	2.363	2.379	2.370	
	Ebn at Noon	696	777	807	810	834	839	811	797	789	735	658	645	
	Edh at Noon	65	87	112	136	134	130	134	123	102	82	63	54	
All-Sky Solar Radiation	RadAvg	0.77	1.47	2.54	4.12	5.04	5.32	5.03	4.47	3.19	1.82	0.87	0.57	
	RadStd	0.13	0.26	0.35	0.55	0.58	0.48	0.58	0.41	0.43	0.25	0.13	0.07	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	+0.77	+0.38	N/A	N/A	N/A	N/A	N/A
(47)	Regional (41 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+58	+20

Nomenclature: See separate page