

LESZNO, Poland

WMO: 124180

Lat: 51.8355N

Lon: 16.5347E

Elev: 305

StdP: 14.53

Time Zone: 1.00 (EUC)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.9	11.7	2.1	6.2	6.5	7.3	8.1	12.5	27.1	42.9	24.5	40.9	4.7	60	0.550

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	86.4	67.3	83.1	66.2	80.0	64.8	69.7	81.4	68.1	79.1	66.5	76.4	7.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.1	97.4	73.2	64.5	91.8	71.3	62.9	86.8	70.4	33.9	81.4	32.6	79.3	31.3	76.9	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.4	18.4	16.1	DB	-0.7	93.1	7.8	3.0	-6.3	95.2	-10.9	97.0	-15.3	98.7	-20.9	100.9	(4)
(5)			WB	-1.2	72.5	7.1	2.4	-6.3	74.3	-10.4	75.7	-14.4	77.0	-19.6	78.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.0	29.7	32.5	38.3	48.1	56.3	61.6	66.4	65.2	56.8	48.6	40.0	32.1		
	DBStd	14.72	9.69	9.05	7.67	7.41	6.76	6.08	5.99	5.50	5.76	7.07	6.69	8.89		
	HDD50	2608	631	491	366	121	18	1	0	0	7	114	304	555		
	HDD65	6415	1096	911	827	510	280	137	56	67	252	510	750	1019		
	CDD50	1894	0	0	5	63	214	349	507	471	212	69	4	0		
	CDD65	226	0	0	0	1	11	36	98	73	7	0	0	0		
	CDH74	2536	0	0	0	31	166	457	1093	698	88	3	0	0		
	CDH80	700	0	0	0	3	24	112	374	175	12	0	0	0		
	WSAvg	7.4	8.5	8.6	9.0	8.0	7.0	6.6	6.5	6.4	6.5	6.4	7.5	8.2		
	PrecAvg	21.9	1.4	1.2	1.6	1.3	2.2	2.5	3.1	2.6	1.7	1.4	1.4	1.5		
(15) Precipitation	PrecMax	28.8	2.6	2.6	3.3	3.3	4.1	5.5	7.7	7.0	4.2	3.9	3.3	3.3		
	PrecMin	15.0	0.2	0.1	0.4	0.1	0.6	0.6	0.6	0.9	0.4	0.2	0.0	0.4		
	PrecStd	3.3	0.6	0.6	0.7	0.7	0.8	1.3	1.7	1.3	1.0	0.9	0.7	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.7	55.4	63.8	78.3	83.4	88.1	92.5	88.8	81.7	72.2	58.9	52.9		
		MCWB	48.0	48.3	51.4	60.1	66.0	69.0	68.6	67.8	64.9	62.3	54.0	49.5		
	2%	DB	48.2	50.4	58.5	71.4	78.8	83.0	88.2	84.4	76.2	67.3	55.1	48.7		
		MCWB	45.3	45.5	49.1	56.0	63.2	66.6	67.0	67.4	62.3	58.9	50.7	45.3		
	5%	DB	44.9	47.5	54.1	66.0	74.6	79.3	84.1	81.1	72.3	63.4	52.7	45.8		
		MCWB	42.2	43.6	47.2	53.6	60.8	64.3	66.5	65.3	60.7	57.0	49.5	43.4		
	10%	DB	42.1	44.6	50.3	62.3	70.6	75.4	80.5	77.7	68.6	59.5	50.2	43.1		
		MCWB	39.8	41.2	45.3	51.8	58.8	62.8	65.5	64.3	59.5	54.9	47.4	41.0		
	0.4%	WB	48.6	49.6	53.3	61.1	67.3	72.3	71.8	71.1	66.4	62.7	54.6	50.3		
		MCDB	51.2	53.7	61.6	75.9	79.9	82.1	84.4	83.5	76.0	69.9	57.7	52.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	45.5	46.5	50.7	57.8	64.6	68.4	69.8	69.1	64.3	59.9	51.9	45.8		
		MCDB	48.0	49.6	56.6	68.5	75.6	80.0	82.4	79.4	73.7	66.0	54.2	47.8		
	5%	WB	42.5	43.9	47.9	54.9	62.4	66.1	68.3	67.5	62.3	57.4	49.8	43.5		
		MCDB	44.6	47.1	53.1	64.0	72.0	76.0	79.6	77.3	69.5	62.3	52.3	45.7		
	10%	WB	39.9	41.3	45.5	52.7	60.2	64.0	66.7	65.9	60.4	55.4	47.5	41.2		
		MCDB	41.8	44.4	49.9	60.6	68.6	72.3	77.1	74.3	67.0	59.0	49.9	42.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	11.2	14.3	19.1	19.6	19.9	19.8	19.7	17.0	15.2	10.8	8.8		
		MCDBR	10.8	15.2	22.9	26.5	26.4	27.1	27.1	25.7	24.4	20.6	14.2	10.6		
		MCWBR	8.9	11.0	14.5	14.1	13.2	12.8	10.1	10.7	12.2	12.8	10.6	8.6		
	5% WB	MCDBR	10.5	14.2	20.1	23.9	23.1	24.0	22.5	21.7	21.3	19.2	13.7	10.3		
		MCWBR	8.9	10.9	13.5	13.3	12.6	12.5	9.8	10.2	11.6	12.6	10.7	8.7		
(40) Clear-Sky Solar Irradiance	taub		0.318	0.343	0.381	0.425	0.419	0.416	0.439	0.432	0.391	0.368	0.344	0.312		
	taud		2.320	2.303	2.228	2.159	2.226	2.264	2.212	2.244	2.328	2.358	2.361	2.346		
	Ebn at Noon		215	243	254	256	265	266	257	252	249	230	203	197		
	Edh at Noon		20	27	36	43	42	41	42	39	32	26	20	17		
(44) All-Sky Solar Radiation	RadAvg		228	446	805	1320	1623	1707	1600	1420	1019	570	264	168		
	RadStd		37	81	103	174	184	156	187	127	130	78	38	20		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+103	N/A

Nomenclature: See separate page