

LASK, Poland

WMO: 124540

Lat: 51.552N

Lon: 19.179E

Elev: 633

StdP: 14.36

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.3	10.3	0.8	5.8	7.4	5.1	7.3	11.9	26.0	39.9	23.8	38.7	5.4	100	0.553

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	87.3	67.5	84.0	66.4	80.8	65.2	69.9	82.1	68.5	79.8	67.0	77.2	8.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	99.4	73.4	64.8	94.1	72.1	63.4	89.3	71.0	34.3	82.6	33.1	80.0	31.8	77.1	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.4	18.5	16.1	-4.0	94.1	7.4	2.3	-9.4	95.8	-13.7	97.1	-17.9	98.4	-23.3	100.1		
(5)			-2.7	73.6	7.0	1.5	-7.8	74.6	-11.9	75.5	-15.8	76.3	-20.9	77.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.3	27.7	30.4	38.2	48.8	56.8	63.4	67.2	66.4	57.4	47.6	41.1	32.8
	DBStd	15.51	9.49	8.96	8.45	7.73	7.11	6.37	6.35	5.60	6.38	7.35	6.88	8.58
	HDD50	2696	690	549	373	112	19	0	0	0	9	138	274	532
	HDD65	6412	1155	969	832	486	268	104	50	52	240	541	718	997
	CDD50	2059	0	0	6	78	230	403	534	508	231	62	7	0
	CDD65	301	0	0	0	2	15	57	120	95	12	0	0	0
	CDH74	2900	0	0	0	30	177	585	1121	840	147	0	0	0
	CDH80	842	0	0	0	3	31	152	382	237	37	0	0	0
	WSAvg	7.5	8.4	7.9	8.2	7.7	7.2	6.9	6.8	6.5	7.0	7.3	8.0	8.6
	PrecAvg	22.4	1.3	1.3	1.5	1.4	2.4	2.5	3.3	2.1	1.9	1.5	1.7	1.5
(15) Precipitation	PrecMax	29.5	2.9	2.8	3.1	3.3	6.2	5.9	9.4	4.8	4.4	5.0	4.1	3.6
	PrecMin	15.4	0.2	0.2	0.6	0.0	0.7	0.4	1.0	0.8	0.6	0.2	0.0	0.3
	PrecStd	3.6	0.6	0.6	0.6	0.7	1.2	1.5	2.0	1.0	0.9	1.1	0.8	0.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.4	52.6	63.8	78.5	83.8	90.0	92.3	90.6	84.9	70.9	60.2	52.9
		MCWB	45.8	46.5	50.9	59.5	64.5	69.5	68.2	68.0	65.2	59.9	53.4	48.5
	2%	DB	45.5	48.8	58.8	71.7	78.8	84.2	88.4	85.5	77.9	66.9	56.3	48.4
		MCWB	42.8	44.2	47.8	56.0	62.5	66.0	67.2	67.1	62.7	58.0	51.7	46.0
	5%	DB	42.6	44.9	54.9	67.4	74.6	80.4	84.5	82.3	73.4	62.5	53.0	45.8
		MCWB	40.1	40.9	46.4	53.3	60.5	64.5	67.3	65.9	61.0	55.9	49.7	43.7
	10%	DB	39.7	41.5	50.6	63.1	70.3	77.0	80.4	79.0	69.5	58.5	50.3	43.3
		MCWB	37.7	38.8	44.5	51.2	58.0	62.3	65.8	64.8	59.3	54.0	47.9	41.6
	0.4%	WB	46.8	48.4	52.7	60.3	66.6	71.3	71.9	71.5	67.1	61.8	54.4	48.6
		MCDB	49.0	50.7	61.3	74.9	78.8	84.1	83.0	83.4	81.6	68.6	58.5	51.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	43.1	44.4	49.6	57.4	64.1	68.5	70.2	69.3	64.3	58.9	52.1	46.3
		MCDB	45.3	48.4	56.8	69.2	75.0	80.4	82.2	81.1	73.2	65.0	55.3	48.3
	5%	WB	40.5	41.4	47.3	54.9	61.7	66.4	68.9	67.9	62.4	56.7	50.0	44.0
		MCDB	42.3	44.3	53.4	64.6	72.1	76.5	80.1	79.1	70.9	61.5	52.5	45.4
	10%	WB	37.7	38.9	44.8	52.4	59.6	64.4	67.4	66.3	60.3	54.5	48.1	41.7
		MCDB	39.5	41.5	49.9	60.9	68.4	73.6	77.2	75.6	67.8	58.3	50.2	43.2
(35) Mean Daily Temperature Range	5% DB	MDBR	8.6	10.9	14.5	18.6	18.9	19.7	19.6	19.8	17.7	13.9	9.9	8.5
		MCDBR	9.1	14.4	21.5	26.0	25.1	25.5	25.4	25.5	24.6	19.6	14.4	9.5
		MCWBR	7.7	10.4	12.9	13.4	11.9	10.9	9.1	10.1	11.4	11.8	10.2	7.6
	5% WB	MCDBR	9.2	13.4	19.2	23.1	22.6	22.1	21.9	21.9	21.5	18.0	13.6	9.1
		MCWBR	8.1	10.3	12.3	12.8	11.5	10.8	9.1	9.8	11.0	11.4	10.1	7.7
(40) Clear-Sky Solar Irradiance	taub		0.316	0.342	0.379	0.430	0.423	0.418	0.447	0.434	0.399	0.370	0.348	0.313
	taud		2.268	2.266	2.219	2.132	2.207	2.252	2.186	2.223	2.291	2.341	2.327	2.309
	Ebn at Noon		215	243	255	255	264	266	255	252	247	230	201	196
	Edh at Noon		22	28	36	44	43	41	43	40	33	26	21	18
(44) All-Sky Solar Radiation	RadAvg		233	456	842	1315	1640	1717	1604	1436	1030	581	266	178
	RadStd		45	82	101	174	173	165	191	120	143	89	35	23

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (27 neighbors)		+0.92	N/A	N/A	N/A	N/A	N/A	N/A	-295	+140	+54	

Nomenclature: See separate page