

SULEJOW, Poland

WMO: 124690

Lat: 51.3533N

Lon: 19.8664E

Elev: 189

StdP: 99.07

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.6	-12.3	-18.1	0.8	-15.3	-15.0	1.0	-11.5	12.3	3.4	11.2	3.7	1.9	140	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	30.2	20.2	28.3	19.3	26.5	18.4	21.2	28.0	20.3	26.4	19.4	24.7	3.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.2	23.2	18.2	13.4	22.4	17.4	12.8	21.7	62.3	28.1	59.2	26.4	56.2	24.9	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 10.0	8.7	7.6	DB	-18.9	33.4	5.3	2.0	-22.7	34.8	-25.8	36.0	-28.8	37.1	-32.6	38.5	(4)
(5)			WB	-19.4	22.8	4.9	0.9	-23.0	23.4	-25.8	24.0	-28.6	24.5	-32.1	25.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	-2.2	-0.8	2.9	8.9	13.4	16.8	18.9	18.7	13.8	8.9	4.4	0.1
	DBStd	8.45	5.39	4.93	4.55	4.04	3.73	3.43	3.23	3.33	3.53	4.10	3.95	4.84
	HDD10.0	1536	378	303	221	67	11	0	0	0	7	71	171	307
	HDD18.3	3644	637	536	477	284	158	69	32	36	141	292	418	565
	CDD10.0	1063	0	0	2	34	117	204	276	269	121	38	3	0
	CDD18.3	131	0	0	0	1	5	23	50	47	5	0	0	0
	CDH23.3	1399	0	0	0	17	87	261	503	468	63	1	0	0
	CDH26.7	384	0	0	0	2	11	68	152	140	12	0	0	0
Wind	WSAvg	3.4	4.0	3.9	4.0	3.3	3.0	3.0	3.0	2.8	3.0	3.2	3.4	4.0
Precipitation	PrecAvg	599	33	30	36	41	66	74	91	61	50	40	41	35
	PrecMax	808	70	66	67	112	160	180	224	147	118	95	85	85
	PrecMin	450	5	5	14	2	27	17	11	21	16	5	2	9
	PrecStd	98	15	14	15	23	37	40	57	32	23	24	18	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.5	11.5	17.2	25.5	28.2	31.7	32.8	33.0	28.3	22.1	15.3	10.6
		MCWB	7.4	7.7	10.9	15.5	18.2	21.0	20.9	20.9	18.2	15.8	11.9	9.0
	2%	DB	7.5	9.0	14.0	21.9	25.8	28.4	30.3	29.9	25.0	19.8	13.0	8.8
		MCWB	6.0	6.5	8.7	13.6	17.1	19.7	20.1	20.0	17.0	14.8	10.5	7.4
	5%	DB	5.9	7.1	11.7	19.0	23.7	26.2	28.2	27.9	22.7	17.4	11.4	7.4
		MCWB	4.6	5.1	7.9	12.0	16.2	18.5	19.3	19.3	16.3	13.6	9.6	6.1
	10%	DB	4.4	5.3	9.5	16.7	21.4	24.2	26.1	25.8	20.5	15.2	9.8	5.9
		MCWB	3.3	3.7	6.8	10.6	14.9	17.5	18.5	18.2	15.3	12.5	8.4	5.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	8.4	11.4	15.8	19.3	22.2	22.3	22.3	19.5	16.8	12.4	9.5
		MCDB	8.7	10.4	16.2	24.3	25.7	28.9	29.3	29.9	25.6	20.7	14.8	10.6
	2%	WB	6.0	6.9	9.6	14.3	18.0	20.7	21.2	21.0	18.0	15.2	11.0	7.5
		MCDB	7.2	8.9	13.0	20.6	23.9	26.8	27.8	28.3	23.1	18.9	12.8	8.7
	5%	WB	4.7	5.3	8.2	12.8	16.9	19.4	20.4	20.0	17.0	13.9	9.7	6.3
		MCDB	5.8	6.9	11.0	17.8	22.4	24.5	26.2	26.4	21.8	16.8	11.1	7.2
	10%	WB	3.4	3.8	6.9	11.4	15.7	18.2	19.5	19.1	15.8	12.7	8.5	5.0
		MCDB	4.3	5.2	9.4	15.6	20.5	22.9	24.3	24.2	19.6	15.0	9.8	5.9
Mean Daily Temperature Range	5% DB	MDBR	4.7	5.9	7.6	10.5	10.8	10.7	10.9	11.3	9.8	8.2	5.5	4.4
		MCDBR	5.3	8.1	11.8	14.9	14.9	14.5	14.5	14.5	13.8	11.8	8.1	5.4
		MCWBR	4.3	5.8	7.5	7.7	7.3	6.9	5.6	6.1	6.8	7.2	5.9	4.4
	5% WB	MCDBR	5.1	7.5	10.7	13.5	13.4	12.6	12.2	12.9	12.4	10.9	7.6	5.2
		MCWBR	4.3	5.8	7.2	7.4	7.1	6.5	5.2	5.8	6.6	6.9	5.8	4.4
Clear-Sky Solar Irradiance	taub	0.319	0.345	0.383	0.435	0.425	0.422	0.450	0.439	0.403	0.372	0.352	0.316	
	taud	2.259	2.252	2.207	2.121	2.206	2.250	2.183	2.216	2.282	2.336	2.318	2.302	
	Ebn at Noon	676	763	802	800	830	836	802	789	775	725	631	619	
	Edh at Noon	69	91	115	141	135	131	138	127	106	84	66	57	
All-Sky Solar Radiation	RadAvg	0.75	1.47	2.67	4.11	5.13	5.42	5.08	4.54	3.25	1.85	0.84	0.57	
	RadStd	0.14	0.26	0.34	0.55	0.56	0.51	0.61	0.37	0.46	0.28	0.10	0.08	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)		+0.50	N/A	N/A	+0.78	N/A	N/A	N/A	-163	+70	+30

Nomenclature: See separate page