

RADOM, Poland

WMO: 124850

Lat: 51.414N

Lon: 21.111E

Elev: 183

StdP: 99.15

Time Zone: 1.00 (EUC)

Period: 01-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.2	-13.6	-19.4	0.7	-16.9	-16.2	0.9	-12.7	10.5	3.4	9.8	2.2	2.0	100	0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	29.8	19.9	28.2	19.3	26.6	18.5	21.5	27.4	20.6	26.1	19.7	24.6	3.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.6	23.8	18.7	13.8	23.0	17.9	13.1	22.1	63.4	27.5	60.1	26.1	57.0	24.9	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 9.1	7.9	6.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-20.5	23.1	5.4	1.5	-24.4	24.1	-27.6	25.0	-30.6	25.8	-34.5	26.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-3.2	-1.2	3.1	8.9	14.3	17.4	20.2	19.1	13.9	8.6	4.7	-0.3
	DBStd	8.97	6.25	5.56	5.07	3.98	3.59	3.10	3.16	2.93	3.53	4.14	4.00	5.03
	HDD10.0	1573	408	315	218	63	6	0	0	0	7	76	161	320
	HDD18.3	3624	666	548	472	282	133	54	18	25	138	301	408	578
	CDD10.0	1155	0	0	4	32	138	221	316	283	124	34	3	0
	CDD18.3	165	0	0	0	1	8	26	75	49	7	0	0	0
	CDH23.3	1401	0	0	0	13	82	226	643	379	59	0	0	0
	CDH26.7	347	0	0	0	2	9	44	192	92	7	0	0	0
Wind	WSAvg	3.2	3.7	3.7	3.7	3.2	2.9	2.8	2.8	2.8	2.7	3.2	3.6	3.7
Precipitation	PrecAvg	636	33	34	37	43	61	67	100	65	58	42	38	32
	PrecMax	797	94	63	91	101	165	148	326	189	127	106	72	61
	PrecMin	476	6	10	12	1	27	34	16	17	6	5	1	8
	PrecStd	84	18	13	18	26	32	31	71	35	34	29	15	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.4	12.4	18.5	24.7	27.8	30.3	32.9	31.7	27.8	21.4	16.0	9.9
		MCWB	8.0	8.7	11.4	14.6	17.6	20.7	21.4	20.8	16.9	16.0	12.9	7.9
	2%	DB	8.2	9.7	15.3	21.1	25.6	27.9	30.6	28.9	25.1	18.7	13.3	8.3
		MCWB	6.5	7.6	9.0	12.8	17.7	19.0	19.9	19.9	16.8	13.8	10.8	6.7
	5%	DB	6.5	7.8	13.1	18.6	23.5	25.9	28.8	27.2	22.7	16.9	11.5	7.0
		MCWB	5.0	5.6	8.1	11.6	16.3	17.8	19.8	19.0	15.8	13.2	9.7	5.8
	10%	DB	4.9	5.9	10.8	16.4	21.4	24.1	27.0	25.3	20.4	15.1	10.2	5.6
		MCWB	3.7	4.2	7.2	10.0	14.9	16.8	19.0	18.3	14.8	12.5	8.9	4.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.4	9.2	11.9	15.1	19.4	21.6	22.8	22.5	19.2	16.5	13.1	8.5
		MCDB	10.0	11.0	17.4	23.4	25.7	27.1	29.2	27.8	24.2	20.1	15.6	9.5
	2%	WB	6.7	7.7	10.2	13.7	18.2	20.3	21.8	21.2	17.5	14.6	11.4	7.0
		MCDB	8.1	9.8	14.0	19.5	24.2	25.8	27.8	27.1	22.0	17.6	13.0	8.0
	5%	WB	5.2	5.9	8.7	12.2	17.0	19.1	21.0	20.2	16.6	13.6	10.1	5.9
		MCDB	6.3	7.8	12.5	17.2	22.2	23.9	26.5	25.3	21.0	16.4	11.2	6.9
	10%	WB	3.7	4.3	7.1	10.9	15.8	18.0	20.0	19.2	15.6	12.4	8.8	4.6
		MCDB	4.7	5.5	10.0	15.4	20.0	22.4	25.2	23.4	20.0	15.0	10.2	5.5
Mean Daily Temperature Range	5% DB	MDBR	5.1	6.3	8.1	10.2	9.9	9.8	10.0	10.0	9.3	7.9	5.6	5.0
		MCDBR	5.8	8.4	12.2	14.0	12.9	12.7	12.8	13.0	13.0	10.5	7.9	6.2
		MCWBR	4.8	6.3	7.1	7.4	6.5	5.9	4.8	5.4	5.8	6.3	5.7	4.8
	5% WB	MCDBR	5.7	7.7	11.1	12.5	11.7	11.1	11.4	11.5	10.9	9.7	7.2	5.6
		MCWBR	4.8	6.0	6.9	6.8	6.4	5.9	5.0	5.4	5.5	6.3	5.5	4.7
Clear-Sky Solar Irradiance	taub	0.321	0.348	0.385	0.432	0.418	0.415	0.442	0.435	0.400	0.372	0.355	0.316	
	taud	2.242	2.228	2.196	2.129	2.230	2.269	2.206	2.228	2.291	2.329	2.293	2.284	
	Ebn at Noon	669	757	799	803	836	841	809	793	778	723	622	613	
	Edh at Noon	70	93	116	139	132	128	134	125	105	84	67	58	
All-Sky Solar Radiation	RadAvg	0.74	1.47	2.69	4.07	5.12	5.49	5.12	4.55	3.24	1.86	0.81	0.56	
	RadStd	0.14	0.25	0.35	0.55	0.56	0.48	0.62	0.35	0.49	0.28	0.09	0.09	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (25 neighbors)		+0.52	N/A	N/A	+0.77	N/A	N/A	N/A	-166	+76	+31	

Nomenclature: See separate page