

DEBLIN, Poland

WMO: 124900

Lat: 51.551N

Lon: 21.894E

Elev: 120

StdP: 99.90

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.2	-13.6	-20.2	0.6	-16.8	-16.6	0.9	-12.8	10.5	-3.0	9.8	-2.3	1.6	90	0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	31.2	20.4	29.2	19.6	27.5	18.8	21.5	28.7	20.7	27.2	19.8	25.6	3.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	14.2	23.7	18.5	13.5	23.1	17.7	12.9	22.5	63.0	28.9	60.1	27.5	57.2	25.7	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.8	7.7	6.7	DB	-21.0	34.0	4.7	1.5	-24.3	35.1	-27.1	36.0	-29.7	36.8	-33.1	37.9	(4)
			WB	-20.2	23.2	5.0	0.9	-23.8	23.8	-26.7	24.4	-29.5	24.9	-33.1	25.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	-3.0	-1.3	3.2	8.9	14.1	17.6	19.9	19.2	13.8	8.4	4.3	-0.3
	DBStd	8.94	6.00	5.35	4.82	4.08	3.82	3.32	3.36	3.31	3.58	4.14	3.95	5.01
	HDD10.0	1592	404	316	214	67	8	0	0	7	81	174	321	
	HDD18.3	3661	662	549	469	283	140	53	23	29	143	309	421	579
	CDD10.0	1145	0	0	3	34	134	228	306	284	120	31	3	0
	CDD18.3	171	0	0	0	1	8	31	71	55	6	0	0	0
	CDH23.3	1832	0	0	0	19	111	349	699	572	81	0	0	0
	CDH26.7	556	0	0	0	4	15	92	233	193	19	0	0	0
Wind	WSAvg	3.0	3.2	3.2	3.4	3.2	2.9	2.9	2.8	2.5	2.7	2.8	2.9	3.2
Precipitation	PrecAvg	585	32	31	35	41	62	66	89	63	53	40	39	35
	PrecMax	738	82	66	77	101	133	148	267	204	111	111	85	80
	PrecMin	436	4	6	9	2	25	29	12	9	8	5	2	7
	PrecStd	76	17	14	16	24	30	32	56	37	33	28	15	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	12.0	18.4	25.9	28.5	32.0	33.4	34.1	29.1	21.9	16.2	11.9
		MCWB	7.8	8.3	11.0	15.3	18.1	21.1	21.1	21.2	18.8	15.6	12.2	9.0
	2%	DB	7.5	9.4	15.2	22.3	26.3	29.2	31.2	30.9	25.4	19.5	13.5	9.1
		MCWB	5.7	6.8	9.3	13.3	17.2	19.9	20.1	20.3	17.4	14.6	10.4	7.1
	5%	DB	5.8	7.4	13.0	19.5	24.2	27.0	29.3	28.6	23.2	17.2	11.7	7.5
		MCWB	4.3	5.1	7.7	11.9	16.2	18.5	19.8	19.4	16.5	13.3	9.5	6.1
	10%	DB	4.3	5.6	10.6	17.1	22.0	25.1	27.4	26.6	20.8	15.0	10.1	5.9
		MCWB	3.1	3.7	7.0	10.7	15.1	17.4	19.1	18.6	15.3	12.3	8.5	4.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	8.9	11.7	15.7	19.9	22.3	22.5	22.4	20.0	16.8	12.6	9.3
		MCDB	9.5	10.8	16.9	24.9	26.4	29.9	29.4	29.8	27.2	20.7	15.6	11.6
	2%	WB	6.0	7.0	9.9	14.2	18.0	20.8	21.6	21.2	18.4	15.1	11.0	7.4
		MCDB	7.5	9.3	14.3	20.9	24.2	27.5	28.5	28.7	24.0	18.5	12.8	8.9
	5%	WB	4.5	5.2	8.6	12.6	16.9	19.6	20.8	20.4	17.0	13.8	9.8	6.1
		MCDB	5.7	7.2	12.2	18.0	22.6	25.5	27.2	26.9	21.3	16.7	11.4	7.3
	10%	WB	3.1	3.9	7.1	11.2	15.8	18.4	19.9	19.5	15.9	12.3	8.5	4.8
		MCDB	4.3	5.4	10.1	16.1	21.0	23.4	25.4	24.9	20.0	14.8	10.0	5.9
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.4	8.9	11.3	11.1	11.3	11.3	11.8	10.5	8.7	5.7	5.1
		MCDBR	5.6	8.7	13.8	15.8	14.3	14.5	14.6	15.2	14.6	12.6	8.6	6.4
		MCWBR	4.7	6.3	8.3	8.2	6.7	6.5	5.5	6.2	7.1	8.0	6.3	5.1
	5% WB	MCDBR	5.5	7.9	12.1	14.4	12.7	12.9	12.6	13.4	12.6	11.6	7.8	6.0
		MCWBR	4.7	5.9	7.7	7.9	6.5	6.1	5.3	5.9	6.5	7.7	5.9	4.9
Clear-Sky Solar Irradiance	taub	0.319	0.346	0.382	0.438	0.423	0.420	0.448	0.442	0.405	0.370	0.356	0.316	
	taud	2.234	2.217	2.202	2.105	2.213	2.252	2.190	2.205	2.271	2.336	2.285	2.278	
	Ebn at Noon	668	757	801	795	831	837	803	785	771	725	618	610	
	Edh at Noon	70	94	115	143	134	130	137	128	107	83	68	58	
All-Sky Solar Radiation	RadAvg	0.74	1.48	2.71	4.09	5.15	5.52	5.16	4.59	3.23	1.85	0.80	0.54	
	RadStd	0.14	0.23	0.36	0.53	0.54	0.47	0.59	0.35	0.49	0.29	0.08	0.09	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.54	N/A	N/A	+0.73	+0.42	N/A	N/A	-170	+83	+34

Nomenclature: See separate page