

LUBLIN RADAWIEC, Poland

WMO: 124950

Lat: 51.2167N

Lon: 22.3931E

Elev: 240

StdP: 98.48

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.3	-13.2	-18.8	0.7	-15.8	-15.9	1.0	-12.7	9.9	2.0	9.1	0.4	2.4	110	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	29.5	20.4	27.7	19.8	25.9	18.8	21.6	27.5	20.6	26.1	19.6	24.5	2.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.7	24.6	18.6	13.8	23.2	17.8	13.1	21.9	64.0	27.4	60.3	26.1	57.0	24.5	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.2	6.3	DB	-19.3	32.4	3.6	1.6	-21.9	33.5	-24.0	34.5	-26.0	35.4	-28.7	36.6	(4)
(5)			WB	-19.6	23.2	3.5	1.2	-22.1	24.1	-24.2	24.8	-26.2	25.5	-28.7	26.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	-2.9	-1.5	2.5	8.7	13.6	16.7	18.9	18.4	13.6	8.3	3.5	-1.1	(6)
(7)		DBStd	8.80	5.48	5.28	4.65	4.32	3.83	3.38	3.22	3.22	3.60	4.22	4.49	4.95	(7)
(8)		HDD10.0	1677	401	321	234	73	11	0	0	0	9	83	199	346	(8)
(9)		HDD18.3	3795	659	554	491	288	153	71	33	38	148	309	446	604	(9)
(10)		CDD10.0	1049	0	0	2	34	122	202	276	262	116	32	3	0	(10)
(11)		CDD18.3	126	0	0	0	1	6	22	51	41	5	0	0	0	(11)
(12)		CDH23.3	1117	0	0	0	8	62	189	443	372	43	0	0	0	(12)
(13)		CDH26.7	271	0	0	0	1	5	34	118	108	5	0	0	0	(13)
(14)	Wind	WSAvg	3.0	3.5	3.4	3.6	3.2	2.6	2.5	2.3	2.4	2.9	3.3	3.4	(14)	
(15)	Precipitation	PrecAvg	605	33	30	38	44	70	67	89	57	62	45	39	32	(15)
(16)		PrecMax	771	78	58	66	100	228	139	192	193	152	121	79	68	(16)
(17)		PrecMin	448	3	12	11	2	24	20	11	7	5	3	1	11	(17)
(18)		PrecStd	83	17	13	16	23	45	30	45	35	39	34	17	14	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.5	10.9	16.7	24.1	27.3	29.8	32.0	32.2	27.1	21.2	15.3	9.9	(19)
(20)			MCWB	6.6	7.7	10.8	15.1	18.4	21.5	21.1	20.9	18.2	15.8	12.0	8.3	(20)
(21)		2%	DB	6.5	8.4	13.4	20.9	25.1	27.5	29.7	29.6	24.3	18.8	12.9	7.8	(21)
(22)			MCWB	5.1	6.3	8.7	13.4	17.6	20.2	20.5	20.2	17.4	14.4	10.5	6.6	(22)
(23)		5%	DB	4.8	6.7	11.2	18.3	23.2	25.5	27.7	27.3	22.2	16.7	11.2	6.1	(23)
(24)			MCWB	3.7	5.1	7.5	11.9	16.7	18.9	19.9	19.4	16.2	13.5	9.5	5.1	(24)
(25)		10%	DB	3.5	4.9	8.9	16.1	21.0	23.7	25.8	25.1	20.0	14.6	9.5	4.7	(25)
(26)			MCWB	2.6	3.6	6.2	10.5	15.2	17.8	19.1	18.2	15.2	12.2	8.3	3.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	8.2	11.2	15.5	19.9	22.5	23.0	22.6	19.5	16.6	12.4	8.8	(27)
(28)			MCDWB	8.1	10.0	15.9	22.9	25.6	28.1	29.1	29.2	25.1	20.0	14.6	9.8	(28)
(29)		2%	WB	5.3	6.6	9.3	14.1	18.3	21.0	21.8	21.1	18.1	15.1	10.9	6.8	(29)
(30)			MCDWB	6.4	8.2	12.9	19.9	23.8	26.2	27.6	27.6	23.3	18.1	12.5	7.8	(30)
(31)		5%	WB	3.9	5.2	7.7	12.6	17.1	19.7	20.7	20.0	16.9	13.8	9.7	5.3	(31)
(32)			MCDWB	4.7	6.6	10.3	17.2	22.3	24.3	26.1	26.0	20.9	16.3	11.0	6.0	(32)
(33)		10%	WB	2.6	3.7	6.4	11.2	15.8	18.5	19.7	19.0	15.7	12.3	8.3	4.0	(33)
(34)			MCDWB	3.4	4.8	8.6	15.1	20.2	22.5	24.3	23.5	19.0	14.5	9.5	4.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	5.3	6.9	9.0	9.9	9.8	10.0	10.3	8.8	7.3	4.9	4.1	(35)
(36)			MCDBR	4.5	7.0	10.5	12.5	12.8	12.6	13.2	13.6	12.2	10.4	7.5	4.8	(36)
(37)			MCWBR	3.9	5.1	6.8	6.7	6.8	6.6	5.7	5.9	6.1	6.5	5.5	4.1	(37)
(38)		5% WB	MCDWB	4.4	6.5	9.7	11.7	12.0	11.6	11.7	12.2	11.0	9.7	6.8	4.8	(38)
(39)			MCWBR	4.0	5.0	6.6	6.5	6.7	6.4	5.8	5.7	5.9	6.4	5.2	4.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.312	0.339	0.375	0.429	0.416	0.414	0.439	0.434	0.398	0.364	0.347	0.310	(40)	
(41)		taud	2.242	2.226	2.216	2.127	2.224	2.257	2.201	2.214	2.276	2.347	2.302	2.291	(41)	
(42)		Ebn at Noon	685	770	811	806	839	843	812	794	780	737	637	628	(42)	
(43)		Edh at Noon	70	93	114	140	133	130	135	127	107	83	67	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.78	1.53	2.75	4.11	5.17	5.53	5.22	4.67	3.24	1.90	0.83	0.56	(44)	
(45)		RadStd	0.13	0.23	0.37	0.48	0.53	0.44	0.54	0.35	0.49	0.30	0.09	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.50	N/A	N/A	+0.86	N/A	N/A	N/A	-166	+80	+32	(46)
(47)	Regional (20 neighbors)	+0.55	N/A	N/A	+0.80	+0.41	N/A	N/A	-176	+88	+36	(47)

Nomenclature: See separate page