

JELENIA GORA, Poland

WMO: 125000

Lat: 50.9003N

Lon: 15.7889E

Elev: 1126

StdP: 14.11

Time Zone: 1.00 (EUC)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.1	8.0	-3.1	4.8	2.1	3.2	6.8	9.9	23.4	40.2	21.0	39.8	1.7	150	0.544

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	84.4	67.2	80.7	65.5	77.5	64.2	69.0	80.9	67.2	77.7	65.5	74.9	6.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	96.8	73.2	63.5	91.4	71.0	62.0	86.5	69.2	33.8	81.3	32.3	77.8	30.9	75.4	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.8	16.3	14.2	-5.9	90.0	8.5	3.2	-12.0	92.3	-17.0	94.1	-21.8	95.9	-27.9	98.2		
			-6.1	72.0	8.4	1.5	-12.1	73.1	-17.0	73.9	-21.8	74.7	-27.9	75.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.1	28.7	31.2	36.7	45.6	53.8	59.2	63.1	62.4	54.6	46.9	38.5	31.0
	DBStd	14.28	10.31	9.43	7.76	7.57	6.56	6.14	5.46	5.62	5.96	7.21	7.51	9.61
	HDD50	2918	661	526	414	171	34	4	0	0	22	145	351	590
	HDD65	7023	1126	945	876	582	352	193	103	119	315	561	796	1055
	CDD50	1478	0	1	3	40	151	280	406	384	159	49	5	0
	CDD65	106	0	0	0	0	4	19	44	37	2	0	0	0
	CDH74	1565	0	0	0	12	88	297	601	507	59	1	0	0
	CDH80	382	0	0	0	0	8	70	164	131	9	0	0	0
Wind	WSAvg	5.2	6.0	6.2	6.3	5.5	5.0	4.6	4.4	3.9	4.3	5.1	5.3	5.7
Precipitation	PrecAvg	33.5	2.6	2.2	2.6	1.8	2.9	3.5	4.5	3.4	2.8	2.2	2.4	2.6
	PrecMax	41.6	5.6	3.6	5.7	3.1	5.0	8.3	14.5	13.1	5.9	6.0	4.9	5.4
	PrecMin	23.6	0.4	0.2	0.9	0.2	1.5	1.5	0.8	1.1	0.9	0.3	0.1	0.9
	PrecStd	5.2	1.3	1.0	1.1	0.7	1.1	1.6	2.6	2.6	1.5	1.3	1.1	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.9	55.3	64.6	75.6	80.9	86.7	89.6	90.0	80.7	72.2	60.8	53.1
		MCWB	46.7	46.5	50.7	58.3	63.2	68.6	67.7	69.0	64.1	60.0	52.5	47.5
	2%	DB	49.2	51.0	58.5	70.1	76.6	81.7	84.8	83.4	74.7	66.9	56.8	49.9
		MCWB	44.1	44.6	47.6	55.2	62.2	66.4	66.9	66.8	61.9	57.2	51.1	45.0
	5%	DB	45.9	47.8	53.9	65.3	72.4	77.1	80.7	79.4	71.3	63.0	53.6	47.1
		MCWB	41.7	42.4	45.8	52.7	59.6	63.9	66.0	65.5	60.6	55.2	48.5	42.8
	10%	DB	42.5	44.8	49.8	61.2	68.4	73.1	76.8	75.9	67.4	59.4	50.7	43.9
		MCWB	38.9	40.6	43.7	50.7	57.4	61.9	64.5	63.6	59.0	53.3	46.6	40.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.5	47.9	51.5	59.5	66.2	71.1	70.9	70.6	66.2	61.8	53.9	48.3
		MCDB	51.9	53.1	61.3	73.3	76.5	82.8	82.1	83.5	76.9	69.8	58.9	52.1
	2%	WB	44.7	45.6	48.8	56.4	63.2	67.7	68.8	68.8	63.6	58.3	51.4	45.4
		MCDB	48.7	50.2	56.6	67.9	73.9	78.0	80.6	80.8	72.0	64.8	55.9	49.4
	5%	WB	41.7	43.0	46.4	53.7	60.7	65.2	67.2	66.7	61.7	55.8	49.1	43.0
		MCDB	45.5	47.3	53.1	64.0	69.9	74.9	77.9	76.6	69.3	61.8	53.0	46.8
	10%	WB	39.1	40.4	43.9	51.2	58.6	62.9	65.5	64.9	59.6	53.9	46.7	40.5
		MCDB	42.4	44.7	49.2	59.8	67.1	70.9	74.6	73.4	66.3	58.6	50.4	43.7
Mean Daily Temperature Range	5% DB	MDBR	12.6	13.6	16.0	19.8	20.2	19.5	19.8	21.3	18.4	16.6	13.2	12.0
		MCDBR	13.8	17.7	26.6	29.2	28.0	28.6	28.9	28.5	26.6	24.0	18.2	13.6
		MCWBR	10.4	12.3	16.7	15.9	15.0	14.2	13.3	13.4	14.9	15.2	13.1	10.4
	5% WB	MCDBR	13.2	15.4	23.6	26.6	24.8	25.6	24.9	25.4	23.6	22.1	17.1	13.0
		MCWBR	10.4	11.4	15.3	15.0	14.0	13.4	12.4	12.7	14.0	14.7	12.9	10.4
Clear-Sky Solar Irradiance	taub		0.316	0.344	0.392	0.444	0.441	0.436	0.457	0.449	0.405	0.376	0.346	0.310
	taud		2.265	2.228	2.148	2.076	2.131	2.185	2.137	2.172	2.258	2.296	2.314	2.313
	Ebn at Noon		219	243	251	251	259	261	253	248	246	229	205	203
	Edh at Noon		22	30	39	47	46	44	46	42	35	28	21	18
All-Sky Solar Radiation	RadAvg		249	478	803	1297	1576	1675	1585	1404	1002	575	272	183
	RadStd		42	79	118	173	182	142	187	134	137	82	37	19

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only			N/A	N/A	N/A	N/A	N/A	+0.72	N/A	N/A	N/A
Regional (43 neighbors)			+0.81	N/A	N/A	N/A	N/A	+0.56	N/A	N/A	+106

Nomenclature: See separate page