

SNIEZKA, Poland

WMO: 125100

Lat: 50.7361N

Lon: 15.7394E

Elev: 1613

StdP: 83.39

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.7	-14.8	-27.3	0.4	-5.4	-23.2	0.6	-7.7	37.0	-3.4	34.6	-3.3	15.0	340	1.285

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.2	18.8	13.5	17.2	12.7	15.7	12.0	14.5	17.3	13.6	16.1	12.7	15.0	5.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.5	11.7	15.4	12.6	11.0	14.6	11.6	10.4	13.8	46.3	17.5	43.5	16.1	41.0	15.2	18.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.0	28.3	25.3	DB	-18.9	21.5	2.4	1.6	-20.6	22.6	-22.1	23.5	-23.4	24.4	-25.2	25.6	(4)
(5)			WB	-19.2	16.3	2.4	0.9	-20.9	16.9	-22.3	17.5	-23.7	18.0	-25.4	18.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.5	-6.2	-6.3	-4.2	0.1	4.7	7.9	9.9	10.0	5.7	2.4	-1.5	-4.8	(6)	
	DBStd	7.33	4.33	4.74	4.56	4.77	4.29	4.23	3.90	3.75	3.88	4.67	4.72	4.64	(7)	
	HDD10.0	3236	502	456	442	297	173	91	52	47	136	239	344	457	(8)	
	HDD18.3	6136	761	689	700	546	424	314	261	259	378	495	594	716	(9)	
	CDD10.0	142	0	0	0	1	8	27	49	47	8	3	1	0	(10)	
	CDD18.3	1	0	0	0	0	0	0	1	1	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	11.9	14.8	14.5	13.6	11.4	10.2	9.3	9.5	8.5	10.3	12.5	13.4	14.6	(14)	
(15) Precipitation	PrecAvg	985	86	70	76	47	75	96	116	99	81	68	80	90	(15)	
	PrecMax	1221	197	166	192	95	137	195	306	280	175	198	174	189	(16)	
	PrecMin	699	9	14	25	4	36	40	32	39	24	15	2	41	(17)	
	PrecStd	135	45	35	40	21	31	36	55	59	40	39	37	37	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.2	5.8	7.2	12.5	16.2	19.9	20.9	20.8	16.2	14.9	11.4	8.1	(19)	
		MCWB	0.6	0.7	2.0	7.8	11.3	14.3	14.3	14.0	11.6	7.7	3.4	2.2	(20)	
	2%	DB	3.3	3.7	5.1	10.5	14.2	17.6	18.9	18.5	14.0	12.2	8.5	4.9	(21)	
		MCWB	-0.4	0.0	1.3	6.5	10.4	13.1	13.6	13.5	10.7	6.6	3.7	0.0	(22)	
	5%	DB	1.3	1.7	3.5	8.3	12.4	15.7	17.1	16.7	12.5	10.3	6.5	3.3	(23)	
		MCWB	-0.8	-0.5	1.2	5.2	9.3	12.2	12.8	12.8	9.8	6.3	3.4	0.4	(24)	
	10%	DB	-0.1	-0.1	2.0	6.5	10.6	13.9	15.4	15.1	11.1	8.6	5.0	1.5	(25)	
		MCWB	-1.3	-1.3	0.7	4.3	8.2	11.0	12.1	12.0	9.1	6.1	2.8	-0.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.4	2.9	4.2	8.6	12.6	15.6	15.8	15.4	13.0	10.2	6.7	3.7	(27)	
		MCDB	2.8	3.9	5.3	11.4	15.1	18.1	18.8	18.4	15.0	11.5	8.0	5.4	(28)	
	2%	WB	0.9	1.3	2.9	7.1	11.0	14.1	14.4	14.3	11.6	8.6	5.5	2.4	(29)	
		MCDB	2.3	2.5	3.9	9.5	13.2	16.4	17.2	17.0	13.1	10.1	6.6	3.5	(30)	
	5%	WB	-0.1	0.0	1.8	5.8	9.7	12.6	13.5	13.4	10.5	7.5	4.2	1.2	(31)	
		MCDB	1.0	0.8	2.8	7.6	11.7	15.0	16.1	15.9	11.9	8.9	5.5	2.3	(32)	
	10%	WB	-1.4	-1.3	0.7	4.5	8.5	11.3	12.6	12.5	9.6	6.6	3.2	-0.1	(33)	
		MCDB	-0.3	-0.4	1.6	6.2	10.3	13.4	14.9	14.7	10.7	7.9	4.7	0.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.3	4.2	4.2	4.2	4.5	4.5	4.3	4.2	3.7	4.1	4.2	4.3	(35)	
		MCDBR	5.5	5.7	5.0	5.5	6.1	6.3	6.0	5.9	5.0	5.6	5.6	5.7	(36)	
	5% WB	MCWBR	4.1	4.5	4.1	4.0	4.5	5.1	4.0	4.2	4.3	4.4	3.7	4.2	(37)	
		MCWBR	4.8	5.3	4.9	5.4	5.6	5.9	5.5	5.4	4.6	4.8	5.2	5.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.260	0.281	0.316	0.355	0.354	0.351	0.365	0.360	0.329	0.309	0.286	0.256	(40)	
		taud	2.380	2.373	2.343	2.300	2.328	2.352	2.308	2.344	2.417	2.458	2.457	2.420	(41)	
	Edn at Noon	Edn at Noon	790	863	887	886	901	904	883	870	864	818	750	742	(42)	
		Edh at Noon	61	80	100	118	120	118	121	111	92	74	57	50	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.80	1.53	2.54	4.09	4.96	5.28	4.99	4.43	3.16	1.81	0.86	0.58	(44)	
	RadStd	RadStd	0.14	0.24	0.38	0.54	0.57	0.45	0.59	0.43	0.43	0.26	0.11	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (47 neighbors)	+0.44	N/A	N/A	N/A	N/A	+0.31	N/A	N/A	+58	+21

Nomenclature: See separate page