

RZESZOW JASIONKA, Poland

WMO: 125800

Lat: 50.110N

Lon: 22.019E

Elev: 675

StdP: 14.34

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.8	8.9	-1.9	5.1	3.4	4.5	7.1	9.6	27.9	35.2	25.7	34.8	5.6	90	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	86.7	69.5	83.7	68.0	80.5	66.6	71.4	83.0	69.7	80.6	68.0	77.5	8.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	104.2	76.8	66.0	98.3	74.4	64.5	93.1	72.2	35.6	83.0	34.0	80.7	32.7	77.6	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.2	20.2	17.9	-4.1	91.3	7.3	2.7	-9.4	93.2	-13.6	94.8	-17.7	96.3	-23.0	98.3		
			-4.6	74.8	7.2	1.5	-9.8	75.9	-14.0	76.8	-18.0	77.7	-23.3	78.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.0	28.1	30.7	37.9	48.4	57.2	63.4	67.0	65.9	57.2	48.2	39.8	31.0
	DBStd	15.72	9.91	9.96	8.53	7.39	6.69	6.00	5.59	5.70	6.41	7.76	8.43	9.16
	HDD50	2782	680	540	383	113	15	0	0	0	12	131	319	589
	HDD65	6478	1145	960	841	499	254	100	45	58	244	522	757	1053
	CDD50	2044	0	0	6	65	237	403	526	493	228	74	12	0
	CDD65	268	0	0	0	1	11	53	106	86	11	0	0	0
	CDH74	2813	0	0	0	22	183	546	1073	858	129	2	0	0
	CDH80	765	0	0	0	2	27	127	331	258	20	0	0	0
Wind	WSAvg	8.0	9.8	9.5	9.3	7.8	7.0	6.8	6.5	6.0	6.7	7.9	9.1	9.9
Precipitation	PrecAvg	27.1	1.4	1.3	1.6	2.0	3.2	3.4	3.9	2.7	2.8	2.0	1.5	1.3
	PrecMax	39.4	3.3	2.8	3.3	3.9	7.6	5.8	9.4	4.8	6.3	4.0	3.3	2.6
	PrecMin	19.9	0.4	0.5	0.6	0.2	1.5	0.6	0.7	0.6	0.5	0.2	0.0	0.4
	PrecStd	4.0	0.6	0.6	0.8	0.9	1.3	1.4	2.2	1.3	1.6	1.2	0.8	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.3	54.7	64.4	77.1	83.6	87.5	91.1	91.4	82.3	72.8	62.5	52.1
		MCWB	44.9	46.5	50.6	59.8	64.7	70.8	70.7	70.9	64.5	60.8	53.2	46.6
	2%	DB	45.4	50.0	59.0	71.6	78.8	83.9	87.4	86.1	77.6	68.3	58.3	48.1
		MCWB	42.1	44.7	48.3	56.2	63.6	68.9	70.0	69.0	64.0	58.9	51.6	44.8
	5%	DB	42.7	46.5	54.9	67.0	75.2	80.2	83.9	82.5	73.7	64.5	55.2	44.7
		MCWB	39.9	42.2	46.3	54.2	62.3	66.9	68.3	67.8	62.3	57.3	50.2	41.8
	10%	DB	40.2	43.4	50.8	62.8	71.5	76.8	80.3	78.8	69.8	60.5	51.8	41.6
		MCWB	37.8	40.2	44.5	52.0	60.2	64.8	66.9	66.0	60.4	54.9	48.3	39.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.6	47.9	52.2	60.1	67.9	72.9	73.9	73.3	67.5	62.4	54.7	47.8
		MCDB	48.2	52.0	61.0	74.5	79.7	84.4	85.9	85.6	78.5	69.8	59.9	51.6
	2%	WB	42.5	45.0	49.5	57.5	65.2	70.4	71.6	70.8	65.1	59.9	52.6	44.7
		MCDB	44.8	49.4	57.0	68.5	75.6	80.8	83.3	82.5	74.4	66.7	57.3	47.7
	5%	WB	40.2	42.7	47.2	55.4	63.0	68.1	69.7	69.0	63.3	57.7	50.5	42.0
		MCDB	42.3	45.9	53.5	64.7	72.8	77.4	80.8	79.8	71.6	63.7	54.2	44.2
	10%	WB	37.8	40.4	44.8	53.1	61.0	66.1	68.1	67.3	61.3	55.4	48.4	39.6
		MCDB	40.0	43.2	50.2	61.3	69.9	74.5	77.4	76.2	68.5	59.9	51.6	41.5
Mean Daily Temperature Range	5% DB	MDBR	8.9	11.3	14.5	19.5	20.2	19.8	20.4	20.7	18.2	15.3	10.6	8.7
		MCDBR	10.0	15.2	22.2	27.8	26.7	25.8	26.9	26.3	25.3	21.7	15.7	11.3
		MCWBR	7.8	10.5	13.3	14.5	13.6	12.5	11.3	11.4	12.9	12.9	10.1	8.8
	5% WB	MCDBR	9.7	14.4	19.9	25.0	24.6	23.0	23.8	23.7	22.0	20.0	13.6	11.0
		MCWBR	7.9	10.6	12.7	13.7	13.2	11.8	10.9	11.1	11.7	12.4	9.5	8.7
Clear-Sky Solar Irradiance	taub	0.319	0.343	0.386	0.440	0.429	0.430	0.451	0.445	0.410	0.374	0.350	0.314	
	taud	2.255	2.221	2.199	2.105	2.197	2.226	2.181	2.196	2.251	2.327	2.321	2.312	
	Ebn at Noon	221	246	256	254	263	264	255	250	246	233	208	206	
	Edh at Noon	23	30	37	46	43	43	44	42	35	28	22	19	
All-Sky Solar Radiation	RadAvg	271	510	875	1293	1594	1705	1633	1489	1042	632	304	205	
	RadStd	44	82	111	144	188	137	177	117	152	92	36	28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (29 neighbors)	+1.15	N/A	N/A	+1.64	N/A	N/A	-284	-400	+200	+95
		+0.99	N/A	N/A	+1.64	+0.90	+0.77	-220	-311	+146	+59

Nomenclature: See separate page