

KASPROWY WIERCH, Poland

WMO: 126500

Lat: 49.2325N

Lon: 19.9819E

Elev: 6525

StdP: 11.55

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.2	1.7	-22.2	2.1	19.9	-15.7	3.0	18.3	46.4	24.1	42.0	22.8	16.5	60	0.944

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.9	62.7	54.2	60.1	52.9	57.7	51.5	55.8	60.1	54.1	58.4	52.6	56.7	9.4	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.0	79.1	57.7	52.2	74.2	56.1	50.7	69.9	54.5	26.5	60.4	25.3	58.7	24.3	56.9	64.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.0	34.8	30.8	DB	-7.0	67.7	4.6	2.6	-10.3	69.5	-13.0	71.0	-15.6	72.5	-18.9	74.4	(4)
(5)			WB	-7.6	59.7	4.6	2.1	-10.9	61.1	-13.6	62.4	-16.1	63.5	-19.5	65.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	32.4	18.0	18.0	20.9	29.6	38.0	44.4	47.9	48.3	40.4	34.4	27.4	20.8	(6)
(7)		DBStd	13.60	8.54	8.48	8.11	8.12	7.66	7.44	6.75	6.56	7.30	8.81	9.02	8.94	(7)
(8)		HDD50	6574	991	897	903	612	378	196	121	112	295	486	679	904	(8)
(9)		HDD65	11891	1456	1317	1368	1062	838	617	529	519	738	949	1129	1369	(9)
(10)		CDD50	158	0	0	0	0	4	30	57	58	7	2	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	14.2	16.7	16.9	15.7	14.0	12.5	11.4	11.4	10.6	12.1	15.0	17.6	16.9	(14)
(15)	Precipitation	PrecAvg	45.1	2.2	2.2	2.6	3.0	5.0	5.6	6.8	4.8	4.2	3.3	3.0	2.2	(15)
(16)		PrecMax	59.3	5.5	6.9	5.9	6.0	12.5	8.7	14.8	8.5	8.4	6.1	4.7	5.2	(16)
(17)		PrecMin	33.7	0.4	0.4	0.3	0.4	2.2	2.6	2.4	1.5	1.2	0.6	0.0	0.6	(17)
(18)		PrecStd	6.2	1.4	1.3	1.3	1.4	2.2	1.7	3.2	2.0	2.0	1.5	1.2	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.2	38.0	39.4	49.9	57.6	65.0	66.2	66.2	58.7	56.4	51.1	43.2	(19)
(20)		0.4%	MCWB	29.1	30.0	32.1	42.1	48.5	54.9	55.9	54.7	51.3	41.4	38.2	31.0	(20)
(21)		2%	DB	36.1	34.7	36.4	45.4	53.8	60.8	62.7	62.4	54.9	52.2	44.1	38.6	(21)
(22)		2%	MCWB	28.8	28.8	31.2	39.5	46.7	53.3	54.3	54.3	48.7	41.1	36.2	29.3	(22)
(23)		5%	DB	32.3	31.9	34.1	42.2	51.1	57.7	59.7	59.7	52.3	48.6	40.9	35.0	(23)
(24)		5%	MCWB	28.5	28.6	30.8	37.0	45.3	51.7	53.1	52.9	47.0	40.3	35.4	28.6	(24)
(25)		10%	DB	29.8	29.2	31.9	39.5	48.5	54.6	57.0	57.2	49.9	45.5	38.6	32.5	(25)
(26)		10%	MCWB	27.4	26.8	29.7	35.5	44.0	49.7	51.8	51.7	45.5	39.6	34.4	28.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.6	33.1	35.2	43.0	51.3	57.5	58.6	57.5	52.7	47.3	41.8	35.0	(27)
(28)		0.4%	MCDWB	35.1	34.3	36.2	48.0	55.5	61.7	63.4	62.2	56.5	50.5	45.8	36.3	(28)
(29)		2%	WB	31.4	31.0	33.2	40.2	48.4	54.5	55.6	55.6	50.2	44.8	39.4	32.9	(29)
(30)		2%	MCDWB	32.8	32.9	34.4	44.3	51.9	58.8	59.8	60.3	53.2	46.8	40.9	34.5	(30)
(31)		5%	WB	29.6	29.1	31.5	38.1	46.2	52.3	54.0	53.9	48.5	43.1	37.4	31.3	(31)
(32)		5%	MCDWB	31.2	31.0	33.0	41.2	49.8	56.6	58.1	58.5	51.1	45.6	38.8	33.0	(32)
(33)		10%	WB	27.6	27.2	29.9	36.2	44.4	50.3	52.6	52.2	46.7	41.4	35.6	29.6	(33)
(34)		10%	MCDWB	29.7	28.7	31.7	38.7	47.8	53.6	56.4	56.3	49.1	44.1	37.2	31.6	(34)
(35)	Mean Daily Temperature Range		MDBR	8.3	8.5	8.5	7.8	8.4	9.1	8.9	8.9	7.7	7.8	7.7	8.1	(35)
(36)		5% DB	MCDBR	9.7	10.4	9.3	9.1	10.8	12.8	11.7	11.2	9.8	9.4	8.4	9.2	(36)
(37)			MCWBR	7.9	9.1	8.2	6.8	8.4	9.7	8.3	9.0	9.2	8.7	7.1	6.6	(37)
(38)			5% WB	MCDWB	9.2	9.9	8.5	8.5	10.0	11.4	10.3	10.5	9.0	8.1	7.2	8.7
(39)		MCWBR		8.8	9.7	8.3	6.7	8.5	9.5	8.3	9.1	8.7	8.3	7.0	8.4	(39)
(40)		Clear-Sky Solar Irradiance	taub	0.236	0.256	0.291	0.336	0.335	0.337	0.346	0.342	0.318	0.293	0.269	0.236	(40)
(41)	taud		2.373	2.338	2.342	2.352	2.397	2.406	2.370	2.391	2.449	2.516	2.510	2.431	(41)	
(42)	Ebn at Noon		270	288	293	289	293	292	287	284	281	272	256	256	(42)	
(43)	Edh at Noon		20	27	32	36	36	36	36	34	29	23	18	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	289	528	891	1296	1558	1667	1615	1479	1044	637	325	223	(44)	
(45)		RadStd	44	80	133	148	197	155	181	132	152	90	45	25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.81	N/A	N/A	N/A	+0.99	+0.90	N/A	N/A	N/A	N/A
(47)	Regional (46 neighbors)	+1.03	N/A	N/A	+1.71	+0.90	+0.77	-234	-331	+158	+68

Nomenclature: See separate page