

KASPROWY WIERCH, Poland

WMO: 126500

Lat: 49.2325N

Lon: 19.9819E

Elev: 1989

StdP: 79.61

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-19.0	-16.8	-30.1	0.3	-6.7	-26.5	0.4	-7.6	20.7	-4.4	18.8	-5.1	7.4	60	0.944

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	17.1	12.3	15.6	11.6	14.3	10.9	13.2	15.6	12.3	14.7	11.4	13.7	4.2	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	11.3	14.3	11.2	10.6	13.4	10.4	10.0	12.5	43.8	15.8	41.1	14.8	38.6	13.8	17.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.4	15.6	13.8	DB	-21.7	19.8	2.5	1.4	-23.5	20.8	-25.0	21.7	-26.4	22.5	-28.3	23.5	(4)
(5)			WB	-22.0	15.4	2.5	1.2	-23.8	16.2	-25.3	16.9	-26.7	17.5	-28.6	18.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.2	-7.8	-7.8	-6.2	-1.3	3.3	6.9	8.9	9.0	4.7	1.3	-2.6	-6.2	(6)	
	DBStd	7.56	4.75	4.71	4.50	4.51	4.26	4.13	3.75	3.65	4.05	4.89	5.01	4.97	(7)	
	HDD10.0	3652	551	498	502	340	210	109	67	62	164	270	377	502	(8)	
	HDD18.3	6606	809	732	760	590	466	343	294	288	410	527	627	761	(9)	
	CDD10.0	88	0	0	0	0	2	17	32	32	4	1	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.4	7.5	7.6	7.0	6.3	5.6	5.1	5.1	4.7	5.4	6.7	7.9	7.5	(14)	
(15) Precipitation	PrecAvg	1145	57	57	67	77	127	142	173	122	106	85	76	56	(15)	
	PrecMax	1506	140	174	151	153	317	220	375	217	213	156	120	133	(16)	
	PrecMin	857	11	11	8	11	56	66	60	37	31	15	1	16	(17)	
	PrecStd	158	35	32	34	36	56	43	81	52	51	38	30	26	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.5	3.3	4.1	10.0	14.2	18.3	19.0	19.0	14.9	13.6	10.6	6.2	(19)	
		MCWB	-1.6	-1.1	0.1	5.6	9.2	12.7	13.3	12.6	10.7	5.2	3.4	-0.5	(20)	
	2%	DB	2.3	1.5	2.4	7.4	12.1	16.0	17.1	16.9	12.7	11.2	6.7	3.6	(21)	
		MCWB	-1.8	-1.8	-0.5	4.2	8.2	11.8	12.4	12.4	9.3	5.1	2.3	-1.5	(22)	
	5%	DB	0.1	0.0	1.2	5.7	10.6	14.3	15.4	15.4	11.3	9.2	4.9	1.7	(23)	
		MCWB	-1.9	-1.9	-0.7	2.8	7.4	10.9	11.7	11.6	8.3	4.6	1.9	-1.9	(24)	
	10%	DB	-1.2	-1.6	-0.1	4.2	9.2	12.6	13.9	14.0	9.9	7.5	3.7	0.3	(25)	
		MCWB	-2.6	-2.9	-1.3	1.9	6.7	9.8	11.0	11.0	7.5	4.2	1.3	-1.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.9	0.6	1.8	6.1	10.7	14.2	14.8	14.2	11.5	8.5	5.4	1.6	(27)	
		MCDB	1.7	1.3	2.3	8.9	13.1	16.5	17.4	16.8	13.6	10.3	7.6	2.4	(28)	
	2%	WB	-0.4	-0.6	0.7	4.5	9.1	12.5	13.1	13.1	10.1	7.1	4.1	0.5	(29)	
		MCDB	0.4	0.5	1.3	6.9	11.1	14.9	15.5	15.7	11.8	8.2	4.9	1.4	(30)	
	5%	WB	-1.3	-1.6	-0.3	3.4	7.9	11.3	12.2	12.2	9.1	6.2	3.0	-0.4	(31)	
		MCDB	-0.4	-0.6	0.6	5.1	9.9	13.6	14.5	14.7	10.6	7.6	3.8	0.6	(32)	
	10%	WB	-2.4	-2.7	-1.2	2.3	6.9	10.2	11.4	11.2	8.1	5.2	2.0	-1.4	(33)	
		MCDB	-1.3	-1.8	-0.2	3.7	8.8	12.0	13.6	13.5	9.5	6.7	2.9	-0.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.6	4.7	4.7	4.4	4.7	5.0	5.0	5.0	4.3	4.4	4.3	4.5	(35)	
		MCDBR	5.4	5.8	5.1	5.1	6.0	7.1	6.5	6.2	5.5	5.2	4.6	5.1	(36)	
	5% WB	MCWBR	4.4	5.1	4.6	3.8	4.7	5.4	4.6	5.0	5.1	4.8	3.9	3.7	(37)	
		MCWBR	5.1	5.5	4.7	4.7	5.6	6.4	5.7	5.8	5.0	4.5	4.0	4.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.236	0.256	0.291	0.336	0.335	0.337	0.346	0.342	0.318	0.293	0.269	0.236	(40)	
		taud	2.373	2.338	2.342	2.352	2.397	2.406	2.370	2.391	2.449	2.516	2.510	2.431	(41)	
	Ebn at Noon		851	909	925	912	924	921	906	894	885	857	806	806	(42)	
		Edh at Noon	63	84	101	113	113	113	115	107	91	72	57	53	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.91	1.66	2.81	4.09	4.91	5.26	5.09	4.66	3.29	2.01	1.02	0.70	(44)	
	RadStd		0.14	0.25	0.42	0.47	0.62	0.49	0.57	0.41	0.48	0.28	0.14	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.45	N/A	N/A	N/A	+0.55	+0.50	N/A	N/A	N/A	N/A
(47) Regional (46 neighbors)		+0.57	N/A	N/A	+0.95	+0.50	+0.43	-130	-184	+88	+38

Nomenclature: See separate page