

NOWY SACZ, Poland

WMO: 126600

Lat: 49.6271N

Lon: 20.6886E

Elev: 296

StdP: 97.82

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.6	-12.0	-17.6	0.8	-15.0	-14.5	1.1	-11.2	9.0	3.5	8.0	3.5	0.9	110	0.478

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	30.5	20.5	28.6	19.8	26.9	18.9	21.7	28.1	20.7	26.8	19.8	25.3	2.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.6	14.9	24.6	18.7	14.0	23.3	17.8	13.3	22.2	64.6	28.1	61.2	27.1	58.0	25.3	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	5.9	4.9	-18.9	33.5	4.4	1.5	-22.1	34.6	-24.7	35.4	-27.1	36.3	-30.3	37.4		
(5)			-19.2	24.0	4.3	1.8	-22.3	25.3	-24.8	26.4	-27.3	27.4	-30.4	28.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	-1.4	0.0	4.0	9.8	14.1	17.5	19.3	18.9	14.4	9.8	5.0	0.1	(6)
(7)		DBStd	8.44	5.46	5.49	4.62	3.88	3.65	3.45	3.10	3.11	3.37	4.19	4.70	4.81	(7)
(8)		HDD10.0	1408	352	280	189	49	8	0	0	0	4	58	161	306	(8)
(9)		HDD18.3	3430	611	513	443	258	137	56	27	30	124	267	401	564	(9)
(10)		CDD10.0	1170	0	1	4	42	134	227	288	277	137	50	9	1	(10)
(11)		CDD18.3	149	0	0	0	1	6	32	57	49	6	1	0	0	(11)
(12)		CDH23.3	1517	0	0	0	21	123	323	525	450	69	5	0	0	(12)
(13)		CDH26.7	416	0	0	0	2	19	89	159	136	10	0	0	0	(13)
(14)	Wind	WSAvg	1.7	2.0	2.0	2.3	1.9	1.6	1.6	1.5	1.3	1.4	1.6	1.8	1.9	(14)
(15)	Precipitation	PrecAvg	821	41	39	47	59	99	112	127	88	75	55	44	35	(15)
(16)		PrecMax	1223	94	82	111	125	291	229	278	164	166	134	86	78	(16)
(17)		PrecMin	627	13	13	10	9	44	28	27	15	16	6	1	8	(17)
(18)		PrecStd	128	20	18	22	28	50	51	72	42	41	32	22	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.5	14.5	18.8	26.0	28.8	31.8	32.8	33.0	28.2	23.7	18.1	12.9	(19)
(20)			MCWB	7.5	8.7	10.4	15.5	17.5	21.0	21.1	21.1	18.7	15.8	12.8	8.9	(20)
(21)		2%	DB	8.9	11.1	16.0	22.5	26.6	29.3	30.4	30.0	25.4	21.5	15.7	10.5	(21)
(22)			MCWB	6.0	7.1	9.4	13.6	16.9	20.2	20.5	20.7	17.7	15.2	11.3	7.2	(22)
(23)		5%	DB	7.0	9.3	13.8	19.9	24.5	26.9	28.4	28.0	23.3	19.1	14.0	8.6	(23)
(24)			MCWB	4.7	6.0	8.3	12.2	16.4	19.1	20.0	20.0	16.7	14.0	10.0	5.9	(24)
(25)		10%	DB	5.4	7.3	11.6	17.6	22.1	24.9	26.4	25.8	21.3	16.7	12.0	6.4	(25)
(26)			MCWB	3.4	4.8	7.2	11.2	15.4	17.9	19.1	19.0	15.8	13.0	9.0	4.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	9.2	11.2	16.2	19.4	22.5	23.1	23.3	19.6	17.2	13.2	9.1	(27)
(28)			MCD B	10.6	12.8	16.7	23.8	26.1	28.9	29.3	30.0	25.7	22.0	17.7	12.3	(28)
(29)		2%	WB	6.3	7.6	10.0	14.4	18.0	21.1	21.6	21.6	18.4	15.6	11.7	7.6	(29)
(30)			MCD B	8.4	10.6	15.3	21.1	23.7	27.5	27.8	27.9	23.8	20.2	15.2	10.2	(30)
(31)		5%	WB	4.9	6.2	8.7	12.9	16.9	19.7	20.7	20.6	17.3	14.4	10.4	6.0	(31)
(32)			MCD B	6.8	9.0	13.1	18.6	23.3	25.4	26.7	26.5	22.2	18.5	13.5	8.3	(32)
(33)		10%	WB	3.6	4.8	7.4	11.7	15.8	18.7	19.8	19.6	16.3	13.2	9.1	4.6	(33)
(34)			MCD B	5.2	7.1	11.2	16.5	21.3	23.5	25.1	24.7	20.4	16.5	11.7	6.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.3	7.5	8.8	11.0	11.3	10.6	10.8	11.2	10.4	9.3	7.1	6.1	(35)
(36)			MCD BR	7.1	10.7	13.6	15.9	16.3	14.7	14.9	14.9	14.5	13.7	10.1	8.0	(36)
(37)			MCWBR	5.1	7.0	7.9	8.0	7.9	6.7	6.3	6.7	7.5	7.9	6.2	5.5	(37)
(38)		5% WB	MCD BR	6.7	9.7	12.7	14.2	14.2	13.0	12.7	13.6	12.8	12.4	9.3	7.6	(38)
(39)			MCWBR	5.1	6.7	7.7	7.8	7.4	6.4	6.1	6.5	7.0	7.5	6.0	5.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.308	0.334	0.380	0.437	0.432	0.435	0.450	0.445	0.409	0.371	0.340	0.305	(40)	
(41)		taud	2.289	2.238	2.205	2.118	2.189	2.219	2.185	2.204	2.263	2.346	2.366	2.352	(41)	
(42)		Ebn at Noon	724	794	817	805	829	828	807	791	779	745	683	679	(42)	
(43)		Edh at Noon	71	95	118	143	139	136	139	130	111	86	67	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.89	1.66	2.79	4.02	4.88	5.18	5.01	4.63	3.26	1.99	1.00	0.68	(44)	
(45)		RadStd	0.13	0.24	0.35	0.46	0.63	0.47	0.59	0.37	0.47	0.29	0.13	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	+0.57	N/A	N/A	+0.97	+0.52	+0.45	-128	-185	+85	+37

Nomenclature: See separate page