

SZECSENY, Hungary

WMO: 127560

Lat: 48.117N

Lon: 19.517E

Elev: 153

StdP: 99.50

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.9	-11.9	-18.4	0.8	-14.9	-14.9	1.0	-10.6	9.5	3.7	8.2	4.0	1.0	90	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	32.4	21.5	30.7	20.6	29.1	20.0	22.7	29.9	21.7	28.8	20.9	27.4	2.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.4	15.4	26.1	19.4	14.4	24.8	18.5	13.6	23.7	67.5	29.9	64.1	29.1	60.8	27.4	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	6.9	5.9	-19.1	34.8	5.0	1.6	-22.7	36.0	-25.6	36.9	-28.4	37.8	-32.0	39.0		
(5)			-19.2	24.4	4.9	0.9	-22.7	25.0	-25.5	25.5	-28.3	26.0	-31.8	26.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	-2.0	0.1	5.2	10.9	15.3	19.1	20.6	20.2	15.2	10.0	5.1	-0.2	(6)
(7)		DBStd	8.77	5.01	4.67	3.99	3.42	3.31	3.11	3.02	2.94	3.25	3.78	3.97	4.36	(7)
(8)		HDD10.0	1353	373	278	153	29	2	0	0	0	1	48	152	317	(8)
(9)		HDD18.3	3263	631	511	408	224	103	27	12	15	102	257	397	575	(9)
(10)		CDD10.0	1357	0	0	4	56	168	273	329	315	158	49	5	0	(10)
(11)		CDD18.3	224	0	0	0	1	10	50	83	72	9	0	0	0	(11)
(12)		CDH23.3	2957	0	0	0	30	212	643	1013	879	174	6	0	0	(12)
(13)		CDH26.7	1004	0	0	0	4	44	194	391	332	40	0	0	0	(13)
(14)	Wind	WSAvg	2.2	2.1	2.2	2.7	2.7	2.5	2.3	2.3	2.0	2.1	1.9	2.2	1.9	(14)
(15)	Precipitation	PrecAvg	663	35	36	33	47	73	75	89	66	53	53	52	43	(15)
(16)		PrecMax	1209	99	131	84	119	219	169	161	163	155	113	110	108	(16)
(17)		PrecMin	461	2	1	1	2	21	23	5	6	2	1	1	4	(17)
(18)		PrecStd	146	22	27	22	29	42	35	46	43	32	32	29	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	14.1	20.5	26.5	30.3	32.3	35.4	34.7	30.1	23.9	17.1	9.7	(19)
(20)			MCWB	7.9	8.4	11.7	16.5	18.3	22.1	21.8	21.5	19.3	16.7	13.2	7.8	(20)
(21)		2%	DB	7.8	10.4	18.1	23.6	27.7	30.7	32.7	32.3	27.6	21.6	14.4	7.9	(21)
(22)			MCWB	6.3	7.0	10.3	14.3	18.0	20.9	21.7	21.2	18.4	15.5	11.3	6.6	(22)
(23)		5%	DB	6.0	8.2	15.4	21.5	25.8	29.0	30.6	30.2	25.3	19.4	12.5	6.6	(23)
(24)			MCWB	4.9	5.8	9.2	13.0	17.2	20.1	20.8	20.5	17.4	14.6	10.2	5.4	(24)
(25)		10%	DB	4.3	6.5	12.9	19.4	23.6	27.2	28.8	28.3	23.1	16.9	10.9	5.4	(25)
(26)			MCWB	3.2	4.8	7.7	11.9	16.1	19.1	20.2	19.8	16.2	13.1	9.2	4.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	9.1	12.7	17.0	20.1	23.9	23.7	23.5	20.5	17.7	13.8	8.2	(27)
(28)			MCD B	9.6	13.5	18.2	24.8	27.2	30.3	30.8	30.4	28.2	22.3	16.2	9.5	(28)
(29)		2%	WB	6.4	7.5	11.1	15.1	18.9	22.2	22.6	22.4	19.3	16.1	12.0	6.8	(29)
(30)			MCD B	7.5	9.7	16.7	22.0	25.8	28.6	30.2	29.7	25.7	20.7	13.7	7.6	(30)
(31)		5%	WB	5.0	6.2	9.7	13.8	17.9	21.0	21.8	21.4	18.1	14.9	10.5	5.7	(31)
(32)			MCD B	5.9	8.0	14.3	19.8	24.0	27.2	29.0	28.6	23.8	18.5	11.9	6.5	(32)
(33)		10%	WB	3.3	4.9	8.3	12.7	16.8	19.9	20.8	20.5	17.0	13.6	9.3	4.5	(33)
(34)			MCD B	4.2	6.2	12.0	18.3	22.4	25.8	27.2	27.0	21.6	16.3	10.6	5.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	8.5	11.6	14.2	13.3	13.4	14.0	14.1	13.3	11.5	7.9	5.6	(35)
(36)			MCDBR	7.4	11.0	17.2	18.3	17.4	16.2	16.8	17.4	17.3	15.3	10.9	6.8	(36)
(37)			MCWBR	5.7	8.0	10.6	9.8	8.6	7.6	7.2	7.7	8.9	9.5	7.8	5.4	(37)
(38)		5% WB	MCD BR	6.7	10.2	15.0	16.0	15.1	14.4	15.1	15.4	14.8	13.6	9.4	6.0	(38)
(39)			MCWBR	5.4	7.6	9.7	8.9	8.0	7.3	6.9	7.4	7.9	8.6	7.0	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.347	0.388	0.441	0.432	0.433	0.447	0.445	0.415	0.385	0.359	0.324	(40)	
(41)		taud	2.336	2.292	2.235	2.118	2.196	2.232	2.197	2.211	2.259	2.314	2.339	2.365	(41)	
(42)		Ebn at Noon	734	797	819	808	833	833	814	796	782	742	681	684	(42)	
(43)		Edh at Noon	72	94	117	145	139	135	138	131	113	92	73	63	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.99	1.78	3.00	4.41	5.29	5.76	5.57	5.01	3.56	2.21	1.14	0.76	(44)	
(45)		RadStd	0.14	0.28	0.48	0.45	0.60	0.47	0.48	0.49	0.47	0.25	0.14	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		+0.57	N/A	N/A	+0.90	+0.54	+0.47	-123	-174	+89	+41

Nomenclature: See separate page