

JOSVAFO, Hungary

WMO: 127660

Lat: 48.485N

Lon: 20.540E

Elev: 1001

StdP: 14.17

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.5	14.2	-0.3	5.6	17.1	4.0	7.0	18.7	12.9	29.1	10.9	30.3	2.1	310	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.1	87.3	69.0	84.2	67.9	81.3	66.4	71.0	82.9	69.3	81.0	67.8	78.7	5.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	103.0	77.1	65.3	97.0	75.0	63.7	91.8	73.1	35.4	82.5	34.0	81.0	32.7	78.6	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	9.8	8.4	DB	5.7	91.2	4.9	3.4	2.2	93.6	-0.6	95.6	-3.4	97.5	-6.9	100.0	(4)
(5)			WB	4.7	74.0	4.7	1.8	1.3	75.3	-1.5	76.3	-4.1	77.3	-7.6	78.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.7	28.5	32.3	40.8	51.5	58.7	65.4	68.5	68.2	59.5	50.0	40.7	30.8	(6)	
	DBStd	15.66	7.68	7.49	8.01	6.68	6.16	5.90	5.58	5.46	6.27	7.10	7.20	7.24	(7)	
	HDD50	2500	667	496	295	60	7	0	0	0	3	93	285	594	(8)	
	HDD65	5976	1132	916	749	405	211	67	28	29	185	467	728	1059	(9)	
	CDD50	2378	0	0	11	105	275	461	573	565	289	92	7	0	(10)	
	CDD65	380	0	0	0	1	14	78	137	129	21	0	0	0	(11)	
	CDH74	3320	0	0	0	18	155	654	1184	1121	186	2	0	0	(12)	
	CDH80	897	0	0	0	1	19	140	365	339	33	0	0	0	(13)	
(14) Wind	WSAvg	3.4	2.6	2.9	4.0	4.2	4.2	4.1	3.9	3.7	3.5	3.0	2.7	2.4	(14)	
(15) Precipitation	PrecAvg	24.3	1.1	1.3	1.3	1.9	2.6	3.1	3.5	2.5	2.0	2.0	1.7	1.4	(15)	
	PrecMax	45.5	2.8	4.4	4.4	3.8	8.7	7.4	6.3	6.1	5.6	4.8	3.7	3.4	(16)	
	PrecMin	15.7	0.1	0.1	0.2	0.2	0.6	1.2	1.0	0.6	0.3	0.1	0.0	0.2	(17)	
	PrecStd	5.9	0.8	1.0	1.0	1.0	1.7	1.4	1.6	1.6	1.3	1.3	0.9	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.8	54.0	66.1	76.5	82.6	87.8	92.4	91.1	84.3	72.0	61.5	48.0	(19)	
		MCWB	42.7	44.0	51.3	58.6	64.1	70.4	69.1	68.7	65.5	59.8	53.4	43.5	(20)	
	2%	DB	44.7	49.1	62.2	71.6	77.9	83.8	87.3	87.4	79.1	68.1	56.5	44.9	(21)	
		MCWB	41.7	42.3	48.6	55.1	62.5	68.1	69.2	68.6	63.4	58.4	49.6	42.3	(22)	
	5%	DB	41.5	45.9	57.9	68.0	74.8	81.0	84.1	83.7	75.4	64.7	53.1	42.6	(23)	
		MCWB	39.3	41.2	46.5	53.3	61.1	66.5	68.3	67.6	61.8	56.4	48.8	40.5	(24)	
	10%	DB	38.6	42.7	53.8	64.5	71.1	77.9	80.8	80.4	71.7	60.8	50.3	40.4	(25)	
		MCWB	36.4	39.1	44.2	51.5	59.0	65.0	66.7	66.4	59.6	54.5	47.3	38.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.4	46.4	52.5	60.3	66.4	73.1	73.5	72.5	67.1	62.1	54.7	45.0	(27)	
		MCDB	47.3	51.9	62.7	73.0	77.6	83.7	84.9	85.0	79.5	69.3	58.8	46.8	(28)	
	2%	WB	42.0	43.9	49.9	57.3	64.1	70.2	71.1	70.4	65.0	59.3	51.7	42.9	(29)	
		MCDB	43.4	47.4	59.7	68.2	74.7	81.3	83.2	82.7	76.7	66.0	54.9	44.4	(30)	
	5%	WB	39.5	41.9	47.6	54.9	62.2	68.0	69.4	68.9	63.0	57.4	49.4	40.9	(31)	
		MCDB	41.3	45.1	55.8	64.2	72.6	78.1	81.1	80.8	72.2	63.0	52.0	42.3	(32)	
	10%	WB	36.7	39.6	45.2	52.9	60.3	66.2	67.7	67.2	61.2	55.4	47.4	38.9	(33)	
		MCDB	38.5	42.3	52.1	62.3	69.3	75.5	78.6	78.3	69.1	60.0	49.9	40.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	12.2	16.7	19.2	19.0	19.1	20.1	20.4	18.4	15.6	11.5	8.8	(35)	
		MCDBR	11.9	16.6	23.3	24.5	23.8	23.0	24.1	24.5	23.0	19.8	15.9	10.6	(36)	
	5% WB	MCWBR	9.0	11.2	12.9	12.0	11.9	11.0	10.4	10.3	10.8	11.1	10.1	8.5	(37)	
		MCWBR	10.6	14.5	21.4	21.5	21.5	21.2	21.9	22.3	20.3	18.3	13.3	9.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.312	0.337	0.378	0.434	0.424	0.426	0.442	0.439	0.405	0.374	0.347	0.312	(40)	
		taud	2.335	2.300	2.254	2.130	2.210	2.242	2.203	2.217	2.276	2.335	2.359	2.373	(41)	
	Ebn at Noon		236	256	263	258	266	266	259	254	251	239	219	220	(42)	
		Edh at Noon	23	29	36	45	43	43	43	41	35	28	22	19	(43)	
(44) All-Sky Solar Radiation	RadAvg		298	535	948	1371	1656	1780	1721	1589	1124	682	355	223	(44)	
	RadStd		38	88	132	137	183	125	167	129	143	92	45	27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (47 neighbors)	N/A	N/A	N/A	+1.71	+0.94	+0.83	-225	-328	+166	+76

Nomenclature: See separate page