

MISKOLC, Hungary

WMO: 127720

Lat: 48.0970N

Lon: 20.7715E

Elev: 236

StdP: 98.52

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.1	-9.1	-16.4	0.9	-9.0	-14.0	1.1	-6.9	10.5	6.2	8.7	5.0	1.9	330	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	32.2	21.1	30.3	20.4	28.6	19.5	22.1	29.7	21.3	28.5	20.4	27.1	2.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.7	14.8	25.8	18.7	13.9	24.8	17.9	13.2	23.9	65.9	29.5	62.7	28.6	59.6	27.2	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.5	6.2	5.2	DB	-13.6	34.5	2.8	1.9	-15.6	35.9	-17.2	37.0	-18.7	38.0	-20.8	39.4	
			WB	-14.2	23.8	2.7	1.2	-16.1	24.6	-17.7	25.3	-19.2	26.0	-21.1	26.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	-1.2	0.7	5.8	11.7	16.3	19.8	21.6	21.3	16.3	10.8	5.2	-0.3
	DBStd	9.03	4.41	4.37	4.36	3.97	3.62	3.42	3.19	3.11	3.68	3.90	4.15	4.25
	HDD10.0	1285	347	259	141	27	1	0	0	0	1	38	150	321
	HDD18.3	3096	605	492	389	199	83	23	8	8	82	234	393	579
	CDD10.0	1552	0	0	10	79	197	294	360	352	191	63	7	0
	CDD18.3	323	0	0	0	2	21	67	109	102	22	1	0	0
	CDH23.3	2729	0	0	0	19	178	565	942	858	164	3	0	0
	CDH26.7	876	0	0	0	1	29	169	336	303	37	0	0	0
Wind	WSAvg	2.3	2.2	2.3	2.8	2.6	2.5	2.3	2.3	2.1	2.1	2.1	2.2	2.0
Precipitation	PrecAvg	557	23	25	31	44	61	80	64	65	46	37	47	34
	PrecMax	860	73	92	88	88	149	178	144	168	187	197	118	98
	PrecMin	364	2	1	0	9	16	13	13	4	1	1	5	2
	PrecStd	129	20	22	20	22	29	40	31	42	36	38	32	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	14.0	19.7	25.6	29.4	32.8	34.9	34.7	30.1	23.4	16.9	10.6
		MCWB	6.9	8.3	11.1	15.7	18.3	21.8	21.2	21.0	19.4	16.3	12.5	7.4
	2%	DB	8.1	10.7	16.9	22.8	27.2	30.6	32.1	32.1	27.3	21.1	14.2	8.2
		MCWB	5.5	6.5	9.4	13.8	17.8	20.8	21.1	21.0	18.2	15.0	10.8	6.3
	5%	DB	6.2	8.5	14.7	20.6	25.4	28.6	30.2	30.0	25.0	18.9	12.5	6.6
		MCWB	4.3	5.4	8.6	12.6	17.0	19.6	20.4	20.4	17.2	14.1	10.0	5.0
	10%	DB	4.6	6.8	12.7	18.8	23.3	26.7	28.3	27.9	22.9	16.7	11.0	5.1
		MCWB	3.1	4.5	7.4	11.7	15.9	18.9	19.5	19.5	16.1	13.0	9.0	3.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	8.9	11.9	16.2	19.7	23.2	23.1	23.6	20.1	17.2	13.0	8.0
		MCDB	10.1	13.2	17.5	24.0	26.9	30.7	30.6	30.7	28.2	21.9	15.5	9.5
	2%	WB	6.0	7.1	10.3	14.8	18.5	21.7	22.1	22.0	18.8	15.8	11.7	6.7
		MCDB	7.5	9.7	15.4	21.5	25.6	28.8	29.9	29.2	25.9	20.1	13.6	8.0
	5%	WB	4.6	5.9	9.2	13.5	17.5	20.6	21.2	21.0	17.8	14.7	10.4	5.3
		MCDB	5.9	8.0	13.8	19.2	24.1	26.9	28.5	28.4	23.7	18.2	12.1	6.2
	10%	WB	3.3	4.7	8.0	12.4	16.5	19.5	20.3	20.1	16.8	13.4	9.1	4.1
		MCDB	4.5	6.6	11.9	17.6	22.4	25.4	26.8	27.0	21.8	16.2	10.8	5.0
Mean Daily Temperature Range	5% DB	MDBR	5.0	6.4	8.6	9.9	10.2	10.3	10.7	10.9	9.6	8.4	5.8	4.4
		MCDBR	6.6	9.0	12.2	12.8	13.1	13.0	13.4	13.8	12.8	11.2	7.9	6.1
		MCWBR	4.8	6.1	6.9	6.5	6.1	5.9	5.5	5.6	5.8	6.3	5.2	4.8
	5% WB	MCDBR	5.8	8.2	10.9	11.6	11.8	11.8	12.0	12.6	11.5	10.4	7.2	5.5
		MCWBR	4.5	5.9	6.7	6.1	5.9	5.9	5.5	5.7	5.5	6.1	5.0	4.7
Clear-Sky Solar Irradiance	taub		0.318	0.341	0.378	0.431	0.419	0.421	0.438	0.434	0.403	0.374	0.349	0.318
	taud		2.349	2.317	2.271	2.147	2.234	2.259	2.219	2.233	2.289	2.348	2.367	2.374
	Ebn at Noon		743	807	831	818	845	843	822	806	795	757	696	693
	Edh at Noon		71	92	112	140	134	131	135	128	110	88	71	62
All-Sky Solar Radiation		RadAvg	0.96	1.75	3.06	4.43	5.37	5.78	5.61	5.15	3.62	2.25	1.19	0.73
		RadStd	0.12	0.29	0.42	0.43	0.56	0.39	0.52	0.43	0.44	0.28	0.13	0.10

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
Station Only	+0.70	N/A	N/A	+1.28	N/A	N/A	-122	-180	+104	+53
Regional (49 neighbors)	+0.60	N/A	N/A	+0.97	+0.57	+0.52	-124	-184	+98	+44

Nomenclature: See separate page