

ZAHONY, Hungary

WMO: 127860

Lat: 48.400N

Lon: 22.167E

Elev: 341

StdP: 14.52

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.5	14.0	1.8	6.1	11.6	6.4	7.7	16.6	15.6	21.3	13.9	24.1	4.6	320	0.455

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.4	91.3	70.7	88.2	69.6	85.3	68.2	72.9	86.4	71.3	84.8	69.7	82.4	5.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.4	105.8	79.5	66.7	99.4	77.1	65.2	94.5	75.5	36.6	86.6	35.2	84.8	33.9	82.3	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.5	11.8	10.2	4.0	95.6	5.8	2.7	-0.2	97.5	-3.6	99.1	-6.8	100.6	-11.0	102.5
			3.1	75.6	5.5	1.4	-0.8	76.6	-4.1	77.4	-7.2	78.2	-11.2	79.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	29.3	33.1	42.2	53.9	61.9	68.5	71.6	71.1	61.7	51.3	42.0	32.7
	DBStd	16.43	8.35	8.26	8.09	6.46	6.57	5.75	5.73	5.28	6.39	6.90	7.38	7.55
	HDD50	2274	641	473	258	34	3	0	0	0	1	71	257	536
	HDD65	5487	1106	892	707	334	139	31	10	11	139	426	691	1001
	CDD50	2897	0	0	16	153	371	556	669	654	351	111	16	0
	CDD65	637	0	0	0	3	42	137	214	200	40	1	0	0
	CDH74	6295	0	0	0	63	504	1277	2087	1947	408	9	0	0
	CDH80	2248	0	0	0	12	118	406	847	763	102	0	0	0
Wind	WSAvg	4.7	4.6	5.0	5.6	5.4	5.1	4.8	4.5	4.2	4.2	4.1	4.2	4.5
Precipitation	PrecAvg	24.5	1.4	1.6	1.3	1.7	2.5	2.6	3.0	2.2	2.4	1.9	1.8	2.0
	PrecMax	40.0	2.4	4.5	4.3	4.1	8.0	4.4	7.0	6.4	6.5	4.4	3.5	3.6
	PrecMin	19.4	0.6	0.3	0.3	0.3	1.1	0.4	0.5	0.2	0.2	0.0	0.1	0.1
	PrecStd	4.8	0.6	0.9	1.0	0.9	1.5	1.2	1.7	1.5	1.3	1.3	0.9	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.9	55.7	68.2	81.7	87.5	90.9	95.8	95.7	88.3	75.2	64.6	52.2
		MCWB	45.5	47.6	53.3	62.4	66.3	71.8	71.7	69.7	67.7	60.4	55.5	48.2
	2%	DB	45.4	50.4	63.6	74.8	83.3	87.7	91.6	91.3	82.7	71.6	59.8	48.2
		MCWB	43.0	44.6	50.5	57.3	64.6	69.9	71.0	70.5	65.3	59.5	53.1	44.9
	5%	DB	42.6	47.0	59.4	71.5	79.9	84.7	88.3	87.8	78.9	67.0	55.9	45.2
		MCWB	40.5	42.9	48.3	55.6	63.3	67.7	69.8	69.6	63.6	57.7	50.9	42.9
	10%	DB	39.9	44.0	55.1	67.5	75.8	81.7	85.0	84.3	74.7	62.4	52.6	42.5
		MCWB	38.1	40.7	46.3	53.8	61.5	66.6	68.7	68.1	61.8	55.4	49.1	40.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.9	48.5	54.8	62.3	68.7	74.2	74.9	75.0	69.2	63.2	57.1	48.6
		MCDB	48.5	54.1	65.5	79.1	82.3	87.0	88.8	88.0	84.7	71.6	61.4	51.7
	2%	WB	43.5	45.6	51.7	59.3	66.3	71.7	72.8	72.7	66.9	60.4	54.2	45.5
		MCDB	44.8	49.0	60.5	71.7	79.3	84.8	86.7	85.9	79.9	69.3	58.5	47.6
	5%	WB	40.7	43.3	49.4	56.9	64.6	69.8	71.4	70.8	64.9	58.4	51.8	43.1
		MCDB	42.1	46.4	57.7	67.9	77.1	81.3	85.7	83.9	75.8	65.1	55.5	45.1
	10%	WB	38.3	41.1	47.1	55.0	62.7	68.0	69.8	69.2	62.9	56.2	49.2	40.5
		MCDB	39.8	43.8	54.0	65.7	73.9	78.9	82.5	81.8	72.8	61.6	52.1	42.3
Mean Daily Temperature Range	5% DB	MDBR	9.6	12.5	17.4	21.0	21.1	20.6	21.4	22.4	20.5	18.2	13.5	8.5
		MCDBR	10.9	16.3	25.0	27.5	27.1	25.1	26.3	27.7	26.5	24.9	19.5	12.1
		MCWBR	8.5	11.3	13.9	12.8	11.6	10.5	9.4	10.2	11.3	14.0	12.9	9.5
	5% WB	MCDBR	9.5	14.9	22.6	24.3	24.4	22.7	24.5	24.9	24.2	21.9	16.2	11.5
		MCWBR	7.9	10.8	13.3	12.0	11.4	10.0	9.5	10.3	11.0	12.8	11.3	9.5
Clear-Sky Solar Irradiance	taub	0.327	0.351	0.392	0.444	0.431	0.432	0.452	0.449	0.411	0.383	0.360	0.327	
	taud	2.273	2.241	2.209	2.105	2.202	2.231	2.188	2.195	2.263	2.312	2.317	2.315	
	Ebn at Noon	227	249	258	255	264	264	256	251	249	235	213	211	
	Edh at Noon	24	31	38	46	44	43	44	42	36	29	23	21	
All-Sky Solar Radiation	RadAvg	295	546	924	1363	1658	1791	1739	1610	1123	691	364	219	
	RadStd	50	87	136	144	184	124	167	145	154	103	53	31	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (42 neighbors)		+1.12	N/A	N/A	+1.75	+0.94	+0.85	-227	-340	+173	+68

Nomenclature: See separate page