

ZAHONY, Hungary

WMO: 127860

Lat: 48.400N

Lon: 22.167E

Elev: 104

StdP: 100.08

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.1	-10.0	-16.8	0.9	-11.3	-14.2	1.1	-8.5	7.0	-6.0	6.2	-4.4	2.1	320	0.455

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	32.9	21.5	31.2	20.9	29.6	20.1	22.7	30.2	21.8	29.4	21.0	28.0	2.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	15.1	26.4	19.3	14.2	25.1	18.5	13.5	24.2	67.3	30.3	64.0	29.3	61.0	28.0	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.1	5.3	4.5	DB	-15.6	35.3	3.2	1.5	-17.9	36.4	-19.8	37.3	-21.6	38.1	-23.9	39.2	(4)
			WB	-16.0	24.2	3.1	0.8	-18.2	24.8	-20.0	25.2	-21.8	25.7	-24.0	26.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	-1.5	0.6	5.7	12.2	16.6	20.3	22.0	21.7	16.5	10.7	5.5	0.4	(6)
(7)		DBStd	9.13	4.64	4.59	4.49	3.59	3.65	3.19	3.18	2.93	3.55	3.83	4.10	4.20	(7)
(8)		HDD10.0	1263	356	263	143	19	2	0	0	1	39	143	298		(8)
(9)		HDD18.3	3048	614	496	393	186	77	17	6	77	237	384	556		(9)
(10)		CDD10.0	1609	0	0	9	85	206	309	372	363	195	62	9	0	(10)
(11)		CDD18.3	354	0	0	0	2	23	76	119	111	22	1	0	0	(11)
(12)		CDH23.3	3497	0	0	0	35	280	709	1159	1082	227	5	0	0	(12)
(13)		CDH26.7	1249	0	0	0	7	66	226	471	424	57	0	0	0	(13)
(14)	Wind	WSAvg	2.1	2.1	2.2	2.5	2.4	2.3	2.1	2.0	1.9	1.9	1.8	1.9	2.0	(14)
(15)	Precipitation	PrecAvg	623	36	40	34	44	64	67	76	55	60	49	46	51	(15)
(16)		PrecMax	1015	60	115	109	105	202	112	179	163	166	113	89	91	(16)
(17)		PrecMin	494	14	7	8	7	28	11	12	5	6	1	2	2	(17)
(18)		PrecStd	122	15	23	25	23	38	30	44	38	32	32	23	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	13.2	20.1	27.6	30.8	32.7	35.5	35.4	31.3	24.0	18.1	11.2	(19)
MCWB			7.5	8.7	11.8	16.9	19.1	22.1	22.0	20.9	19.8	15.8	13.0	9.0	(20)	
2%		DB	7.4	10.2	17.6	23.8	28.5	30.9	33.1	33.0	28.2	22.0	15.4	9.0	(21)	
		MCWB	6.1	7.0	10.3	14.0	18.1	21.1	21.7	21.4	18.5	15.3	11.7	7.2	(22)	
5%		DB	5.9	8.3	15.2	21.9	26.6	29.3	31.3	31.0	26.0	19.4	13.3	7.4	(23)	
		MCWB	4.7	6.0	9.1	13.1	17.4	19.9	21.0	20.9	17.6	14.3	10.5	6.1	(24)	
10%		DB	4.4	6.7	12.8	19.7	24.4	27.6	29.4	29.1	23.7	16.9	11.5	5.8	(25)	
		MCWB	3.4	4.8	7.9	12.1	16.4	19.2	20.4	20.1	16.5	13.0	9.5	4.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	9.2	12.7	16.9	20.4	23.5	23.8	23.9	20.7	17.3	14.0	9.2	(27)
MCDWB			9.1	12.3	18.6	26.2	27.9	30.6	31.6	31.1	29.3	22.0	16.3	11.0	(28)	
2%		WB	6.4	7.5	10.9	15.1	19.1	22.1	22.7	22.6	19.4	15.8	12.3	7.5	(29)	
		MCDWB	7.1	9.4	15.8	22.1	26.3	29.3	30.4	29.9	26.6	20.7	14.7	8.7	(30)	
5%		WB	4.8	6.3	9.7	13.8	18.1	21.0	21.9	21.6	18.3	14.7	11.0	6.2	(31)	
		MCDWB	5.6	8.0	14.3	20.0	25.1	27.4	29.8	28.8	24.3	18.4	13.0	7.3	(32)	
10%		WB	3.5	5.1	8.4	12.8	17.1	20.0	21.0	20.7	17.2	13.5	9.5	4.7	(33)	
		MCDWB	4.3	6.5	12.2	18.7	23.3	26.1	28.1	27.7	22.7	16.5	11.2	5.7	(34)	
(35)	Mean Daily Temperature Range	MDBR	5.4	6.9	9.7	11.6	11.7	11.4	11.9	12.4	11.4	10.1	7.5	4.7	(35)	
5% DB		MCDBR	6.1	9.1	13.9	15.3	15.0	13.9	14.6	15.4	14.7	13.9	10.8	6.7	(36)	
		MCWBR	4.7	6.3	7.7	7.1	6.5	5.8	5.2	5.7	6.3	7.8	7.2	5.3	(37)	
		MCDBR	5.3	8.3	12.6	13.5	13.6	12.6	13.6	13.8	13.4	12.2	9.0	6.4	(38)	
5% WB		MCWBR	4.4	6.0	7.4	6.6	6.3	5.6	5.3	5.7	6.1	7.1	6.3	5.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.327	0.351	0.392	0.444	0.431	0.432	0.452	0.449	0.411	0.383	0.360	0.327	(40)	
(41)		taud	2.273	2.241	2.209	2.105	2.202	2.231	2.188	2.195	2.263	2.312	2.317	2.315	(41)	
(42)		Ebn at Noon	716	785	812	804	833	833	808	791	784	741	672	666	(42)	
(43)		Edh at Noon	76	98	119	146	138	135	139	132	112	91	74	65	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.93	1.72	2.91	4.30	5.23	5.65	5.48	5.08	3.54	2.18	1.15	0.69	(44)	
(45)		RadStd	0.16	0.27	0.43	0.46	0.58	0.39	0.53	0.46	0.48	0.32	0.17	0.10	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47)	Regional (42 neighbors)	+0.62	N/A	N/A	+0.97	+0.52	+0.47	-126	-189	+96	+38	(47)

Nomenclature: See separate page