

MOSONMAGYAROVAR, Hungary

WMO: 128150

Lat: 47.883N

Lon: 17.283E

Elev: 400

StdP: 14.48

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.2	18.3	6.9	8.0	17.4	11.6	10.1	21.2	24.8	38.5	22.6	34.4	6.3	320	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.1	91.0	70.5	87.9	69.3	84.7	67.8	72.1	86.5	70.6	84.6	69.2	82.2	7.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.4	102.2	78.3	65.8	96.5	76.6	64.4	91.9	75.2	36.1	86.5	34.7	85.0	33.5	82.5	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.6	18.8	16.5	8.5	96.1	5.5	3.4	4.5	98.5	1.3	100.5	-1.7	102.4	-5.7	104.9
			7.3	75.0	5.3	1.6	3.5	76.2	0.4	77.2	-2.6	78.1	-6.4	79.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.0	31.7	36.0	43.0	52.8	60.8	67.5	70.9	69.9	61.5	52.3	43.0	34.0	(6)
	DBStd	15.31	7.96	7.27	7.52	7.03	6.48	6.35	5.89	5.84	5.91	7.03	7.37	7.46	(7)
	HDD50	2038	567	394	237	51	3	0	0	0	1	58	230	497	(8)
	HDD65	5294	1032	813	682	369	163	46	16	19	136	396	660	962	(9)
	CDD50	2777	0	2	19	134	337	526	647	616	346	129	20	1	(10)
	CDD65	557	0	0	0	2	32	122	198	170	31	2	0	0	(11)
	CDH74	5701	0	0	0	55	372	1234	2013	1707	304	16	0	0	(12)
	CDH80	1991	0	0	0	6	70	392	793	667	63	0	0	0	(13)
	WSAvg	7.1	7.2	8.1	8.4	8.0	7.4	7.1	7.1	6.1	6.5	6.1	6.9	7.0	(14)
	PrecAvg	22.4	1.5	1.3	1.3	1.7	2.0	2.2	2.9	2.2	1.5	1.8	2.3	1.7	(15)
(16) Precipitation	PrecMax	31.1	3.2	3.3	2.6	3.9	4.2	5.6	5.7	4.2	3.3	5.4	6.0	3.0	(16)
	PrecMin	17.9	0.0	0.1	0.4	0.3	0.1	0.2	0.4	0.7	0.4	0.0	1.0	0.3	(17)
	PrecStd	3.3	0.8	1.0	0.7	1.0	1.2	1.4	1.7	1.1	0.8	1.5	1.3	0.7	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	59.9	68.7	79.6	85.7	91.8	95.2	95.9	85.8	76.2	65.9	56.5	(19)
		MCWB	47.7	48.6	52.9	61.4	66.3	70.9	71.3	70.4	67.4	63.1	56.5	50.2	(20)
	2%	DB	49.7	55.0	63.7	74.7	81.7	88.2	91.1	91.1	81.2	71.5	60.9	49.4	(21)
		MCWB	44.4	46.8	51.1	58.1	64.7	69.9	70.5	70.4	65.6	60.7	54.1	44.9	(22)
	5%	DB	45.8	51.0	59.5	70.7	78.3	84.7	88.0	87.1	77.4	67.6	56.7	45.8	(23)
		MCWB	41.7	44.7	49.3	56.3	63.1	68.0	69.4	68.9	63.6	58.5	51.4	42.3	(24)
	10%	DB	42.4	47.2	55.6	66.7	74.6	81.2	84.5	83.2	73.6	63.6	53.1	43.3	(25)
		MCWB	39.2	42.3	47.3	54.2	60.9	66.4	67.9	67.3	61.8	56.7	49.0	40.5	(26)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	50.1	54.8	62.1	68.7	73.9	74.1	74.1	69.0	64.2	57.3	50.5	(27)
		MCDB	54.0	58.1	65.3	77.4	81.5	87.4	89.9	88.0	83.1	73.8	64.2	56.2	(28)
	2%	WB	45.0	47.4	52.3	59.5	66.1	71.2	72.0	71.8	66.8	61.7	54.3	45.5	(29)
		MCDB	49.1	54.0	61.8	71.7	79.6	84.6	87.0	86.0	78.3	70.0	60.1	48.7	(30)
	5%	WB	42.0	44.9	50.1	57.3	64.1	69.4	70.6	70.2	64.9	59.4	52.0	42.9	(31)
		MCDB	45.3	50.3	58.1	67.9	76.1	82.1	84.8	84.2	74.6	66.2	56.5	45.3	(32)
	10%	WB	39.4	42.5	47.8	55.3	62.0	67.6	69.1	68.5	63.0	57.3	49.4	40.8	(33)
		MCDB	42.1	47.0	54.7	65.8	72.4	79.1	82.2	80.8	71.9	62.6	52.7	43.0	(34)
(36) Mean Daily Temperature Range	5% DB	MDBR	9.9	12.5	16.4	20.0	20.0	20.5	21.1	21.2	18.7	16.6	11.3	9.0	(35)
		MCDBR	13.9	19.1	23.9	26.7	25.8	25.4	26.8	27.6	25.3	21.9	16.7	13.0	(36)
		MCWBR	10.0	12.7	14.0	13.3	11.9	10.4	10.0	10.1	11.7	12.4	10.8	9.7	(37)
	5% WB	MCDBR	13.5	17.7	21.8	24.2	23.8	23.1	24.4	25.3	22.6	20.7	16.3	12.4	(38)
		MCWBR	10.2	12.2	13.4	12.5	11.5	10.2	9.9	10.4	10.8	12.1	10.7	9.5	(39)
(40) Clear-Sky Solar Irradiance	taub		0.325	0.349	0.386	0.430	0.426	0.428	0.436	0.437	0.412	0.382	0.356	0.324	(40)
	taud		2.368	2.337	2.255	2.151	2.214	2.244	2.221	2.235	2.272	2.332	2.356	2.384	(41)
	Ebn at Noon		234	254	261	260	266	266	261	255	250	238	219	219	(42)
	Edh at Noon		23	29	36	44	43	43	43	41	36	29	23	20	(43)
(44) All-Sky Solar Radiation	RadAvg		324	582	961	1432	1695	1846	1791	1594	1140	703	366	251	(44)
	RadStd		35	79	122	140	175	132	154	154	135	75	35	29	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (78 neighbors)	+1.06	N/A	N/A	+1.57	+0.90	+0.79	-220	-306	+176	+92	

Nomenclature: See separate page