

TAT, Hungary

WMO: 128470

Lat: 47.750N

Lon: 18.600E

Elev: 358

StdP: 14.51

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.6	16.6	1.9	6.1	14.5	8.5	8.6	19.3	20.6	35.3	18.7	35.1	3.2	140	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.9	91.3	70.8	88.1	69.5	84.8	68.4	72.8	85.7	71.3	84.0	69.9	82.0	6.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.7	106.9	78.4	67.1	101.1	76.6	65.7	96.1	75.2	36.6	85.9	35.2	84.2	34.0	82.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.2	15.8	13.7	6.2	95.9	6.9	3.3	1.2	98.3	-2.8	100.2	-6.7	102.0	-11.8	104.4		
			5.6	76.0	6.5	1.8	0.9	77.3	-2.9	78.3	-6.6	79.3	-11.4	80.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	31.7	34.7	43.2	53.3	61.2	67.8	71.0	61.4	52.7	43.3	33.9		
		DBStd	15.50	8.22	8.20	7.68	6.64	6.28	5.96	5.79	5.80	6.11	6.77	7.83		
		HDD50	2046	568	429	232	40	0	0	0	1	50	223	499		
		HDD65	5270	1033	849	677	355	150	38	13	140	383	652	963		
		CDD50	2816	0	0	20	138	350	535	649	623	344	135	21		
		CDD65	565	0	0	0	3	31	123	198	175	33	2	0		
		CDH74	5785	0	0	0	59	378	1204	2016	1780	332	16	0		
		CDH80	2043	0	0	0	10	72	370	801	711	79	0	0		
		WSAvg	5.7	6.3	6.5	6.7	6.2	5.5	4.9	5.0	4.5	4.7	5.2	6.6		
		PrecAvg	22.9	1.5	1.3	1.3	1.5	2.4	2.5	2.6	2.4	2.1	1.8	1.9		
(15)	Precipitation	PrecMax	37.9	2.9	4.2	4.0	2.9	7.2	6.2	5.8	6.6	5.1	4.3	3.6		
(16)		PrecMin	13.9	0.1	0.0	0.1	0.1	0.7	0.3	0.4	0.1	0.4	0.0	0.1		
(17)		PrecStd	5.2	0.7	0.9	0.9	0.8	1.3	1.4	1.4	1.6	1.4	1.1	0.9		
(18)		PrecStd	5.2	0.7	0.9	0.9	0.8	1.3	1.4	1.4	1.6	1.4	1.1	0.9		
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	54.2	58.4	68.8	81.1	85.6	91.1	95.6	95.4	87.2	76.1	64.6	53.0		
(20)		0.4% MCWB	47.6	47.7	53.6	62.0	66.6	71.7	70.7	70.6	67.4	62.4	56.7	48.7		
(21)		2% DB	48.6	52.4	64.7	74.6	81.7	87.8	91.7	91.4	81.8	71.7	60.0	49.5		
(22)		2% MCWB	44.3	45.7	51.9	58.1	65.5	69.9	70.9	70.5	65.9	60.1	54.2	45.9		
(23)		5% DB	45.3	48.9	60.2	71.0	78.3	84.4	88.0	87.7	77.6	68.0	56.4	46.7		
(24)		5% MCWB	41.7	43.8	49.6	56.1	63.5	68.8	69.8	69.1	63.8	58.7	51.4	43.7		
(25)		10% DB	42.5	45.7	55.8	67.0	74.6	81.3	84.5	83.7	73.9	64.2	53.3	44.0		
(26)		10% MCWB	39.2	42.2	47.3	54.2	61.6	67.5	68.6	67.9	62.0	56.6	49.2	41.3		
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	48.2	49.0	55.3	62.7	69.1	74.2	75.1	74.8	69.2	63.9	57.4	49.4		
(28)		0.4% MCDB	52.7	56.4	65.9	77.2	81.8	86.9	88.6	87.7	83.7	73.9	63.5	52.4		
(29)		2% WB	44.9	46.3	52.5	59.4	66.7	71.9	72.8	72.5	67.2	61.6	54.6	46.5		
(30)		2% MCDB	48.2	51.0	61.4	71.4	78.6	83.8	86.0	85.7	79.0	69.8	59.3	49.0		
(31)		5% WB	42.3	44.5	50.2	57.3	64.8	70.3	71.2	70.8	65.2	59.5	52.2	43.9		
(32)		5% MCDB	45.0	48.2	58.8	67.8	75.5	81.5	83.9	84.0	74.9	66.0	55.8	46.3		
(33)		10% WB	39.7	42.5	48.0	55.4	62.8	68.6	69.8	69.3	63.2	57.5	49.7	41.6		
(34)		10% MCDB	42.0	45.7	54.4	65.6	72.3	78.9	81.8	81.4	71.5	62.8	52.9	43.9		
(35)	Mean Daily Temperature Range	MDBR	10.0	12.3	17.3	20.9	20.3	20.6	21.9	22.2	19.9	17.2	11.6	9.0		
(36)		5% DB MCDBR	13.2	17.2	25.9	27.4	26.5	25.2	27.3	28.1	26.0	22.6	16.2	11.6		
(37)		5% DB MCWBR	9.8	12.0	15.1	14.0	12.7	11.1	10.8	11.1	12.5	12.5	10.9	9.1		
(38)		5% WB MCDBR	13.0	15.5	22.7	24.4	24.2	22.8	24.3	25.6	22.7	20.5	15.0	11.0		
(39)		5% WB MCWBR	9.9	11.1	13.8	12.8	12.2	10.6	10.6	11.1	11.4	11.9	10.5	8.9		
(40)	Clear-Sky Solar Irradiance	taub	0.330	0.353	0.391	0.438	0.430	0.431	0.443	0.442	0.416	0.385	0.361	0.329		
(41)		taud	2.353	2.313	2.239	2.128	2.202	2.237	2.204	2.220	2.258	2.320	2.345	2.370		
(42)		Ebn at Noon	232	252	259	258	265	265	259	254	248	236	217	217		
(43)		Edh at Noon	23	30	37	45	44	43	43	41	36	29	23	20		
(44)	All-Sky Solar Radiation	RadAvg	322	577	969	1428	1721	1869	1821	1635	1154	729	380	246		
(45)		RadStd	41	87	149	140	186	147	141	159	142	81	40	30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (63 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+1.04	N/A	N/A	+1.57	+0.99	+0.92	-220	-313	+166	+79

Nomenclature: See separate page