

KEKESTETO, Hungary

WMO: 128510

Lat: 47.867N

Lon: 20.017E

Elev: 3330

StdP: 13.01

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.0	11.7	-5.2	4.7	17.5	0.7	6.4	17.1	26.3	28.9	24.0	28.1	9.9	40	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	77.2	63.5	74.3	62.4	71.7	61.4	65.5	73.7	63.9	71.9	62.4	70.1	5.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.5	95.9	70.2	60.8	90.2	68.3	59.2	85.1	66.8	32.3	73.9	31.0	72.1	29.8	70.2	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.9	19.6	17.7	DB	5.5	81.2	4.7	3.1	2.2	83.5	-0.5	85.3	-3.2	87.0	-6.5	89.3	(4)
(5)			WB	3.8	68.1	4.6	1.6	0.5	69.2	-2.2	70.2	-4.8	71.0	-8.2	72.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.9	25.5	27.3	33.2	44.0	52.3	58.5	61.8	61.7	52.8	44.7	35.8	27.8	(6)	
	DBStd	15.10	7.63	8.05	8.16	8.19	7.32	6.82	6.34	6.53	7.07	8.24	8.12	7.66	(7)	
	HDD50	3574	761	635	521	210	61	10	1	2	51	207	427	688	(8)	
	HDD65	7814	1226	1055	985	629	395	214	139	143	370	630	875	1153	(9)	
	CDD50	1341	0	0	1	31	133	265	367	366	135	41	2	0	(10)	
	CDD65	105	0	0	0	0	2	19	39	42	3	0	0	0	(11)	
	CDH74	276	0	0	0	0	2	43	115	114	2	0	0	0	(12)	
	CDH80	20	0	0	0	0	0	2	10	8	0	0	0	0	(13)	
(14) Wind	WSAvg	8.8	10.4	9.9	9.6	8.7	7.8	7.1	7.3	6.8	7.6	8.9	10.7	10.8	(14)	
(15) Precipitation	PrecAvg	23.9	1.2	1.4	1.3	1.7	2.6	2.6	3.1	2.5	2.1	2.0	1.8	1.5	(15)	
	PrecMax	45.7	3.0	4.4	4.7	4.4	9.1	6.5	7.7	8.6	7.3	5.0	4.3	3.8	(16)	
	PrecMin	13.2	0.1	0.0	0.0	0.0	0.6	0.7	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	6.5	0.8	1.1	1.1	1.1	1.7	1.4	2.0	1.9	1.6	1.4	1.1	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.6	46.9	55.0	66.5	72.5	78.3	81.0	81.0	72.4	63.3	54.1	45.4	(19)	
		MCWB	39.8	39.5	45.2	53.3	58.7	64.5	64.4	63.8	59.9	54.9	48.6	40.1	(20)	
	2%	DB	40.9	42.8	50.7	61.8	68.7	74.4	77.1	77.2	68.3	59.9	51.1	42.4	(21)	
		MCWB	38.5	37.8	42.9	50.5	57.7	63.2	63.2	63.4	58.1	53.3	46.5	39.0	(22)	
	5%	DB	38.3	40.1	47.1	58.3	65.8	71.3	74.0	74.1	65.2	57.5	48.7	40.1	(23)	
		MCWB	36.6	36.8	40.8	48.5	56.3	61.6	62.8	62.1	57.2	52.2	45.0	37.6	(24)	
	10%	DB	35.9	37.7	44.0	55.2	62.9	68.5	71.1	71.4	62.4	55.2	46.4	37.9	(25)	
		MCWB	34.5	35.7	38.9	46.5	54.6	60.1	61.5	61.2	55.7	50.8	43.6	36.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.5	41.3	46.8	54.7	61.3	67.1	67.3	67.5	61.2	56.8	50.8	42.6	(27)	
		MCDB	42.6	44.4	52.3	63.9	69.2	75.2	75.7	74.9	69.1	60.5	52.9	43.6	(28)	
	2%	WB	38.9	39.2	43.8	51.7	58.9	64.6	65.4	65.2	59.5	54.8	47.9	40.3	(29)	
		MCDB	40.3	41.6	48.6	59.7	66.4	72.4	73.7	73.2	66.1	58.3	49.9	41.4	(30)	
	5%	WB	37.0	37.5	41.8	49.4	57.1	62.6	63.9	63.5	58.0	53.0	46.1	38.3	(31)	
		MCDB	38.0	39.4	46.0	56.5	64.2	69.6	71.8	71.9	64.0	56.5	48.0	39.6	(32)	
	10%	WB	34.5	35.9	39.7	47.5	55.4	60.8	62.4	61.9	56.4	51.2	44.1	36.4	(33)	
		MCDB	35.6	37.5	43.5	54.0	62.0	67.4	69.8	70.1	61.8	54.4	46.0	37.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.4	7.4	9.4	11.5	11.7	11.3	11.4	10.6	9.1	8.2	6.6	6.5	(35)	
		MCDBR	7.1	9.0	12.7	13.6	13.6	13.1	13.5	12.3	11.0	9.4	8.0	7.9	(36)	
	5% WB	MCWBR	6.4	6.7	8.4	8.2	9.0	8.7	8.0	7.7	7.4	6.5	6.3	6.7	(37)	
		MCWBR	7.2	8.0	11.2	12.6	12.7	12.2	12.5	11.7	10.0	9.1	7.5	6.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.281	0.299	0.330	0.370	0.362	0.364	0.375	0.374	0.351	0.328	0.309	0.282	(40)	
		taud	2.435	2.419	2.396	2.301	2.352	2.362	2.328	2.343	2.391	2.450	2.470	2.461	(41)	
	Ebn at Noon		256	275	282	279	285	285	279	275	271	260	242	241	(42)	
		Edh at Noon	21	26	31	38	38	38	38	36	31	25	20	18	(43)	
(44) All-Sky Solar Radiation	RadAvg		313	570	974	1422	1721	1860	1810	1641	1156	727	382	240	(44)	
	RadStd		40	90	141	139	180	134	154	150	140	83	41	31	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	+1.30	+1.35	N/A	N/A	N/A	N/A	(46)
(47)	Regional (51 neighbors)	+1.10	N/A	N/A	+1.69	+1.03	+0.97	-225	-335	+175	+81	(47)

Nomenclature: See separate page