

SZOLNOK, Hungary

WMO: 128600

Lat: 47.123N

Lon: 20.236E

Elev: 322

StdP: 14.53

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.7	15.2	5.7	7.5	13.8	9.8	9.2	17.7	23.5	36.2	20.8	37.1	3.9	40	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.0	92.7	69.6	89.7	69.0	86.5	68.0	72.4	86.1	70.9	84.4	69.5	82.5	7.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.3	105.4	77.1	66.6	99.2	75.7	65.2	94.1	74.7	36.2	86.1	34.9	84.5	33.7	82.6	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.2	17.6	15.3	DB	5.0	97.3	6.1	3.2	0.6	99.6	-3.0	101.5	-6.4	103.3	-10.8	105.6	(4)
			WB	4.4	74.7	6.0	2.0	0.1	76.2	-3.5	77.3	-6.9	78.4	-11.2	79.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.8	31.4	34.8	43.6	54.0	62.6	69.1	72.7	72.1	62.9	53.1	43.1	33.2
	DBStd	16.37	8.49	9.36	7.98	6.78	6.36	6.10	5.59	5.74	6.54	7.43	7.65	8.42
	HDD50	2073	576	427	224	37	1	0	0	0	0	55	230	523
	HDD65	5181	1041	845	663	331	122	28	7	9	117	373	658	987
	CDD50	3099	0	2	26	158	390	574	703	685	388	150	22	1
	CDD65	732	0	0	0	2	47	152	245	229	54	3	0	0
	CDH74	7444	0	0	0	51	513	1509	2510	2328	502	31	0	0
	CDH80	2826	0	0	0	4	115	537	1058	979	132	1	0	0
Wind	WSAvg	6.9	6.9	7.5	8.3	8.0	7.1	6.6	6.6	6.0	6.4	6.1	7.0	6.7
Precipitation	PrecAvg	21.3	1.1	1.2	1.1	1.4	2.2	2.6	2.7	2.1	2.0	1.8	1.5	1.5
	PrecMax	34.1	2.7	3.1	3.5	3.1	5.9	5.7	6.2	7.4	4.8	4.3	3.8	3.5
	PrecMin	13.7	0.2	0.0	0.0	0.0	0.2	0.6	0.1	0.2	0.4	0.0	0.0	0.0
	PrecStd	5.7	0.7	0.9	0.7	0.9	1.2	1.3	1.5	1.5	1.4	1.2	0.9	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	60.9	69.4	79.2	87.2	93.6	97.1	97.6	88.8	78.0	65.6	54.0
		MCWB	48.3	50.7	54.0	61.1	65.9	70.2	70.5	69.6	66.8	63.0	56.9	49.8
	2%	DB	49.0	55.2	64.7	74.8	83.3	89.6	92.7	92.9	83.9	73.4	60.9	50.2
		MCWB	45.1	47.0	51.6	58.7	65.1	69.7	70.0	69.0	64.9	60.8	54.2	46.7
	5%	DB	45.9	51.0	60.4	70.9	79.8	86.1	89.4	89.4	79.8	69.7	57.5	46.5
		MCWB	42.8	45.2	49.8	56.6	63.8	68.4	69.2	68.6	63.9	59.3	52.3	43.8
	10%	DB	42.8	47.5	56.7	67.6	76.2	82.7	86.1	85.6	76.0	65.6	54.2	43.8
		MCWB	40.4	43.3	47.7	54.9	62.3	67.2	68.2	67.5	62.4	57.4	50.2	41.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.9	50.9	55.8	62.8	68.6	74.3	74.1	74.0	68.8	64.7	58.1	50.7
		MCDB	53.3	58.4	65.7	77.0	82.4	86.6	87.9	88.2	83.6	74.4	63.3	53.4
	2%	WB	45.9	48.0	52.9	60.1	66.6	71.9	72.2	71.9	66.9	62.2	55.2	46.8
		MCDB	48.8	53.7	61.4	71.1	79.6	84.4	86.4	85.9	80.0	71.1	59.9	49.4
	5%	WB	43.0	45.8	50.8	57.9	65.1	70.1	70.9	70.3	65.1	60.1	52.8	44.3
		MCDB	45.3	50.1	59.1	68.5	77.4	82.1	84.7	84.2	76.2	67.7	56.9	46.3
	10%	WB	40.5	43.7	48.6	55.9	63.3	68.4	69.5	68.6	63.5	58.1	50.4	42.0
		MCDB	42.6	47.3	56.0	65.7	74.1	79.9	82.5	82.0	73.1	64.5	53.8	43.6
Mean Daily Temperature Range	5% DB	MDBR	10.0	13.3	16.9	19.5	19.8	20.0	21.0	21.4	18.9	17.9	13.1	9.4
		MCDBR	13.8	19.0	23.3	25.1	25.8	25.0	26.6	27.1	25.1	23.4	18.0	12.5
		MCWBR	10.2	12.7	13.5	12.7	11.5	9.3	8.8	8.7	10.2	12.4	12.2	10.0
	5% WB	MCDBR	13.0	17.0	20.7	22.6	23.0	22.5	23.3	23.4	21.7	21.1	16.6	12.1
		MCWBR	10.0	11.9	12.8	12.0	11.1	9.4	8.7	8.8	9.8	11.9	11.8	9.9
Clear-Sky Solar Irradiance	taub	0.334	0.357	0.394	0.448	0.432	0.433	0.447	0.446	0.421	0.387	0.361	0.333	
	taud	2.345	2.299	2.232	2.092	2.204	2.233	2.196	2.206	2.242	2.321	2.343	2.360	
	Ebn at Noon	233	252	259	255	265	265	259	253	248	238	220	218	
	Edh at Noon	24	30	37	47	44	43	44	42	37	30	24	21	
All-Sky Solar Radiation	RadAvg	331	599	1004	1460	1773	1921	1886	1706	1193	777	424	254	
	RadStd	39	94	137	138	169	132	151	157	134	83	39	37	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.30	N/A	N/A	N/A	+1.33	+1.49	-211	-297	+167	+90
(47)	Regional (51 neighbors)	+1.13	N/A	N/A	N/A	+0.92	+0.92	-221	-331	+191	+103

Nomenclature: See separate page