

SZOLNOK, Hungary

WMO: 128600

Lat: 47.123N

Lon: 20.236E

Elev: 98

StdP: 100.15

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.8	-9.3	-14.6	1.1	-10.1	-12.3	1.3	-7.9	10.5	2.3	9.3	2.8	1.7	40	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	33.7	20.9	32.0	20.6	30.3	20.0	22.4	30.1	21.6	29.1	20.8	28.1	3.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	15.1	25.1	19.2	14.2	24.3	18.4	13.4	23.7	66.2	30.0	63.4	29.1	60.5	28.1	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.0	7.9	6.9	DB	-15.0	36.3	3.4	1.8	-17.4	37.5	-19.4	38.6	-21.3	39.6	-23.8	40.9	
			WB	-15.3	23.7	3.4	1.1	-17.7	24.5	-19.7	25.2	-21.6	25.8	-24.0	26.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.6	-0.3	1.6	6.4	12.2	17.0	20.6	22.6	22.3	17.2	11.7	6.2	0.6	(6)
(7)		DBStd	9.10	4.72	5.20	4.43	3.76	3.53	3.39	3.11	3.19	3.64	4.13	4.25	4.68	(7)
(8)		HDD10.0	1152	320	237	124	21	1	0	0	0	31	128	291		(8)
(9)		HDD18.3	2878	578	469	368	184	68	16	4	5	65	207	366	548	(9)
(10)		CDD10.0	1722	0	1	14	88	217	319	391	381	216	83	12	1	(10)
(11)		CDD18.3	407	0	0	0	1	26	84	136	127	30	2	0	0	(11)
(12)		CDH23.3	4136	0	0	0	28	285	838	1394	1293	279	17	0	0	(12)
(13)		CDH26.7	1570	0	0	0	2	64	298	588	544	73	1	0	0	(13)
(14)	Wind	WSAvg	3.1	3.1	3.4	3.7	3.6	3.2	3.0	2.9	2.7	2.9	2.7	3.1	3.0	(14)
(15)	Precipitation	PrecAvg	541	28	31	27	36	55	67	68	54	51	45	39	39	(15)
(16)		PrecMax	867	69	78	88	78	150	144	157	188	123	108	96	90	(16)
(17)		PrecMin	349	5	0	1	0	6	14	2	4	11	0	0	0	(17)
(18)		PrecStd	145	18	23	19	22	31	34	39	37	36	31	22	25	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	16.0	20.8	26.2	30.6	34.2	36.2	36.5	31.5	25.5	18.7	12.2	(19)
(20)		0.4%	MCWB	9.1	10.4	12.2	16.2	18.9	21.2	21.4	20.9	19.3	17.2	13.8	9.9	(20)
(21)		2%	DB	9.5	12.9	18.2	23.8	28.5	32.0	33.7	33.8	28.8	23.0	16.1	10.1	(21)
(22)		2%	MCWB	7.3	8.3	10.9	14.8	18.4	21.0	21.1	20.5	18.3	16.0	12.3	8.2	(22)
(23)		5%	DB	7.7	10.6	15.8	21.6	26.6	30.0	31.9	31.9	26.5	20.9	14.2	8.1	(23)
(24)		5%	MCWB	6.0	7.3	9.9	13.7	17.7	20.2	20.7	20.3	17.7	15.2	11.3	6.5	(24)
(25)		10%	DB	6.0	8.6	13.7	19.8	24.6	28.2	30.0	29.8	24.4	18.6	12.3	6.6	(25)
(26)		10%	MCWB	4.6	6.3	8.7	12.7	16.8	19.5	20.1	19.7	16.9	14.1	10.1	5.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	10.5	13.2	17.1	20.4	23.5	23.4	23.3	20.4	18.1	14.5	10.4	(27)
(28)		0.4%	MCDWB	11.8	14.7	18.7	25.0	28.0	30.3	31.1	31.2	28.7	23.5	17.4	11.9	(28)
(29)		2%	WB	7.7	8.9	11.6	15.6	19.2	22.2	22.4	22.2	19.4	16.8	12.9	8.2	(29)
(30)		2%	MCDWB	9.3	12.0	16.3	21.7	26.4	29.1	30.2	29.9	26.7	21.7	15.5	9.7	(30)
(31)		5%	WB	6.1	7.7	10.5	14.4	18.4	21.2	21.6	21.3	18.4	15.6	11.6	6.8	(31)
(32)		5%	MCDWB	7.4	10.1	15.0	20.3	25.2	27.9	29.3	29.0	24.6	19.8	13.8	7.9	(32)
(33)		10%	WB	4.7	6.5	9.2	13.3	17.4	20.2	20.8	20.4	17.5	14.5	10.2	5.6	(33)
(34)		10%	MCDWB	5.9	8.5	13.4	18.7	23.4	26.6	28.1	27.8	22.8	18.1	12.1	6.4	(34)
(35)	Mean Daily Temperature Range		MDBR	5.6	7.4	9.4	10.8	11.0	11.1	11.7	11.9	10.5	9.9	7.3	5.2	(35)
(36)		5% DB	MCDBR	7.7	10.6	12.9	14.0	14.3	13.9	14.8	15.1	13.9	13.0	10.0	7.0	(36)
(37)		5% DB	MCWBR	5.6	7.0	7.5	7.1	6.4	5.2	4.9	4.8	5.7	6.9	6.8	5.5	(37)
(38)		5% WB	MCDBR	7.2	9.5	11.5	12.6	12.8	12.5	13.0	13.0	12.1	11.7	9.2	6.7	(38)
(39)		5% WB	MCWBR	5.6	6.6	7.1	6.7	6.2	5.2	4.8	4.9	5.4	6.6	6.6	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.334	0.357	0.394	0.448	0.432	0.433	0.447	0.446	0.421	0.387	0.361	0.333	(40)	
(41)		taud	2.345	2.299	2.232	2.092	2.204	2.233	2.196	2.206	2.242	2.321	2.343	2.360	(41)	
(42)		Ebn at Noon	736	796	818	805	835	835	816	798	781	750	693	688	(42)	
(43)		Edh at Noon	75	96	118	149	139	135	139	132	116	93	75	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.04	1.89	3.17	4.60	5.59	6.05	5.95	5.38	3.76	2.45	1.34	0.80	(44)	
(45)		RadStd	0.12	0.30	0.43	0.43	0.53	0.42	0.48	0.49	0.42	0.26	0.12	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.72	N/A	N/A	N/A	+0.74	+0.83	-117	-165	+93	+50
(47)	Regional (51 neighbors)	+0.63	N/A	N/A	N/A	+0.51	+0.51	-123	-184	+106	+57

Nomenclature: See separate page