

POROSZLO, Hungary

WMO: 128660

Lat: 47.650N

Lon: 20.633E

Elev: 92

StdP: 100.22

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.6	-9.8	-15.9	0.9	-11.2	-13.4	1.2	-8.2	8.5	2.8	7.5	1.5	1.2	40	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	33.5	22.3	31.8	21.5	30.3	20.7	23.5	31.0	22.5	29.8	21.6	28.6	2.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.9	27.8	20.0	14.9	26.1	19.2	14.1	24.8	70.3	31.0	66.5	29.8	63.2	28.8	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.1	6.0	5.1	-15.3	35.8	3.9	1.4	-18.1	36.9	-20.3	37.7	-22.5	38.5	-25.3	39.5
			-15.6	24.8	3.7	1.0	-18.2	25.5	-20.4	26.1	-22.5	26.6	-25.1	27.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	-1.1	0.8	6.0	12.3	17.0	20.6	22.3	22.0	17.2	11.2	5.7	0.3
	DBStd	9.24	4.60	4.79	4.44	3.62	3.64	3.37	3.20	3.12	3.60	3.94	4.11	4.31
	HDD10.0	1229	344	259	134	18	1	0	0	0	0	34	138	301
	HDD18.3	2974	602	492	381	182	68	16	4	6	63	221	381	559
	CDD10.0	1691	0	1	11	87	219	319	383	373	217	72	8	0
	CDD18.3	394	0	0	0	2	28	84	129	121	29	1	0	0
	CDH23.3	4144	0	0	0	40	329	875	1344	1244	303	10	0	0
	CDH26.7	1561	0	0	0	7	89	304	565	513	82	1	0	0
Wind	WSAvg	2.2	2.2	2.3	2.7	2.4	2.3	2.2	2.2	2.0	2.0	1.9	2.0	1.9
Precipitation	PrecAvg	557	28	35	30	41	56	66	77	53	52	43	40	45
	PrecMax	924	76	79	99	91	156	167	138	214	143	133	89	84
	PrecMin	352	4	3	0	3	10	20	20	4	3	0	0	4
	PrecStd	153	18	23	23	26	35	35	36	44	36	31	23	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	14.5	20.7	27.6	31.8	33.6	36.2	35.5	31.5	24.6	17.6	11.4
		MCWB	7.5	8.9	12.5	17.1	19.5	23.2	22.5	21.8	20.1	17.5	13.6	9.2
	2%	DB	8.2	11.1	18.0	24.1	29.0	31.6	33.7	33.3	29.0	22.2	15.0	9.0
		MCWB	6.0	7.7	11.1	14.6	18.8	21.6	22.7	21.7	19.0	15.6	11.9	7.5
	5%	DB	6.3	9.0	15.9	22.1	27.0	30.2	31.9	31.5	26.8	20.2	13.1	7.3
		MCWB	4.7	6.5	9.7	13.6	17.9	20.7	21.9	21.3	18.2	14.9	10.8	6.0
	10%	DB	4.7	7.2	13.5	20.1	24.8	28.4	30.0	29.7	24.6	18.0	11.5	5.8
		MCWB	3.7	5.4	8.4	12.3	16.8	19.8	21.0	20.5	17.3	13.8	9.7	4.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	9.6	13.2	17.3	20.7	24.5	24.6	24.3	21.0	18.2	14.1	9.6
		MCDB	10.6	13.2	19.0	26.2	29.0	31.5	32.1	31.7	29.6	23.2	16.9	10.9
	2%	WB	6.3	8.1	11.6	15.5	19.6	23.0	23.6	23.0	19.8	16.5	12.6	7.8
		MCDB	7.9	10.4	16.7	22.6	27.0	29.4	31.5	30.7	27.0	21.0	14.5	8.9
	5%	WB	5.0	6.7	10.2	14.3	18.6	21.8	22.6	22.1	18.8	15.4	11.1	6.2
		MCDB	6.0	8.6	14.8	20.5	25.5	28.1	30.2	29.5	25.4	19.1	12.5	7.0
	10%	WB	3.7	5.6	8.9	13.2	17.5	20.7	21.6	21.2	17.8	14.3	9.9	5.0
		MCDB	4.7	7.3	12.7	18.8	23.8	26.6	28.7	28.2	23.3	17.4	11.4	5.6
Mean Daily Temperature Range	5% DB	MDBR	5.7	7.1	9.9	11.8	12.0	12.1	12.6	12.8	11.7	10.5	7.3	5.0
		MCDBR	7.3	10.0	14.2	15.0	15.3	14.2	15.1	15.2	14.9	13.5	9.9	6.8
		MCWBR	5.7	7.3	8.2	7.4	7.0	6.0	6.1	6.2	6.7	7.7	6.8	5.6
	5% WB	MCDBR	6.8	8.8	12.7	13.7	14.0	12.9	14.1	14.0	13.5	12.1	8.6	6.2
		MCWBR	5.4	6.6	7.7	6.9	6.7	5.9	6.1	6.2	6.3	7.2	6.2	5.3
Clear-Sky Solar Irradiance	taub	0.331	0.354	0.393	0.447	0.432	0.434	0.450	0.448	0.418	0.386	0.360	0.330	
	taud	2.336	2.298	2.236	2.103	2.208	2.235	2.196	2.207	2.256	2.322	2.341	2.352	
	Ebn at Noon	731	794	817	804	834	833	812	795	782	746	686	682	
	Edh at Noon	74	95	117	147	138	135	139	131	114	92	74	65	
All-Sky Solar Radiation	RadAvg	0.98	1.82	3.14	4.55	5.55	5.97	5.83	5.32	3.72	2.37	1.26	0.76	
	RadStd	0.12	0.30	0.42	0.43	0.53	0.38	0.51	0.46	0.42	0.27	0.12	0.11	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (55 neighbors)	+0.63	N/A	N/A	+0.97	+0.55	+0.54	-125	-189	+100	+46

Nomenclature: See separate page