

EGER, Hungary

WMO: 128700

Lat: 47.900N

Lon: 20.383E

Elev: 218

StdP: 98.73

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.5	-8.5	-16.9	0.9	-7.4	-14.3	1.1	-5.9	8.3	5.0	7.2	4.3	1.7	340	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	32.6	20.5	30.7	19.9	29.0	19.3	21.9	29.3	21.0	28.6	20.2	27.3	2.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.6	25.5	18.5	13.8	24.3	17.7	13.0	23.4	65.1	29.2	61.6	28.6	58.8	27.2	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.0	5.9	5.2	-13.4	34.8	2.7	1.8	-15.4	36.1	-17.0	37.2	-18.5	38.2	-20.5	39.6		
(5)			-14.0	23.3	2.5	1.1	-15.8	24.1	-17.3	24.8	-18.7	25.4	-20.5	26.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	-0.7	1.3	6.2	12.2	16.4	19.8	21.7	21.6	16.8	11.4	6.1	0.4		
	DBStd	8.85	4.39	4.26	4.40	3.81	3.56	3.46	3.22	3.27	3.59	4.02	4.13	4.22		
	HDD10.0	1184	332	243	129	21	1	0	0	0	1	33	126	297		
	HDD18.3	2957	591	477	376	186	81	23	7	7	71	216	367	556		
	CDD10.0	1604	0	0	12	87	200	295	361	360	204	76	9	0		
	CDD18.3	336	0	0	0	2	21	69	110	109	25	1	0	0		
	CDH23.3	3108	0	0	0	23	195	611	1034	1041	199	6	0	0		
	CDH26.7	1015	0	0	0	2	34	175	372	387	46	0	0	0		
(14) Wind	WSAvg	2.4	2.2	2.4	2.8	2.7	2.6	2.5	2.5	2.3	2.3	2.2	2.3	2.1		
(15) Precipitation	PrecAvg	580	28	31	31	42	63	68	79	60	52	43	42	40		
	PrecMax	1051	71	78	107	111	202	164	173	198	144	113	97	84		
	PrecMin	334	3	0	0	0	15	18	3	5	0	0	0	0		
	PrecStd	158	19	22	25	29	41	35	45	44	37	31	25	23		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	14.0	20.0	25.9	29.8	32.9	35.2	35.1	30.5	24.1	17.5	11.0		
		MCWB	7.3	8.4	11.5	15.5	17.6	20.8	20.8	20.4	18.8	16.2	12.8	8.2		
	2%	DB	8.5	10.7	17.5	23.3	27.3	30.5	32.4	32.8	27.7	21.8	15.1	9.1		
		MCWB	6.4	6.8	10.1	14.0	17.3	20.2	20.6	20.4	17.8	15.2	11.3	7.2		
	5%	DB	6.9	8.9	15.2	21.3	25.5	28.7	30.5	30.6	25.5	19.9	13.4	7.5		
		MCWB	5.0	5.8	8.8	12.8	16.7	19.3	20.2	19.8	16.9	14.3	10.4	5.9		
	10%	DB	5.3	7.3	13.1	19.4	23.6	27.0	28.6	28.7	23.6	17.8	11.9	6.0		
		MCWB	3.8	5.0	7.8	11.8	15.7	18.7	19.5	19.3	16.0	13.2	9.5	4.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	8.7	12.2	16.3	19.3	23.1	23.0	22.8	19.7	17.1	13.6	8.8		
		MCDB	9.7	12.5	18.0	24.0	26.4	30.0	29.7	30.3	28.7	22.5	16.2	9.9		
	2%	WB	6.7	7.4	10.7	14.7	18.3	21.5	21.9	21.7	18.6	15.8	12.1	7.5		
		MCDB	8.1	9.9	15.7	21.6	25.5	28.2	29.6	29.2	26.0	20.7	14.3	8.9		
	5%	WB	5.3	6.4	9.6	13.5	17.4	20.4	21.0	20.7	17.6	14.8	10.9	6.1		
		MCDB	6.6	8.3	14.0	19.9	23.9	26.8	28.8	28.4	23.9	19.0	12.8	7.4		
	10%	WB	3.9	5.3	8.4	12.4	16.4	19.3	20.2	19.9	16.7	13.7	9.7	4.8		
		MCDB	5.2	7.0	12.5	18.3	22.4	25.3	27.1	27.4	22.2	17.1	11.6	5.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.6	6.7	8.7	10.1	10.5	10.7	11.1	11.3	10.0	8.8	6.3	5.0		
		MCDBR	6.7	8.9	12.2	12.8	13.0	12.8	13.5	13.7	12.6	11.3	8.5	6.0		
		MCWBR	5.1	6.1	7.0	6.3	6.0	5.6	5.1	5.2	5.4	5.9	5.4	4.7		
		MCDBR	6.2	7.7	10.9	11.7	11.7	11.4	11.9	12.1	11.2	10.3	7.4	5.5		
	5% WB	MCWBR	5.0	5.7	6.7	6.0	5.9	5.5	5.1	5.2	5.2	5.7	5.2	4.5		
(40) Clear-Sky Solar Irradiance	taub		0.321	0.343	0.381	0.433	0.421	0.423	0.438	0.436	0.406	0.377	0.352	0.320		
	taud		2.352	2.319	2.267	2.142	2.230	2.256	2.219	2.232	2.282	2.343	2.364	2.374		
	Ebn at Noon		742	806	829	817	843	842	822	806	793	755	695	693		
	Edh at Noon		72	92	113	141	134	132	135	128	111	89	71	63		
(44) All-Sky Solar Radiation	RadAvg		0.97	1.79	3.09	4.48	5.44	5.86	5.70	5.21	3.66	2.30	1.22	0.74		
	RadStd		0.12	0.29	0.42	0.43	0.55	0.39	0.51	0.45	0.43	0.27	0.13	0.10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (50 neighbors)		+0.60	N/A	N/A	+0.96	+0.56	+0.50	-126	-188	+98	+45

Nomenclature: See separate page