

NYIREGYHAZA, Hungary

WMO: 128920

Lat: 47.984N

Lon: 21.692E

Elev: 103

StdP: 100.09

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.0	-9.4	-16.2	0.9	-9.6	-13.7	1.2	-7.9	10.8	-0.2	9.6	-0.8	3.2	40	0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	32.6	21.5	30.8	20.8	29.2	20.0	22.7	29.9	21.7	28.8	20.8	27.6	2.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.3	15.2	26.1	19.3	14.2	24.9	18.4	13.4	24.0	67.2	30.2	63.7	28.9	60.5	27.6	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.0	7.0	-14.6	35.1	3.3	1.7	-16.9	36.3	-18.8	37.3	-20.7	38.2	-23.0	39.4		
(5)			-15.1	23.9	3.1	1.1	-17.3	24.7	-19.0	25.4	-20.8	26.0	-23.0	26.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	-1.2	0.9	5.7	11.9	16.4	19.8	21.5	21.2	16.1	10.8	5.3	0.1		
	DBStd	9.02	4.57	4.71	4.45	4.13	3.71	3.46	3.17	3.10	3.70	4.17	4.46	4.54		
	HDD10.0	1276	348	256	142	27	2	0	0	0	1	41	152	307		
	HDD18.3	3081	607	489	390	194	82	24	8	9	87	234	391	566		
	CDD10.0	1557	0	1	10	86	199	294	356	348	185	67	11	1		
	CDD18.3	319	0	0	0	2	22	69	106	98	21	1	0	0		
	CDH23.3	3091	0	0	0	34	239	629	1023	964	193	9	0	0		
	CDH26.7	1061	0	0	0	6	48	199	392	368	48	0	0	0		
(14) Wind	WSAvg	3.4	3.4	3.7	4.2	3.9	3.6	3.3	3.1	3.0	3.2	3.1	3.3	3.1		
(15) Precipitation	PrecAvg	553	27	32	30	45	58	64	69	49	51	45	41	41		
	PrecMax	920	60	89	112	104	152	108	153	116	153	98	72	96		
	PrecMin	415	7	3	5	2	18	21	12	8	14	2	0	2		
	PrecStd	115	13	21	26	26	27	28	38	29	31	29	19	24		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.4	14.1	20.0	26.9	30.1	33.0	35.2	35.0	31.0	24.6	18.6	12.2		
		MCWB	7.6	9.2	11.5	16.0	18.3	22.1	21.8	21.4	19.9	16.6	12.9	9.6		
	2%	DB	8.2	11.1	17.1	23.7	28.0	30.9	32.6	32.6	27.7	22.4	15.9	9.5		
		MCWB	6.6	7.4	10.2	13.9	17.6	20.8	21.6	21.5	18.5	15.6	11.7	7.6		
	5%	DB	6.3	9.1	14.8	21.6	26.1	29.0	30.6	30.6	25.5	20.0	13.7	7.5		
		MCWB	5.0	6.3	8.9	13.0	17.0	20.0	20.9	20.9	17.6	14.7	10.6	6.1		
	10%	DB	4.7	7.3	12.7	19.5	24.0	27.1	28.8	28.5	23.2	17.7	11.8	5.9		
		MCWB	3.6	5.2	8.0	12.0	16.1	19.1	20.3	20.0	16.5	13.5	9.5	4.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	9.4	12.5	16.6	19.7	23.3	23.7	24.1	20.4	17.6	13.8	9.5		
		MCDB	9.6	13.1	17.7	25.4	27.0	30.4	30.8	31.0	28.7	22.5	17.1	11.6		
	2%	WB	6.7	7.8	11.0	15.0	18.5	22.0	22.6	22.6	19.3	16.2	12.2	7.7		
		MCDB	8.1	10.5	15.6	22.0	25.6	28.7	30.2	29.6	26.3	21.2	15.2	9.2		
	5%	WB	5.2	6.6	9.7	13.7	17.6	21.0	21.7	21.5	18.2	15.0	10.9	6.2		
		MCDB	6.2	8.8	14.0	20.0	24.3	27.1	29.1	28.6	24.4	19.4	13.3	7.4		
	10%	WB	3.7	5.3	8.4	12.7	16.6	19.8	20.8	20.5	17.1	13.9	9.6	4.8		
		MCDB	4.7	7.1	12.1	18.3	22.8	25.8	27.4	27.5	22.1	17.2	11.7	5.7		
(35) Mean Daily Temperature Range	MDBR		4.9	6.4	8.5	10.4	10.8	10.9	11.5	11.9	10.5	9.6	6.8	4.6		
	5% DB	MCDBR	6.1	8.9	11.7	13.6	14.2	13.6	14.6	15.0	13.8	12.9	9.8	6.3		
		MCWBR	4.8	6.2	6.7	6.3	5.8	5.5	5.6	5.8	5.9	7.0	6.3	5.0		
	5% WB	MCDBR	5.8	8.3	10.7	12.4	12.7	12.4	13.3	13.6	12.5	11.7	8.7	6.1		
		MCWBR	4.7	6.0	6.6	6.1	5.7	5.5	5.5	5.9	5.8	6.6	5.8	5.0		
(40) Clear-Sky Solar Irradiance	taub		0.332	0.356	0.394	0.448	0.433	0.435	0.454	0.451	0.415	0.385	0.361	0.331		
	taud		2.306	2.269	2.211	2.090	2.198	2.225	2.179	2.187	2.251	2.306	2.319	2.328		
	Ebn at Noon		721	786	812	801	832	831	807	791	782	742	677	671		
	Edh at Noon		75	97	120	149	139	136	141	134	114	92	74	66		
(44) All-Sky Solar Radiation	RadAvg		0.97	1.77	3.06	4.44	5.40	5.82	5.67	5.20	3.64	2.28	1.21	0.73		
	RadStd		0.13	0.29	0.42	0.44	0.56	0.39	0.52	0.45	0.44	0.28	0.14	0.10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.89	+1.03	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		+0.60	N/A	N/A	+0.92	+0.51	+0.48	-120	-180	+93	+41

Nomenclature: See separate page