

ZALAEGERSZEG ANDRASHIDA, Hungary

WMO: 129150

Lat: **46.867N**Lon: **16.800E**Elev: **591**StdP: **14.39**Time Zone: **1.00 (EUC)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.0	18.2	6.1	7.7	16.5	10.9	9.8	21.8	24.8	32.8	22.3	31.4	8.3	10	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	89.1	69.7	85.9	69.0	82.9	67.7	71.7	84.0	70.2	82.7	68.9	80.8	6.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	103.9	77.9	65.9	97.8	75.9	64.5	93.0	74.3	35.7	83.9	34.5	82.8	33.3	81.2	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	18.3	15.7	10.7	94.2	4.9	3.7	7.1	96.8	4.3	99.0	1.5	101.1	-2.0	103.7
			9.4	74.5	4.7	1.9	6.0	75.8	3.2	76.9	0.6	78.0	-2.9	79.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	31.8	35.1	43.2	52.9	60.1	66.6	69.8	69.2	60.9	52.4	42.8	34.6	(6)
	DBStd	15.11	8.12	8.41	8.44	7.18	6.36	6.41	5.82	5.74	6.02	7.17	7.81	7.15	(7)
	HDD50	2061	566	420	240	52	5	0	0	0	2	61	236	479	(8)
	HDD65	5341	1030	838	677	366	175	58	23	22	152	393	665	942	(9)
	CDD50	2680	0	2	27	138	319	498	615	596	328	134	21	2	(10)
	CDD65	485	0	0	0	2	24	105	172	153	28	1	0	0	(11)
	CDH74	4358	0	0	0	24	234	924	1574	1390	203	9	0	0	(12)
	CDH80	1342	0	0	0	1	31	253	532	493	32	0	0	0	(13)
(14) Wind	WSAvg	6.7	6.8	7.7	8.0	7.9	7.3	6.3	6.1	5.5	6.1	5.9	6.3	6.5	(14)
(15) Precipitation	PrecAvg	26.4	1.1	1.4	1.4	1.7	2.6	3.1	2.8	3.0	2.9	2.6	2.1	1.6	(15)
	PrecMax	38.0	2.7	4.1	3.3	3.6	4.0	5.2	5.4	6.6	6.7	5.6	5.7	4.1	(16)
	PrecMin	18.2	0.2	0.2	0.1	0.0	1.2	1.0	0.4	0.2	0.9	0.0	0.0	0.2	(17)
	PrecStd	5.4	0.7	1.1	0.9	0.9	0.9	1.1	1.3	1.8	1.6	1.5	1.4	1.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.6	59.2	68.4	77.2	83.4	90.0	92.7	94.0	83.7	75.2	65.5	56.9	(19)
		MCWB	46.9	47.8	52.4	60.4	64.8	70.1	70.1	69.4	66.4	62.8	56.2	51.0	(20)
	2%	DB	50.2	54.1	64.1	73.1	79.7	86.3	88.9	89.4	79.3	70.5	60.4	52.2	(21)
		MCWB	44.0	45.9	51.1	57.0	64.0	69.7	70.1	69.1	65.7	60.9	53.9	47.4	(22)
	5%	DB	46.5	50.3	60.1	69.5	76.4	82.9	85.6	85.7	75.7	67.2	56.6	47.5	(23)
		MCWB	42.0	43.5	49.4	55.6	62.3	68.3	69.1	68.6	63.9	59.1	51.7	43.5	(24)
	10%	DB	42.7	46.9	56.1	65.9	72.8	79.6	82.6	81.9	72.0	63.6	53.5	44.0	(25)
		MCWB	38.9	41.4	47.1	53.8	60.5	66.5	67.9	67.3	61.9	57.2	49.8	40.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.0	49.2	54.1	61.4	67.6	72.9	74.5	73.5	68.9	64.3	57.0	51.4	(27)
		MCDB	53.1	58.1	64.6	74.8	79.8	85.0	86.3	85.2	81.0	73.0	63.8	56.4	(28)
	2%	WB	45.0	46.4	52.0	58.6	65.3	70.7	71.8	71.3	66.8	61.7	54.5	47.9	(29)
		MCDB	49.2	52.8	61.9	70.4	76.7	82.8	84.1	83.9	77.0	68.9	59.5	51.9	(30)
	5%	WB	42.2	44.1	49.9	56.5	63.4	69.0	70.3	69.8	64.8	59.7	52.2	44.0	(31)
		MCDB	45.7	49.5	58.6	67.1	74.1	81.0	82.8	82.5	73.3	66.1	56.3	46.8	(32)
	10%	WB	39.5	41.8	47.9	54.5	61.5	67.4	68.9	68.3	62.8	57.8	49.9	41.2	(33)
		MCDB	42.1	46.2	55.2	64.3	71.2	78.2	80.7	79.9	70.4	62.9	53.1	43.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	12.0	15.2	17.5	18.3	18.7	19.6	19.5	16.8	15.7	10.7	8.8	(35)
		MCDBR	14.7	17.7	21.7	23.0	23.5	23.1	24.2	25.1	21.7	20.2	15.6	14.5	(36)
	5% WB	MCWBR	10.0	11.6	12.1	11.4	11.2	10.1	9.3	9.3	10.0	11.2	10.3	10.6	(37)
		MCWBR	13.9	16.6	19.8	20.8	21.6	21.9	22.4	22.8	20.0	18.6	14.9	13.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.325	0.350	0.386	0.432	0.426	0.430	0.434	0.437	0.414	0.385	0.354	0.326	(40)
		taud	2.381	2.330	2.255	2.140	2.211	2.241	2.231	2.230	2.265	2.323	2.362	2.404	(41)
	Ebn at Noon		239	256	263	260	267	266	263	256	251	239	224	225	(42)
		Edh at Noon	23	30	37	45	44	43	43	41	36	30	23	20	(43)
(44) All-Sky Solar Radiation	RadAvg		366	620	1001	1436	1739	1897	1872	1659	1172	764	407	278	(44)
	RadStd		44	89	121	141	158	135	135	168	141	80	46	39	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (76 neighbors)	+1.01	N/A	N/A	+1.62	+0.88	+0.81	-194	-272	+173	+104

Nomenclature: See separate page