

KESZTHELY, Hungary

WMO: 129200

Lat: 46.736N

Lon: 17.239E

Elev: 363

StdP: 14.50

Time Zone: 1.00 (EUC)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.3	17.6	8.3	8.5	15.0	12.5	10.5	19.6	29.3	29.1	25.2	33.0	3.1	340	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	87.8	71.1	84.6	70.0	81.7	68.4	72.8	84.4	71.3	82.5	69.7	80.1	4.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.1	108.5	78.7	67.4	102.0	77.2	65.7	96.2	75.4	36.6	84.3	35.2	82.9	33.9	80.2	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.9	15.5	12.6	DB	7.1	92.4	4.8	2.8	3.7	94.4	0.8	96.1	-1.9	97.6	-5.4	99.6
			WB	6.7	76.1	4.7	1.1	3.3	76.8	0.5	77.5	-2.2	78.1	-5.6	78.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.4	32.0	34.6	42.3	52.0	60.5	65.8	69.1	69.5	61.9	52.0	42.1	33.6	(6)
	DBStd	15.11	7.30	8.86	8.13	7.07	5.56	5.74	5.30	6.03	5.01	7.02	7.15	7.24	(7)
	HDD50	2137	558	434	260	59	2	0	0	0	0	62	251	511	(8)
	HDD65	5414	1023	852	705	390	157	58	22	26	118	403	687	973	(9)
	CDD50	2641	0	3	20	120	329	474	592	604	357	125	14	3	(10)
	CDD65	441	0	0	0	1	19	82	149	165	24	1	0	0	(11)
	CDH74	3698	0	0	1	14	172	675	1262	1441	128	5	0	0	(12)
	CDH80	1044	0	0	0	0	22	166	342	507	7	0	0	0	(13)
(14) Wind	WSAvg	4.2	3.8	4.5	5.0	5.0	4.3	4.0	4.1	3.5	3.5	3.6	4.0	4.5	(14)
(15) Precipitation	PrecAvg	26.3	1.3	1.3	1.7	2.0	2.3	3.0	3.2	2.8	2.2	1.7	2.8	1.8	(15)
	PrecMax	40.8	2.5	3.3	4.4	6.2	6.0	5.5	7.5	6.9	4.1	5.6	6.9	3.9	(16)
	PrecMin	16.4	0.1	0.3	0.5	0.2	0.1	0.3	0.3	0.5	0.4	0.0	0.8	0.3	(17)
	PrecStd	6.2	0.6	0.7	0.9	1.5	1.4	1.4	2.1	1.8	1.1	1.5	1.6	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.6	61.6	69.4	76.0	82.9	89.0	90.0	93.3	80.8	74.6	64.8	58.8	(19)
		MCWB	47.9	50.7	55.7	61.0	65.6	71.6	71.8	72.6	67.5	63.5	56.0	52.3	(20)
	2%	DB	49.4	56.6	63.0	71.4	78.4	84.4	86.4	89.0	77.4	69.3	58.8	52.3	(21)
		MCWB	44.4	47.8	52.0	59.0	64.5	69.6	71.0	71.5	66.4	61.4	52.9	47.3	(22)
	5%	DB	45.2	52.0	58.6	67.5	75.0	81.0	83.7	85.5	74.6	65.4	54.8	46.7	(23)
		MCWB	41.4	45.3	49.8	56.5	63.0	68.4	70.0	70.4	65.1	59.0	51.0	43.4	(24)
	10%	DB	42.1	47.4	54.6	64.0	72.1	77.8	81.0	81.8	71.9	62.4	51.8	42.6	(25)
		MCWB	39.3	42.2	47.3	54.4	61.5	67.0	68.2	68.4	63.3	57.0	49.2	40.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	51.3	56.6	62.5	68.4	73.3	74.5	75.4	70.5	64.6	57.1	52.8	(27)
		MCDB	54.0	60.8	68.6	73.4	78.5	83.4	84.6	85.9	77.6	72.2	63.0	58.6	(28)
	2%	WB	44.7	48.4	52.8	59.8	66.0	71.3	72.7	73.1	67.8	62.1	53.6	47.5	(29)
		MCDB	49.0	56.0	61.7	69.5	76.0	81.6	83.7	85.9	75.5	67.9	57.4	51.8	(30)
	5%	WB	42.0	45.6	50.3	57.4	63.9	69.6	71.1	71.2	66.1	59.9	51.5	43.9	(31)
		MCDB	44.9	51.4	57.8	66.0	73.4	79.7	81.8	83.8	72.8	64.8	54.4	46.4	(32)
	10%	WB	39.5	42.6	47.7	55.0	62.1	67.7	69.4	69.5	64.4	57.9	49.4	40.4	(33)
		MCDB	42.0	46.8	53.8	62.7	70.9	76.6	79.2	80.4	70.6	61.6	51.7	42.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	13.7	15.2	16.7	17.9	18.4	19.7	19.9	17.7	15.1	10.7	8.7	(35)
		MCDBR	15.2	21.6	22.9	21.9	24.0	23.2	24.0	26.0	21.3	19.4	15.6	14.2	(36)
	5% WB	MCWBR	11.0	13.2	13.1	11.3	12.1	11.2	11.2	11.6	11.4	11.9	10.4	9.7	(37)
		MCWBR	14.9	20.7	21.3	20.5	21.8	21.5	22.0	24.7	19.3	17.7	14.4	13.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.329	0.353	0.389	0.437	0.428	0.431	0.436	0.440	0.419	0.388	0.358	0.329	(40)
		taud	2.379	2.324	2.252	2.134	2.214	2.245	2.230	2.230	2.261	2.324	2.362	2.393	(41)
	Ebn at Noon		238	255	262	259	266	266	262	256	249	239	223	224	(42)
		Edh at Noon	23	30	37	46	43	43	43	41	36	30	23	21	(43)
(44) All-Sky Solar Radiation	RadAvg		371	624	1005	1435	1745	1904	1882	1668	1175	771	412	281	(44)
	RadStd		46	90	121	141	155	137	133	170	143	82	48	41	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (73 neighbors)	+0.99	N/A	N/A	N/A	N/A	+0.86	+0.81	-198	-274	+166

Nomenclature: See separate page