

KESZTHELY, Hungary

WMO: 129200

Lat: 46.736N

Lon: 17.239E

Elev: 111

StdP: 100.00

Time Zone: 1.00 (EUC)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.4	-8.0	-13.2	1.2	-9.5	-10.8	1.5	-6.9	13.1	-1.6	11.3	0.5	1.4	340	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	31.0	21.7	29.2	21.1	27.6	20.2	22.7	29.1	21.8	28.0	20.9	26.7	1.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.5	26.0	19.7	14.6	25.1	18.7	13.7	24.1	67.3	29.1	64.1	28.3	60.9	26.8	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	6.9	5.6	DB	-13.8	33.6	2.7	1.5	-15.7	34.7	-17.3	35.6	-18.8	36.4	-20.8	37.6	(4)
(5)			WB	-14.1	24.5	2.6	0.6	-16.0	24.9	-17.5	25.3	-19.0	25.6	-20.9	26.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	0.0	1.4	5.7	11.1	15.9	18.8	20.6	20.8	16.6	11.1	5.6	0.9
	DBStd	8.39	4.06	4.92	4.52	3.93	3.09	3.19	2.94	3.35	2.78	3.90	3.97	4.02
	HDD10.0	1187	310	241	144	33	1	0	0	0	0	34	139	284
	HDD18.3	3008	568	473	392	217	87	32	12	14	66	224	382	541
	CDD10.0	1467	0	2	11	67	183	263	329	336	198	69	8	2
	CDD18.3	245	0	0	0	1	11	46	83	92	13	1	0	0
	CDH23.3	2054	0	0	1	8	96	375	701	801	71	3	0	0
	CDH26.7	580	0	0	0	0	12	92	190	282	4	0	0	0
Wind	WSAvg	1.9	1.7	2.0	2.2	2.3	1.9	1.8	1.9	1.5	1.6	1.6	1.8	2.0
Precipitation	PrecAvg	667	34	33	42	52	59	75	82	72	56	44	72	46
	PrecMax	1036	63	85	111	157	152	140	190	175	104	141	176	99
	PrecMin	417	2	8	13	4	2	7	8	13	10	1	20	7
	PrecStd	157	14	19	23	38	36	35	54	46	29	39	41	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	16.4	20.8	24.4	28.3	31.7	32.2	34.1	27.1	23.6	18.2	14.9
		MCWB	8.8	10.4	13.1	16.1	18.7	22.0	22.1	22.6	19.7	17.5	13.4	11.3
	2%	DB	9.7	13.7	17.2	21.9	25.8	29.1	30.2	31.7	25.2	20.7	14.9	11.3
		MCWB	6.9	8.8	11.1	15.0	18.0	20.9	21.7	21.9	19.1	16.3	11.6	8.5
	5%	DB	7.3	11.1	14.8	19.7	23.9	27.2	28.7	29.7	23.7	18.5	12.7	8.2
		MCWB	5.2	7.4	9.9	13.6	17.2	20.2	21.1	21.3	18.4	15.0	10.5	6.4
	10%	DB	5.6	8.6	12.6	17.8	22.3	25.4	27.2	27.7	22.2	16.9	11.0	5.9
		MCWB	4.0	5.7	8.5	12.5	16.4	19.5	20.1	20.2	17.4	13.9	9.5	4.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	10.7	13.7	16.9	20.2	22.9	23.6	24.1	21.4	18.1	14.0	11.5
		MCDB	12.2	16.0	20.4	23.0	25.8	28.6	29.2	30.0	25.3	22.3	17.2	14.8
	2%	WB	7.0	9.1	11.5	15.5	18.9	21.8	22.6	22.8	19.9	16.7	12.0	8.6
		MCDB	9.4	13.3	16.5	20.8	24.4	27.5	28.7	29.9	24.2	20.0	14.1	11.0
	5%	WB	5.6	7.6	10.2	14.1	17.7	20.9	21.7	21.8	19.0	15.5	10.8	6.6
		MCDB	7.1	10.8	14.4	18.9	23.0	26.5	27.7	28.8	22.7	18.2	12.5	8.0
	10%	WB	4.2	5.9	8.7	12.8	16.7	19.8	20.8	20.8	18.0	14.4	9.7	4.7
		MCDB	5.6	8.2	12.1	17.1	21.6	24.8	26.2	26.9	21.4	16.4	10.9	5.7
Mean Daily Temperature Range	5% DB	MDBR	5.4	7.6	8.4	9.3	10.0	10.2	10.9	11.1	9.8	8.4	5.9	4.8
		MCDBR	8.5	12.0	12.7	12.2	13.4	12.9	13.3	14.4	11.8	10.8	8.7	7.9
		MCWBR	6.1	7.4	7.3	6.3	6.7	6.2	6.2	6.4	6.3	6.6	5.8	5.4
	5% WB	MCDBR	8.3	11.5	11.8	11.4	12.1	12.0	12.2	13.7	10.7	9.9	8.0	7.6
		MCWBR	6.1	7.3	7.0	6.1	6.4	6.2	6.1	6.5	6.2	6.3	5.5	5.4
Clear-Sky Solar Irradiance	taub	0.329	0.353	0.389	0.437	0.428	0.431	0.436	0.440	0.419	0.388	0.358	0.329	
	taud	2.379	2.324	2.252	2.134	2.214	2.245	2.230	2.230	2.261	2.324	2.362	2.393	
	Ebn at Noon	751	805	826	817	840	838	827	806	786	752	704	705	
	Edh at Noon	73	94	117	144	137	134	134	129	115	93	74	65	
All-Sky Solar Radiation	RadAvg	1.17	1.97	3.17	4.52	5.50	6.00	5.93	5.26	3.70	2.43	1.30	0.89	
	RadStd	0.14	0.28	0.38	0.45	0.49	0.43	0.42	0.54	0.45	0.26	0.15	0.13	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (73 neighbors)		+0.55	N/A	N/A	N/A	+0.48	+0.45	-110	-152	+92	+54

Nomenclature: See separate page