

NAGYKANIZSA, Hungary

WMO: 129250

Lat: 46.450N

Lon: 16.967E

Elev: 141

StdP: 99.64

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.4	-8.5	-14.5	1.1	-10.5	-11.7	1.4	-7.0	8.4	1.0	7.5	0.3	1.4	10	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	32.5	21.6	30.9	21.1	29.1	20.5	22.7	29.9	21.9	29.1	21.1	27.8	2.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.4	15.4	25.8	19.5	14.5	24.9	18.7	13.8	24.0	67.5	30.0	64.4	29.2	61.7	28.0	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.1	6.0	5.0	-15.5	34.7	3.7	2.1	-18.1	36.2	-20.3	37.4	-22.4	38.6	-25.1	40.1
			-15.8	24.4	3.7	0.8	-18.4	25.0	-20.6	25.4	-22.6	25.9	-25.3	26.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	0.1	1.8	6.1	11.1	15.3	19.0	20.8	20.3	15.5	10.7	5.8	1.0	(6)
(7)		DBStd	8.26	4.37	4.72	4.28	3.70	3.36	3.40	3.00	3.01	3.31	4.03	4.30	4.27	(7)
(8)		HDD10.0	1164	308	231	133	32	2	0	0	0	1	41	136	281	(8)
(9)		HDD18.3	3034	566	463	381	218	103	32	12	15	96	236	375	538	(9)
(10)		CDD10.0	1411	0	1	11	64	168	271	334	319	166	64	11	1	(10)
(11)		CDD18.3	238	0	0	0	0	10	53	87	76	11	1	0	0	(11)
(12)		CDH23.3	3014	0	0	0	24	205	668	1040	914	154	8	0	0	(12)
(13)		CDH26.7	1041	0	0	0	2	36	219	397	357	29	0	0	0	(13)
(14)	Wind	WSAvg	1.9	2.0	2.2	2.4	2.2	2.0	1.8	1.7	1.5	1.6	1.6	1.8	1.9	(14)
(15)	Precipitation	PrecAvg	752	35	43	41	52	69	79	78	75	88	72	66	53	(15)
(16)		PrecMax	1086	88	143	107	116	143	145	142	155	200	176	151	122	(16)
(17)		PrecMin	461	5	3	1	6	22	31	26	6	27	2	3	4	(17)
(18)		PrecStd	147	22	33	28	30	31	32	30	45	51	44	35	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.5	16.1	21.0	26.0	29.7	33.3	34.7	35.3	30.0	24.5	19.5	14.5	(19)
(20)		0.4%	MCWB	9.4	9.8	12.4	16.3	19.1	21.9	22.4	21.6	20.0	17.7	14.1	10.9	(20)
(21)		2%	DB	11.0	13.6	18.7	23.5	27.5	31.2	32.4	32.6	27.1	22.1	16.8	11.7	(21)
(22)		2%	MCWB	7.7	8.6	11.3	14.2	18.2	21.3	21.8	21.5	19.2	16.4	12.8	9.1	(22)
(23)		5%	DB	8.7	11.5	16.3	21.3	25.7	29.3	30.7	30.6	25.0	20.2	14.6	9.1	(23)
(24)		5%	MCWB	6.2	7.6	10.3	13.3	17.4	20.6	21.3	21.0	18.3	15.6	11.6	7.1	(24)
(25)		10%	DB	6.4	9.2	13.9	19.3	23.7	27.4	28.9	28.4	22.9	17.9	12.6	6.9	(25)
(26)		10%	MCWB	4.6	6.0	8.9	12.2	16.4	19.6	20.5	20.4	17.2	14.2	10.4	5.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	10.5	13.1	16.7	20.4	23.3	24.0	23.7	21.0	18.5	14.7	11.1	(27)
(28)		0.4%	MCDWB	13.3	15.3	19.1	24.3	27.4	30.6	31.5	30.6	27.5	23.2	18.5	14.1	(28)
(29)		2%	WB	8.0	9.0	11.8	15.1	19.1	22.1	22.7	22.6	19.9	17.0	13.2	9.2	(29)
(30)		2%	MCDWB	10.7	13.1	17.4	21.6	25.9	29.2	30.1	29.6	25.6	21.3	16.3	11.5	(30)
(31)		5%	WB	6.4	7.7	10.7	14.0	18.0	21.1	21.9	21.7	18.9	15.9	11.9	7.3	(31)
(32)		5%	MCDWB	8.4	11.0	15.4	19.7	24.4	28.0	29.2	28.8	23.9	19.6	14.5	8.9	(32)
(33)		10%	WB	4.9	6.3	9.4	12.9	16.9	20.2	21.1	20.9	17.7	14.7	10.5	5.6	(33)
(34)		10%	MCDWB	6.2	8.9	13.5	18.4	22.6	26.2	27.6	27.5	21.9	17.6	12.5	6.6	(34)
(35)	Mean Daily Temperature Range	MDBR	7.0	9.2	10.9	12.2	12.6	12.7	13.0	13.4	11.8	11.3	8.1	6.6	(35)	
(36)		5% DB	MCDBR	11.1	13.4	15.6	16.9	16.8	16.0	16.5	17.4	15.6	14.0	12.0	10.1	(36)
(37)		5% DB	MCWBR	8.0	8.7	9.1	8.7	8.3	7.2	7.1	7.5	8.2	8.8	8.3	7.6	(37)
(38)		5% WB	MCDBR	10.4	12.5	14.0	14.6	14.8	14.9	15.0	15.6	14.2	13.1	11.2	9.4	(38)
(39)		5% WB	MCWBR	7.7	8.4	8.3	7.7	7.7	6.9	6.9	7.4	7.8	8.4	7.8	7.3	(39)
(40)		Clear-Sky Solar Irradiance	taub	0.330	0.355	0.391	0.439	0.429	0.432	0.436	0.440	0.420	0.389	0.358	0.330	(40)
(41)	taud		2.377	2.318	2.247	2.125	2.207	2.239	2.228	2.229	2.253	2.318	2.361	2.393	(41)	
(42)	Ebn at Noon		753	805	826	816	840	837	828	807	786	753	708	707	(42)	
(43)	Edh at Noon		74	95	118	145	139	135	135	130	116	94	75	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.20	1.99	3.19	4.51	5.53	6.05	6.00	5.32	3.72	2.47	1.33	0.91	(44)	
(45)		RadStd	0.16	0.29	0.39	0.45	0.47	0.44	0.41	0.55	0.46	0.27	0.16	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (68 neighbors)	+0.54	N/A	N/A	+1.28	+0.48	N/A	N/A	N/A	+96	+62
		+0.54	N/A	N/A	+0.88	+0.50	+0.45	-104	-145	+92	+58

Nomenclature: See separate page