

SIOFOK, Hungary

WMO: 129350

Lat: 46.9106N

Lon: 18.0407E

Elev: 109

StdP: 100.02

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.6	-7.1	-12.8	1.3	-8.2	-10.5	1.5	-6.2	14.7	1.2	13.1	1.1	2.5	70	0.497

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	31.9	22.8	30.2	22.2	28.7	21.5	24.0	29.9	23.0	28.8	22.0	27.8	3.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	16.9	28.6	20.9	15.8	27.2	19.9	14.8	26.0	72.7	30.0	68.6	28.9	65.0	27.9	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.9	11.1	9.6	-12.1	35.0	4.0	1.7	-15.0	36.2	-17.3	37.2	-19.6	38.2	-22.5	39.4		
(5)			-12.7	25.7	3.9	1.0	-15.6	26.5	-17.9	27.1	-20.1	27.7	-22.9	28.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.9	0.1	1.8	6.4	12.4	17.3	21.1	22.9	22.4	17.4	12.1	6.6	1.4	(6)
(7)		DBStd	8.87	3.88	4.39	4.00	3.74	3.28	3.35	2.98	2.87	3.20	3.81	3.88	4.00	(7)
(8)		HDD10.0	1083	306	230	122	19	0	0	0	0	0	23	115	268	(8)
(9)		HDD18.3	2782	564	463	369	179	58	12	2	3	56	196	353	526	(9)
(10)		CDD10.0	1769	0	1	11	91	228	332	401	386	221	87	12	1	(10)
(11)		CDD18.3	426	0	0	0	2	28	94	144	129	27	1	0	0	(11)
(12)		CDH23.3	3018	0	0	0	18	168	671	1100	933	123	4	0	0	(12)
(13)		CDH26.7	888	0	0	0	2	26	189	357	295	19	0	0	0	(13)
(14)	Wind	WSAvg	3.6	3.5	3.7	4.1	3.8	3.9	3.8	3.3	3.5	3.1	3.4	3.4	(14)	
(15)	Precipitation	PrecAvg	608	35	33	32	40	60	66	62	67	63	53	51	45	(15)
(16)		PrecMax	945	82	85	94	103	177	159	144	212	178	133	103	125	(16)
(17)		PrecMin	362	4	2	3	1	13	10	20	3	6	1	1	3	(17)
(18)		PrecStd	136	22	25	22	27	33	34	31	46	44	35	25	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.6	13.7	18.8	25.7	29.2	33.0	34.2	34.1	28.7	23.7	18.9	13.6	(19)
(20)			MCWB	8.1	8.9	11.5	16.4	19.0	22.7	23.1	23.0	20.3	17.2	13.5	10.1	(20)
(21)		2%	DB	8.3	11.2	15.9	22.5	27.0	30.8	31.8	31.7	26.4	21.2	15.4	9.4	(21)
(22)			MCWB	6.0	7.5	10.6	15.2	19.0	22.5	23.1	22.8	19.8	16.4	12.0	7.4	(22)
(23)		5%	DB	6.5	9.2	14.0	20.3	25.2	28.8	30.1	29.7	24.5	19.3	13.4	7.3	(23)
(24)			MCWB	4.7	6.4	9.5	13.9	18.4	21.7	22.4	22.1	18.8	15.6	11.0	5.9	(24)
(25)		10%	DB	5.1	7.3	12.2	18.4	23.4	27.1	28.6	28.1	22.8	17.6	11.8	6.1	(25)
(26)			MCWB	3.8	5.2	8.7	13.2	17.5	20.7	21.6	21.2	17.9	14.7	10.0	4.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.4	9.3	12.4	17.9	21.6	24.9	25.6	25.2	21.7	18.4	13.8	10.4	(27)
(28)			MCDWB	11.2	12.6	17.2	23.4	26.4	30.4	31.5	31.0	26.8	21.9	17.2	13.1	(28)
(29)		2%	WB	6.2	7.8	11.0	15.9	20.1	23.3	24.0	23.9	20.4	17.2	12.5	7.7	(29)
(30)			MCDWB	7.8	10.7	15.1	21.4	25.2	29.1	29.9	29.8	25.3	20.2	15.0	9.1	(30)
(31)		5%	WB	5.0	6.6	10.0	14.7	18.9	22.2	23.0	22.8	19.4	16.0	11.3	6.2	(31)
(32)			MCDWB	6.3	8.9	13.3	19.3	24.1	28.0	28.8	28.6	23.7	18.7	13.1	7.1	(32)
(33)		10%	WB	3.8	5.4	8.9	13.5	17.9	21.2	22.0	21.7	18.3	14.9	10.2	5.1	(33)
(34)			MCDWB	4.9	7.1	11.8	17.7	22.7	26.5	27.8	27.2	22.2	17.4	11.7	6.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.8	6.9	8.1	8.5	8.4	8.4	8.8	7.6	7.3	5.0	4.0	(35)
(36)			MCDBR	6.3	8.5	10.1	11.8	11.9	11.1	11.3	11.6	10.4	9.7	7.9	5.9	(36)
(37)			MCWBR	4.6	5.6	6.1	6.6	6.5	5.8	5.9	6.3	6.0	5.8	5.1	4.6	(37)
(38)		5% WB	MCDWB	6.2	7.6	9.3	10.5	10.5	10.5	10.6	10.8	9.6	8.7	7.4	5.8	(38)
(39)			MCWBR	4.6	5.3	5.9	6.4	6.4	6.0	6.0	6.3	5.9	5.6	5.0	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.357	0.394	0.443	0.433	0.433	0.442	0.445	0.423	0.390	0.360	0.332	(40)	
(41)		taud	2.362	2.305	2.233	2.112	2.200	2.235	2.211	2.214	2.241	2.315	2.348	2.372	(41)	
(42)		Ebn at Noon	743	797	819	810	835	835	821	800	780	748	697	695	(42)	
(43)		Edh at Noon	74	95	119	147	139	135	137	131	117	94	75	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.12	1.93	3.14	4.56	5.51	6.00	5.92	5.28	3.72	2.43	1.31	0.85	(44)	
(45)		RadStd	0.14	0.28	0.41	0.44	0.44	0.53	0.44	0.43	0.52	0.44	0.25	0.13	0.12	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.68	N/A	N/A	N/A	+0.68	+0.69	N/A	N/A	N/A	N/A
(47) Regional (66 neighbors)		+0.57	N/A	N/A	N/A	+0.50	+0.48	-117	-165	+96	+55

Nomenclature: See separate page