

BAJA, Hungary

WMO: 129600

Lat: 46.183N

Lon: 19.017E

Elev: 113

StdP: 99.97

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.0	-9.1	-14.6	1.1	-11.0	-11.7	1.4	-7.4	6.5	3.0	5.9	2.2	1.1	110	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	34.2	21.3	32.5	21.1	30.8	20.5	22.9	30.6	22.1	30.0	21.3	28.8	2.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.5	25.9	19.6	14.6	24.9	18.8	13.8	24.0	68.1	30.6	65.1	29.8	62.2	28.9	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.7	4.9	4.2	-17.5	36.7	4.3	1.8	-20.5	38.0	-23.0	39.1	-25.4	40.1	-28.5	41.4		
(5)			-17.6	24.5	4.4	1.0	-20.8	25.3	-23.4	25.9	-25.8	26.5	-29.0	27.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	-0.1	1.6	6.1	11.8	16.4	19.9	21.7	21.4	16.6	11.9	6.2	1.1		
	DBStd	8.75	4.72	5.14	4.51	3.79	3.60	3.56	3.16	3.15	3.48	4.17	4.40	4.58		
	HDD10.0	1143	313	236	133	24	0	0	0	0	1	30	127	277		
	HDD18.3	2909	572	468	378	198	80	24	8	8	74	201	364	534		
	CDD10.0	1608	0	1	14	78	201	298	362	354	197	89	13	1		
	CDD18.3	331	0	0	0	1	21	72	111	104	21	2	0	0		
	CDH23.3	4384	0	0	1	57	348	934	1407	1292	311	34	0	0		
	CDH26.7	1777	0	0	0	9	93	363	632	584	93	1	0	0		
(14) Wind	WSAvg	1.8	1.8	2.0	2.2	2.1	1.8	1.7	1.7	1.5	1.5	1.5	1.7	1.8		
(15) Precipitation	PrecAvg	625	34	37	33	42	67	75	66	55	62	55	51	48		
	PrecMax	970	76	86	113	99	193	174	168	142	143	129	136	103		
	PrecMin	319	4	2	3	1	14	19	20	5	19	7	3	2		
	PrecStd	137	21	23	23	22	37	42	35	31	37	34	27	28		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.6	17.5	22.2	28.2	31.5	34.7	36.9	37.1	32.5	26.3	20.5	13.7		
		MCWB	9.9	10.5	12.4	16.6	18.9	21.8	21.5	21.0	19.6	17.8	14.7	10.6		
	2%	DB	10.8	14.3	19.6	24.8	29.2	32.6	34.1	34.4	29.3	24.1	17.4	10.8		
		MCWB	7.9	9.3	11.4	14.8	18.8	21.5	21.4	21.3	18.7	16.6	13.0	8.8		
	5%	DB	8.2	11.5	17.0	22.5	27.2	30.7	32.4	32.1	26.9	22.1	14.9	8.7		
		MCWB	6.2	8.0	10.3	13.6	17.8	21.1	21.4	20.9	17.9	15.7	11.8	7.2		
	10%	DB	6.3	9.1	14.4	20.3	25.0	28.8	30.5	30.0	24.6	19.6	12.9	7.0		
		MCWB	4.8	6.5	9.2	12.7	16.8	20.0	20.5	20.3	17.2	14.7	10.5	5.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.1	11.1	13.6	17.2	20.6	23.8	23.8	24.0	21.2	18.7	15.1	11.1		
		MCDB	13.0	16.0	19.9	25.8	28.6	30.9	31.4	31.4	29.0	25.0	19.6	13.4		
	2%	WB	8.3	9.8	12.2	15.7	19.5	22.5	22.8	22.7	19.7	17.3	13.4	9.0		
		MCDB	10.4	13.8	18.0	22.9	26.9	30.2	30.8	30.3	26.8	22.7	16.7	10.6		
	5%	WB	6.5	8.2	10.9	14.5	18.5	21.6	22.0	21.8	18.8	16.1	12.1	7.3		
		MCDB	8.0	10.8	15.9	20.8	25.4	29.2	29.9	29.7	25.0	21.0	14.6	8.5		
	10%	WB	5.0	6.8	9.6	13.4	17.4	20.6	21.2	20.9	17.8	15.0	10.7	6.0		
		MCDB	6.1	8.9	13.9	19.0	23.9	27.3	28.7	28.4	23.3	19.1	12.7	6.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.0	8.9	11.4	13.1	13.3	13.4	13.9	14.2	12.8	12.2	8.7	6.3		
		MCDBR	10.3	13.1	16.3	17.5	16.9	16.7	17.4	18.2	17.0	15.3	12.1	9.4		
	5% WB	MCWBR	7.5	8.8	9.3	8.8	7.7	7.0	6.4	6.8	7.7	8.4	7.9	7.2		
		MCWBR	9.7	11.6	14.6	15.4	15.2	15.1	15.7	14.5	14.4	11.3	8.9	8.9		
(40) Clear-Sky Solar Irradiance	taub	taub	0.337	0.360	0.395	0.448	0.435	0.433	0.442	0.445	0.426	0.390	0.360	0.336		
		taud	2.364	2.295	2.231	2.090	2.193	2.233	2.205	2.205	2.226	2.316	2.355	2.369		
	Ebn at Noon	Ebn at Noon	747	799	823	808	835	837	823	803	781	754	708	700		
		Edh at Noon	75	98	120	151	141	136	138	133	120	95	76	68		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.16	1.98	3.20	4.61	5.57	6.08	6.07	5.43	3.80	2.55	1.44	0.91		
	RadStd	RadStd	0.16	0.29	0.42	0.43	0.51	0.47	0.45	0.54	0.43	0.26	0.13	0.14		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (46 neighbors)	+0.64	N/A	N/A	N/A	+0.43	+0.46	-114	-167	+98	+56	

Nomenclature: See separate page