

KECSKEMET, Hungary

WMO: 129700

Lat: 46.918N

Lon: 19.749E

Elev: 376

StdP: 14.50

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.0	15.0	5.4	7.3	12.9	10.0	9.3	18.0	26.7	42.3	22.4	39.0	4.0	40	0.503

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.3	92.5	69.3	89.3	68.7	86.2	67.6	72.0	86.1	70.5	84.4	69.0	82.3	7.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	103.2	77.4	66.1	97.4	75.2	64.6	92.3	74.2	35.9	86.2	34.6	84.3	33.3	82.5	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.5	18.2	15.5	DB	3.3	96.6	6.2	3.3	-1.1	99.0	-4.7	101.0	-8.2	102.8	-12.7	105.3	(4)
(5)			WB	2.8	74.4	6.1	2.3	-1.6	76.1	-5.1	77.4	-8.6	78.6	-13.0	80.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.2	31.5	34.8	42.9	53.2	61.7	68.2	71.6	70.7	61.9	52.4	42.7	33.1	(6)
(7)		DBStd	16.03	8.57	9.33	8.05	6.95	6.42	6.17	5.60	5.62	6.55	7.51	7.75	8.61	(7)
(8)		HDD50	2121	574	429	242	46	2	0	0	0	1	64	239	524	(8)
(9)		HDD65	5308	1038	847	684	357	140	36	10	13	136	391	668	988	(9)
(10)		CDD50	2909	0	2	23	141	365	545	670	643	358	140	21	1	(10)
(11)		CDD65	622	0	0	0	2	38	131	215	191	43	2	0	0	(11)
(12)		CDH74	7010	0	0	0	63	499	1455	2378	2103	481	31	0	0	(12)
(13)		CDH80	2640	0	0	0	8	110	527	1002	866	126	1	0	0	(13)
(14)	Wind	WSAvg	6.8	6.8	7.4	8.2	7.8	6.9	6.4	6.7	5.7	6.1	6.1	6.7	6.5	(14)
(15)	Precipitation	PrecAvg	22.0	1.2	1.3	1.1	1.5	2.4	2.7	2.5	2.0	2.0	1.8	1.7	1.7	(15)
(16)		PrecMax	35.6	2.8	3.2	3.6	3.2	6.3	5.4	5.2	4.8	5.7	4.1	4.6	4.0	(16)
(17)		PrecMin	12.9	0.2	0.0	0.2	0.1	0.4	0.7	0.3	0.2	0.5	0.1	0.0	0.1	(17)
(18)		PrecStd	5.3	0.8	0.9	0.8	0.7	1.3	1.3	1.3	1.1	1.4	1.2	0.9	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.0	61.0	69.6	80.6	86.9	93.6	97.1	96.9	88.9	77.8	66.4	55.2	(19)
(20)			MCWB	48.5	49.9	53.3	60.8	65.6	70.0	69.9	69.3	67.1	63.3	57.4	50.4	(20)
(21)		2%	DB	49.8	55.6	64.9	75.1	83.0	89.6	92.4	92.4	83.5	73.5	61.2	50.6	(21)
(22)			MCWB	45.0	47.2	51.5	58.2	64.5	68.9	69.9	68.7	65.2	61.0	54.1	46.8	(22)
(23)		5%	DB	46.4	51.7	60.5	71.2	79.7	86.1	89.2	88.7	79.5	69.7	57.7	47.1	(23)
(24)			MCWB	42.8	45.1	49.8	56.1	63.3	68.0	69.0	68.3	63.7	59.1	52.2	44.0	(24)
(25)		10%	DB	43.1	47.9	56.6	67.5	76.1	82.5	85.7	84.9	75.7	65.3	54.1	44.2	(25)
(26)			MCWB	40.5	43.4	47.5	54.4	61.5	66.3	67.9	67.1	62.4	57.2	50.0	41.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.2	50.5	55.5	62.4	68.3	73.7	74.4	73.4	68.9	64.6	58.0	50.9	(27)
(28)			MCD B	54.0	58.0	65.7	74.6	81.7	87.4	88.4	86.8	84.1	74.9	63.9	54.4	(28)
(29)		2%	WB	45.7	48.1	52.8	59.6	66.4	71.1	72.2	71.4	66.8	62.2	55.2	47.1	(29)
(30)			MCD B	49.1	54.0	61.5	72.2	79.5	84.3	86.5	86.3	80.0	71.3	60.6	49.9	(30)
(31)		5%	WB	43.1	45.9	50.6	57.4	64.7	69.4	70.6	69.9	64.9	60.0	52.7	44.4	(31)
(32)			MCD B	45.7	50.7	59.0	69.0	76.6	82.0	84.5	84.2	75.8	67.7	56.8	46.6	(32)
(33)		10%	WB	40.6	43.7	48.4	55.4	62.7	67.7	69.0	68.3	63.2	57.9	50.3	42.1	(33)
(34)			MCD B	42.9	47.4	55.9	65.4	73.6	79.6	82.2	81.7	73.2	64.5	53.7	43.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.1	14.4	18.1	21.1	21.1	21.2	22.3	22.8	20.4	19.2	14.0	10.5	(35)
(36)			MCDBR	15.5	20.0	24.7	27.6	27.5	26.6	28.2	29.0	26.9	25.0	19.4	14.1	(36)
(37)			MCWBR	11.2	13.1	14.1	13.7	12.2	10.1	10.0	10.2	11.5	13.8	12.8	10.7	(37)
(38)		5% WB	MCD BR	14.9	17.6	21.9	25.1	24.1	23.8	24.7	24.7	23.8	22.7	18.1	13.1	(38)
(39)			MCWBR	11.1	12.2	13.2	13.2	11.6	10.0	10.0	9.9	10.9	13.1	12.5	10.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.334	0.356	0.393	0.447	0.432	0.431	0.445	0.444	0.421	0.386	0.360	0.333	(40)	
(41)		taud	2.348	2.295	2.227	2.090	2.201	2.235	2.200	2.207	2.237	2.315	2.341	2.358	(41)	
(42)		Ebn at Noon	234	253	260	256	265	266	260	254	248	238	221	219	(42)	
(43)		Edh at Noon	24	30	38	48	44	43	44	42	37	30	24	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	343	606	998	1459	1762	1914	1888	1698	1191	779	427	263	(44)	
(45)		RadStd	42	92	139	138	172	141	142	163	136	82	39	38	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.28	N/A	N/A	N/A	N/A	N/A	N/A	-324	N/A	N/A	(46)
(47)	Regional (50 neighbors)	+1.15	N/A	N/A	N/A	+0.90	+0.95	-218	-324	+185	+101	(47)

Nomenclature: See separate page