

KECSKEMET, Hungary

WMO: 129700

Lat: 46.918N

Lon: 19.749E

Elev: 115

StdP: 99.96

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.2	-9.4	-14.8	1.0	-10.6	-12.2	1.3	-7.8	11.9	5.7	10.0	3.9	1.8	40	0.503

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	33.6	20.7	31.8	20.4	30.1	19.8	22.2	30.1	21.4	29.1	20.6	28.0	3.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.8	14.7	25.2	18.9	13.9	24.0	18.1	13.2	23.4	65.7	30.1	62.5	29.1	59.6	28.1	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.1	6.9	DB	-15.9	35.9	3.4	1.9	-18.4	37.2	-20.4	38.3	-22.3	39.4	-24.8	40.7	(4)
(5)			WB	-16.2	23.6	3.4	1.3	-18.7	24.5	-20.6	25.2	-22.5	25.9	-25.0	26.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	-0.3	1.5	6.1	11.8	16.5	20.1	22.0	21.5	16.6	11.4	6.0	0.6	(6)	
	DBStd	8.90	4.76	5.18	4.47	3.86	3.57	3.43	3.11	3.12	3.64	4.17	4.31	4.79	(7)	
	HDD10.0	1178	319	238	134	26	1	0	0	0	1	36	133	291	(8)	
	HDD18.3	2949	577	471	380	198	78	20	6	7	76	217	371	549	(9)	
	CDD10.0	1616	0	1	13	78	203	303	372	357	199	78	12	1	(10)	
	CDD18.3	346	0	0	0	1	21	73	119	106	24	1	0	0	(11)	
	CDH23.3	3894	0	0	0	35	277	808	1321	1168	267	17	0	0	(12)	
	CDH26.7	1467	0	0	0	4	61	293	557	481	70	1	0	0	(13)	
(14) Wind	WSAvg	3.0	3.1	3.3	3.6	3.5	3.1	2.9	3.0	2.6	2.7	2.7	3.0	2.9	(14)	
(15) Precipitation	PrecAvg	558	31	34	29	37	60	68	64	51	52	46	43	44	(15)	
	PrecMax	903	71	82	92	81	161	136	133	123	144	104	116	101	(16)	
	PrecMin	327	5	0	4	3	10	18	7	5	12	2	0	3	(17)	
	PrecStd	135	20	23	20	19	32	34	33	28	35	31	24	25	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	16.1	20.9	27.0	30.5	34.2	36.2	36.1	31.6	25.5	19.1	12.9	(19)	
		MCWB	9.1	9.9	11.8	16.0	18.7	21.1	21.1	20.7	19.5	17.4	14.1	10.2	(20)	
	2%	DB	9.9	13.1	18.3	23.9	28.4	32.0	33.6	33.6	28.6	23.1	16.2	10.3	(21)	
		MCWB	7.2	8.4	10.8	14.6	18.1	20.5	21.0	20.4	18.5	16.1	12.3	8.2	(22)	
	5%	DB	8.0	10.9	15.8	21.8	26.5	30.0	31.8	31.5	26.4	21.0	14.3	8.4	(23)	
		MCWB	6.0	7.3	9.9	13.4	17.4	20.0	20.5	20.2	17.6	15.0	11.2	6.7	(24)	
	10%	DB	6.2	8.8	13.6	19.7	24.5	28.1	29.8	29.4	24.3	18.5	12.3	6.8	(25)	
		MCWB	4.7	6.3	8.6	12.4	16.4	19.1	19.9	19.5	16.9	14.0	10.0	5.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	10.3	13.1	16.9	20.2	23.2	23.6	23.0	20.5	18.1	14.4	10.5	(27)	
		MCDB	12.2	14.5	18.7	23.7	27.6	30.8	31.4	30.4	28.9	23.8	17.7	12.4	(28)	
	2%	WB	7.6	8.9	11.5	15.3	19.1	21.7	22.3	21.9	19.3	16.8	12.9	8.4	(29)	
		MCDB	9.5	12.2	16.4	22.3	26.4	29.0	30.3	30.1	26.6	21.8	15.9	10.0	(30)	
	5%	WB	6.2	7.7	10.3	14.1	18.2	20.8	21.4	21.1	18.3	15.6	11.5	6.9	(31)	
		MCDB	7.6	10.4	15.0	20.6	24.8	27.8	29.2	29.0	24.3	19.9	13.8	8.1	(32)	
	10%	WB	4.8	6.5	9.1	13.0	17.1	19.8	20.6	20.2	17.3	14.4	10.2	5.6	(33)	
		MCDB	6.1	8.6	13.3	18.6	23.1	26.5	27.9	27.6	22.9	18.0	12.1	6.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	8.0	10.1	11.7	11.7	11.8	12.4	12.7	11.3	10.7	7.8	5.9	(35)	
		MCDBR	8.6	11.1	13.7	15.3	15.3	14.8	15.7	16.1	15.0	13.9	10.8	7.8	(36)	
	5% WB	MCWBR	6.2	7.3	7.8	7.6	6.8	5.6	5.6	5.7	6.4	7.6	7.1	6.0	(37)	
		MCWBR	8.3	9.8	12.2	14.0	13.4	13.2	13.7	13.7	13.2	12.6	10.1	7.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.334	0.356	0.393	0.447	0.432	0.431	0.445	0.444	0.421	0.386	0.360	0.333	(40)	
		taud	2.348	2.295	2.227	2.090	2.201	2.235	2.200	2.207	2.237	2.315	2.341	2.358	(41)	
	Ebn at Noon		739	798	820	807	836	837	819	801	782	751	697	691	(42)	
		Edh at Noon	75	96	119	150	139	135	138	132	117	94	75	67	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.08	1.91	3.15	4.60	5.56	6.04	5.95	5.35	3.75	2.46	1.34	0.83	(44)	
	RadStd		0.13	0.29	0.44	0.43	0.54	0.44	0.45	0.52	0.43	0.26	0.12	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.71	N/A	N/A	N/A	N/A	N/A	N/A	-180	N/A	N/A	(46)
(47)	Regional (50 neighbors)	+0.64	N/A	N/A	N/A	+0.50	+0.53	-121	-180	+103	+56	(47)

Nomenclature: See separate page