

SZEGED, Hungary

WMO: 129820

Lat: 46.2561N

Lon: 20.0906E

Elev: 272

StdP: 14.55

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.3	16.2	6.6	7.8	13.4	11.0	9.8	18.9	25.2	39.3	22.3	35.5	4.6	10	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	93.4	70.2	90.4	69.6	87.3	68.6	73.1	86.7	71.4	85.3	70.0	83.6	7.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.9	107.2	78.7	67.1	100.6	76.7	65.5	95.2	75.0	36.8	86.8	35.3	85.3	34.0	83.6	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.9	18.0	15.7	DB	4.9	97.2	7.5	3.2	-0.5	99.5	-4.9	101.4	-9.1	103.2	-14.5	105.5	
			WB	4.2	76.2	7.3	2.9	-1.1	78.2	-5.3	79.9	-9.5	81.5	-14.8	83.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.8	32.1	35.1	43.5	53.6	62.2	68.5	71.9	71.7	62.8	53.4	43.6	33.8	(6)
	DBStd	16.02	8.09	9.26	7.89	6.90	6.48	6.33	5.58	5.83	6.71	7.64	7.98	8.32	(7)
	HDD50	2022	555	419	226	42	1	0	0	0	55	221	503		(8)
	HDD65	5147	1020	838	666	344	131	36	9	10	120	364	642	967	(9)
	CDD50	3040	0	2	25	151	380	556	678	674	384	159	30	1	(10)
	CDD65	689	0	0	0	3	44	142	222	220	54	4	0	0	(11)
	CDH74	8036	0	0	0	71	547	1615	2559	2575	613	56	0	0	(12)
	CDH80	3186	0	0	0	11	118	598	1109	1166	182	2	0	0	(13)
(14) Wind	WSAvg	6.9	7.2	7.7	8.3	8.0	7.0	6.1	6.2	5.7	6.1	6.3	7.2	7.1	(14)
(15) Precipitation	PrecAvg	20.3	1.1	1.1	1.1	1.5	2.1	2.9	2.2	2.0	1.7	1.4	1.6	1.6	(15)
	PrecMax	33.1	3.5	3.1	3.9	3.7	6.2	7.8	6.7	4.8	5.8	4.4	4.2	4.5	(16)
	PrecMin	12.0	0.1	0.0	0.0	0.1	0.2	0.3	0.4	0.1	0.0	0.0	0.0	0.0	(17)
	PrecStd	4.5	0.7	0.8	0.7	0.8	1.3	1.7	1.4	1.2	1.2	1.1	1.0	1.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	62.0	70.8	81.2	87.0	93.9	97.0	98.6	90.4	79.0	68.1	55.5	(19)
		MCWB	49.2	50.3	54.0	62.2	65.7	71.0	70.8	70.6	67.6	63.2	58.4	50.4	(20)
	2%	DB	49.8	56.5	65.8	75.4	83.3	90.2	92.9	94.1	85.0	75.2	62.9	51.2	(21)
		MCWB	45.9	48.5	52.3	58.7	65.0	70.0	70.8	69.6	65.3	61.2	55.3	47.3	(22)
	5%	DB	46.2	51.9	61.4	71.5	80.3	86.7	89.9	90.5	80.9	71.2	59.1	47.4	(23)
		MCWB	43.0	46.2	50.6	57.0	64.0	69.1	70.0	69.1	64.0	59.6	52.9	44.6	(24)
	10%	DB	43.0	48.0	57.2	67.8	76.6	83.2	86.5	86.8	77.0	66.7	55.5	44.6	(25)
		MCWB	40.8	43.7	48.3	55.0	62.3	67.5	69.0	68.1	62.7	57.5	50.9	42.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.6	51.9	56.4	63.3	68.7	74.9	75.4	74.8	69.6	64.9	58.5	51.1	(27)
		MCDB	53.7	59.1	66.3	78.0	81.8	88.6	88.3	89.2	85.6	76.1	65.7	54.8	(28)
	2%	WB	46.0	49.3	53.7	60.3	66.6	72.5	73.0	72.5	67.0	62.5	56.0	47.7	(29)
		MCDB	49.2	55.5	63.4	72.5	79.5	84.8	86.8	87.3	80.1	72.3	61.7	50.8	(30)
	5%	WB	43.3	46.6	51.4	58.2	65.0	70.6	71.4	70.7	65.3	60.4	53.6	45.0	(31)
		MCDB	45.6	51.2	59.8	69.0	77.2	82.5	85.3	85.8	77.2	69.4	58.3	47.0	(32)
	10%	WB	40.9	44.0	49.2	56.2	63.4	68.8	70.0	69.1	63.8	58.3	51.2	42.7	(33)
		MCDB	42.8	47.6	56.6	65.6	74.6	80.3	83.5	83.5	74.4	65.6	55.3	44.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.9	14.6	18.6	21.0	21.3	22.0	23.3	24.1	21.4	19.9	14.4	10.3	(35)
		MCDBR	16.0	21.4	26.0	27.6	26.9	27.2	28.8	30.1	28.0	26.0	19.7	14.4	(36)
		MCWBR	12.1	14.5	15.0	13.8	12.0	10.6	10.5	10.4	11.7	13.6	12.7	11.1	(37)
	5% WB	MCDBR	15.1	19.5	23.4	24.3	23.9	23.8	25.1	25.9	24.1	23.6	18.8	13.5	(38)
		MCWBR	11.9	13.8	14.2	12.8	11.4	10.5	10.3	10.2	10.8	13.0	12.5	10.7	(39)
(40) Clear-Sky Solar Irradiance	taub		0.339	0.363	0.399	0.454	0.438	0.436	0.448	0.450	0.429	0.392	0.362	0.339	(40)
	taud		2.339	2.283	2.216	2.070	2.187	2.228	2.193	2.190	2.217	2.308	2.344	2.354	(41)
	Ebn at Noon		235	252	259	254	264	265	259	253	246	238	223	220	(42)
	Edh at Noon		24	31	39	49	45	43	44	43	38	30	24	22	(43)
(44) All-Sky Solar Radiation	RadAvg		360	626	1020	1468	1777	1941	1926	1730	1209	809	463	280	(44)
	RadStd		43	93	136	138	164	148	147	166	134	85	41	41	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.39	N/A	N/A	+2.05	N/A	N/A	-281	-423	+221	+119	(46)
(47)	Regional (51 neighbors)	+1.19	N/A	N/A	N/A	+0.72	N/A	-200	-302	+184	+99	(47)

Nomenclature: See separate page