

PALIC, Serbia

WMO: 130670

Lat: 46.100N

Lon: 19.767E

Elev: 344

StdP: 14.51

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.1	17.6	7.9	8.3	17.7	11.6	10.1	21.3	18.8	41.2	16.9	37.6	4.2	0	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	92.0	69.3	89.2	68.6	86.4	67.5	72.5	84.5	70.9	83.3	69.6	81.6	6.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.1	108.1	76.1	67.3	101.6	74.8	65.8	96.3	73.4	36.3	84.6	34.9	83.6	33.8	81.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
Min	Max			Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 16.9	14.5	12.7		7.0	96.1	7.7	2.7	1.5	98.1	-3.0	99.7	-7.3	101.2	-12.9	103.2	
(5)				6.5	74.9	7.6	1.8	1.1	76.2	-3.4	77.3	-7.6	78.3	-13.1	79.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.5	32.5	35.9	44.3	54.7	63.0	69.6	72.8	72.7	63.5	54.1	44.0	34.3		
	DBStd	16.10	7.74	8.90	8.00	6.95	6.51	6.41	5.73	5.76	6.58	7.56	7.70	7.89		
	HDD50	1927	542	398	207	36	1	0	0	0	0	47	209	487		
	HDD65	4969	1007	816	642	314	115	28	8	8	106	343	630	952		
	CDD50	3221	0	2	31	175	405	588	708	703	406	173	29	1		
	CDD65	786	0	0	0	4	54	166	250	246	61	5	0	0		
	CDH74	7584	0	0	0	48	494	1592	2530	2391	494	35	0	0		
	CDH80	2761	0	0	0	5	97	543	1010	980	126	0	0	0		
(14) Wind	WSAvg	5.8	6.0	6.3	6.8	6.7	6.1	5.5	5.5	5.0	5.2	5.4	5.9	5.8		
(15) Precipitation	PrecAvg	22.4	1.3	1.4	1.2	1.6	2.4	2.8	2.3	2.0	2.2	1.9	1.7	1.8		
	PrecMax	34.8	2.5	3.6	4.4	4.0	7.2	8.1	5.0	5.2	5.4	4.5	4.8	3.4		
	PrecMin	9.5	0.1	0.0	0.1	0.1	0.2	0.4	0.4	0.2	0.6	0.1	0.0	0.0		
	PrecStd	5.5	0.7	0.9	0.9	0.9	1.5	1.8	1.3	1.1	1.2	1.3	1.0	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.3	60.5	69.0	79.6	86.3	92.9	95.0	96.8	88.6	77.7	66.6	54.4		
		MCWB	47.5	49.0	52.9	61.7	64.8	70.4	70.0	69.8	66.6	61.8	55.7	49.7		
	2%	DB	49.1	55.4	64.5	74.1	82.7	89.6	91.6	92.4	83.5	74.3	62.0	50.0		
		MCWB	45.0	46.9	51.2	57.5	63.9	69.0	69.9	68.9	64.2	60.4	54.2	46.9		
	5%	DB	45.7	51.2	60.6	70.6	79.7	86.3	88.9	89.0	79.7	70.7	58.6	47.0		
		MCWB	42.7	45.6	49.6	55.6	62.9	67.9	69.0	68.2	63.1	58.9	52.6	44.4		
	10%	DB	42.9	48.0	56.8	67.3	76.3	83.1	85.9	85.7	75.9	66.8	55.3	44.4		
		MCWB	40.8	43.7	47.7	54.2	61.2	66.3	67.8	67.2	61.8	57.2	50.7	42.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.1	50.4	54.9	62.7	67.9	74.1	74.5	74.0	69.2	64.6	58.1	50.3		
		MCDB	52.1	56.5	63.2	76.1	79.2	84.5	84.3	86.7	80.6	72.5	63.6	53.3		
	2%	WB	45.6	48.3	52.7	59.4	66.1	71.7	72.4	72.0	67.0	62.1	55.5	47.2		
		MCDB	48.1	53.8	61.0	70.0	78.2	82.8	84.5	84.9	76.8	70.4	60.4	49.5		
	5%	WB	43.2	46.3	50.9	57.4	64.5	70.0	71.0	70.2	65.3	60.3	53.3	44.8		
		MCDB	45.2	50.4	58.8	67.2	75.4	81.8	83.8	82.5	74.3	67.9	57.8	46.6		
	10%	WB	40.9	44.3	48.9	55.5	62.9	68.3	69.6	68.9	63.7	58.5	51.0	42.7		
		MCDB	42.7	47.7	55.7	64.5	73.1	79.3	81.8	80.9	72.4	65.2	54.7	44.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	12.9	15.7	17.5	18.1	18.4	19.3	20.3	17.7	17.1	12.5	9.0		
		MCDBR	13.4	18.6	21.4	23.2	23.7	23.1	23.9	25.6	23.5	22.4	17.7	12.6		
	5% WB	MCWBR	9.6	11.4	10.7	9.7	8.4	7.2	7.3	7.7	8.2	10.1	10.0	9.5		
		MCWBR	12.5	16.7	19.2	20.1	20.9	20.3	21.4	21.9	19.6	19.9	16.0	11.8		
(40) Clear-Sky Solar Irradiance	taub		0.339	0.363	0.398	0.453	0.438	0.435	0.445	0.448	0.428	0.392	0.361	0.338		
	taud		2.346	2.285	2.219	2.074	2.185	2.228	2.196	2.193	2.216	2.307	2.346	2.358		
	Ebn at Noon		236	253	260	255	264	265	260	254	247	239	224	221		
	Edh at Noon		24	31	38	49	45	43	44	43	38	30	24	22		
(44) All-Sky Solar Radiation	RadAvg		367	629	1021	1466	1774	1938	1933	1731	1209	813	464	288		
	RadStd		48	92	134	137	162	150	145	168	136	84	41	43		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.28	N/A	N/A	N/A	N/A	+1.22	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		+1.21	N/A	N/A	N/A	+0.79	+0.88	-207	-313	+194	+104

Nomenclature: See separate page