

PALIC, Serbia

WMO: 130670

Lat: 46.100N

Lon: 19.767E

Elev: 105

StdP: 100.07

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.5	-8.0	-13.4	1.2	-8.0	-11.3	1.4	-6.0	8.4	5.1	7.6	3.1	1.9	0	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	33.3	20.7	31.8	20.3	30.2	19.7	22.5	29.2	21.6	28.5	20.9	27.5	2.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.4	24.5	19.6	14.5	23.8	18.8	13.8	23.0	66.4	29.2	63.4	28.7	60.6	27.6	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
7.6	6.5	5.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-13.9	35.6	4.3	1.5	-17.0	36.7	-19.5	37.6	-21.9	38.5	-25.0	39.6
			-14.2	23.8	4.2	1.0	-17.2	24.6	-19.6	25.2	-22.0	25.7	-25.1	26.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	0.3	2.1	6.8	12.6	17.2	20.9	22.7	22.6	17.5	12.3	6.7	1.3
	DBStd	8.94	4.30	4.94	4.44	3.86	3.61	3.56	3.18	3.20	3.65	4.20	4.28	4.38
	HDD10.0	1071	301	221	115	20	1	0	0	0	26	116	271	
	HDD18.3	2761	559	453	357	174	64	16	4	59	191	350	529	
	CDD10.0	1789	0	1	17	97	225	327	393	391	226	96	16	1
	CDD18.3	437	0	0	0	2	30	92	139	137	34	3	0	0
	CDH23.3	4213	0	0	0	27	274	884	1406	1328	274	19	0	0
	CDH26.7	1534	0	0	0	3	54	302	561	544	70	0	0	0
(14) Wind	WSAvg	2.6	2.7	2.8	3.1	3.0	2.7	2.5	2.5	2.2	2.3	2.4	2.6	2.6
(15) Precipitation	PrecAvg	569	32	35	31	40	61	72	59	50	56	49	44	46
	PrecMax	883	64	91	111	102	182	207	126	132	138	114	123	87
	PrecMin	241	3	1	2	3	6	9	11	4	14	2	1	1
	PrecStd	140	19	22	23	24	38	46	32	28	31	32	25	26
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	15.8	20.5	26.5	30.1	33.8	35.0	36.0	31.4	25.4	19.2	12.5
		MCWB	8.6	9.5	11.6	16.5	18.2	21.3	21.1	21.0	19.2	16.6	13.2	9.9
	2%	DB	9.5	13.0	18.0	23.4	28.2	32.0	33.1	33.6	28.6	23.5	16.7	10.0
		MCWB	7.2	8.3	10.6	14.1	17.7	20.5	21.0	20.5	17.9	15.8	12.3	8.3
	5%	DB	7.6	10.7	15.9	21.5	26.5	30.2	31.6	31.7	26.5	21.5	14.8	8.4
		MCWB	5.9	7.5	9.8	13.1	17.2	19.9	20.6	20.1	17.3	14.9	11.5	6.9
	10%	DB	6.1	8.9	13.8	19.6	24.6	28.4	30.0	29.8	24.4	19.3	12.9	6.9
		MCWB	4.9	6.5	8.7	12.3	16.2	19.0	19.9	19.6	16.5	14.0	10.4	5.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	10.2	12.7	17.1	20.0	23.4	23.6	23.3	20.7	18.1	14.5	10.2
		MCDB	11.2	13.6	17.3	24.5	26.2	29.2	29.0	30.4	27.0	22.5	17.5	11.8
	2%	WB	7.5	9.1	11.5	15.2	19.0	22.0	22.5	22.2	19.4	16.7	13.1	8.4
		MCDB	9.0	12.1	16.1	21.1	25.7	28.2	29.2	29.4	24.9	21.3	15.8	9.7
	5%	WB	6.2	7.9	10.5	14.1	18.1	21.1	21.6	21.2	18.5	15.7	11.8	7.1
		MCDB	7.3	10.2	14.9	19.5	24.1	27.7	28.8	28.1	23.5	19.9	14.3	8.1
	10%	WB	4.9	6.8	9.4	13.1	17.2	20.2	20.9	20.5	17.6	14.7	10.5	5.9
		MCDB	5.9	8.7	13.2	18.1	22.8	26.3	27.7	27.2	22.5	18.4	12.6	6.8
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	7.2	8.7	9.7	10.1	10.2	10.7	11.3	9.9	9.5	7.0	5.0
		MCDBR	7.4	10.3	11.9	12.9	13.1	12.8	13.3	14.2	13.1	12.4	9.8	7.0
	5% WB	MCWBR	5.4	6.3	5.9	5.4	4.7	4.0	4.1	4.3	4.5	5.6	5.6	5.3
		MCWBR	7.0	9.3	10.7	11.1	11.6	11.3	11.9	12.2	10.9	11.1	8.9	6.6
(40) Clear-Sky Solar Irradiance	taub		0.339	0.363	0.398	0.453	0.438	0.435	0.445	0.448	0.428	0.392	0.361	0.338
		taud	2.346	2.285	2.219	2.074	2.185	2.228	2.196	2.193	2.216	2.307	2.346	2.358
	Ebn at Noon		743	797	820	804	832	835	820	800	779	752	707	698
		Edh at Noon	77	99	121	153	142	137	139	135	121	96	77	69
(44) All-Sky Solar Radiation	RadAvg		1.16	1.98	3.22	4.62	5.59	6.11	6.09	5.46	3.81	2.56	1.46	0.91
	RadStd		0.15	0.29	0.42	0.43	0.51	0.47	0.46	0.53	0.43	0.27	0.13	0.13

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (49 neighbors)	+0.71	N/A	N/A	N/A	N/A	+0.68	N/A	N/A	N/A	N/A
		+0.67	N/A	N/A	N/A	+0.44	+0.49	-115	-174	+108	+58

Nomenclature: See separate page