

RIJEKA OMISALJ, Croatia

WMO: 131160

Lat: 45.217N

Lon: 14.570E

Elev: 85

StdP: 100.31

Time Zone: 1.00 (EUC)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.8	(c) -1.2	(d) -18.1	(e) 0.8	(f) -1.8	(g) -15.8	(h) 1.0	(i) 0.4	(j) 14.2	(k) -0.6	(l) 12.6	(m) -0.1	(n) 5.2	(o) 50	(p) 0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	32.2	20.6	31.0	20.2	29.9	19.8	22.7	28.4	22.0	27.8	21.2	27.1	2.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.9	24.9	20.1	14.9	24.4	19.1	14.0	24.1	67.1	28.2	64.5	28.1	62.0	26.7	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 12.1	(b) 9.2	(c) 7.3	(e) -4.4	(f) 34.0	(g) 2.5	(h) 0.9	(i) -6.1	(j) 34.6	(k) -7.6	(l) 35.2	(m) -9.0	(n) 35.7	(o) -10.8	(p) 36.3		
(a) 12.1	(b) 9.2	(c) 7.3	(e) -7.0	(f) 24.0	(g) 2.3	(h) 1.3	(i) -8.7	(j) 24.9	(k) -10.1	(l) 25.6	(m) -11.4	(n) 26.3	(o) -13.1	(p) 27.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.5	5.6	5.8	9.5	12.9	17.0	20.9	24.4	24.2	19.9	15.7	10.5	7.4
	DBStd	7.23	3.23	3.72	3.46	2.78	3.20	3.12	2.41	2.90	2.74	2.52	3.09	2.99
	HDD10.0	436	137	123	50	6	1	0	0	0	0	1	31	89
	HDD18.3	1933	393	352	274	164	63	11	0	1	15	87	235	338
	CDD10.0	2095	1	4	34	94	218	326	448	439	297	178	46	9
	CDD18.3	551	0	0	0	1	23	87	189	182	62	6	0	0
	CDH23.3	4252	0	0	0	8	96	576	1656	1587	318	13	0	0
	CDH26.7	1318	0	0	0	0	6	131	559	571	51	0	0	0
Wind	WSAvg	2.6	2.7	2.9	3.0	2.6	2.2	2.0	2.1	2.4	2.1	2.7	3.2	3.3
Precipitation	PrecAvg	1308	87	71	75	96	81	82	53	70	166	207	179	141
	PrecMax	1526	215	178	182	161	197	152	100	178	330	405	343	233
	PrecMin	840	4	4	9	30	9	30	12	15	60	44	84	33
	PrecStd	180	60	46	51	39	53	37	31	49	74	124	65	60
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	17.2	21.2	24.2	27.2	31.9	33.9	34.9	30.0	25.0	18.8	16.2
		MCWB	9.4	9.0	11.1	15.0	18.7	20.9	20.6	22.3	19.6	16.5	14.0	12.6
	2%	DB	12.1	14.0	18.8	21.1	25.8	29.8	32.2	32.9	28.0	23.1	17.2	14.2
		MCWB	9.1	8.0	10.1	13.4	17.2	20.0	20.3	21.1	18.7	15.7	13.1	11.6
	5%	DB	11.1	12.1	16.1	19.5	24.1	28.1	31.0	31.2	26.8	21.3	16.1	13.2
		MCWB	8.4	7.7	9.1	12.3	16.2	19.5	20.2	20.3	18.4	14.8	12.7	10.5
	10%	DB	10.1	10.9	14.8	18.0	22.8	26.8	29.9	30.0	25.1	20.1	15.1	12.1
		MCWB	7.7	7.3	9.0	11.0	15.4	18.6	19.9	19.9	17.5	14.6	11.7	9.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.6	11.4	12.7	16.2	20.6	22.7	23.6	23.7	22.3	18.7	16.4	13.4
		MCDB	12.7	13.1	16.9	21.3	25.3	29.5	28.0	30.3	25.0	21.2	17.8	15.3
	2%	WB	10.5	10.2	11.6	14.6	18.9	21.6	22.7	22.7	21.1	17.7	15.0	12.6
		MCDB	11.4	11.9	15.5	19.8	23.3	27.3	28.2	28.7	24.7	20.2	16.2	14.3
	5%	WB	9.6	9.2	11.0	13.4	17.5	20.6	21.9	22.0	20.0	16.9	13.7	11.6
		MCDB	10.3	11.2	14.3	17.4	21.7	25.9	27.9	28.2	23.9	19.3	15.4	13.1
	10%	WB	8.6	8.0	10.0	12.5	16.4	19.6	21.1	21.2	19.2	16.2	12.8	10.3
		MCDB	9.5	9.9	13.4	16.2	20.9	24.7	27.2	27.6	23.2	18.8	14.5	11.5
Mean Daily Temperature Range	5% DB	MDBR	5.8	5.9	6.9	7.3	7.5	8.2	9.1	9.0	8.4	7.5	6.1	5.7
		MCDBR	6.8	7.6	9.6	9.9	9.4	9.7	10.3	10.6	10.4	9.1	7.2	6.6
		MCWBR	5.1	4.5	4.8	4.6	4.4	4.2	4.2	4.2	4.8	4.6	4.6	4.8
	5% WB	MCDBR	4.3	6.0	7.6	8.4	8.3	9.0	9.7	9.5	9.1	7.4	5.3	4.7
		MCWBR	4.3	4.4	4.8	4.5	4.5	4.4	4.8	4.7	5.0	4.9	4.4	4.3
Clear-Sky Solar Irradiance	taub	0.349	0.377	0.423	0.469	0.464	0.468	0.460	0.454	0.442	0.418	0.380	0.347	
	taud	2.362	2.270	2.165	2.067	2.135	2.182	2.208	2.236	2.229	2.262	2.309	2.382	
	Ebn at Noon	744	787	798	792	811	808	810	798	771	730	693	704	
	Edh at Noon	78	102	130	155	150	144	138	130	121	102	82	70	
All-Sky Solar Radiation	RadAvg	1.27	2.06	3.27	4.46	5.58	6.39	6.49	5.62	3.88	2.46	1.38	1.10	
	RadStd	0.19	0.37	0.47	0.53	0.55	0.40	0.38	0.57	0.45	0.27	0.17	0.16	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	+0.43	N/A	N/A	N/A	N/A	+0.40	N/A	N/A	+89	+60

Nomenclature: See separate page