

SOMBOR, SerbiaWMO: **131600**Lat: **45.767N**Lon: **19.150E**Elev: **292**StdP: **14.54**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.4	17.7	7.2	8.0	16.6	12.0	10.2	20.9	18.5	36.0	16.7	35.1	3.6	0	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	92.9	69.0	90.0	68.0	87.1	67.0	71.9	84.8	70.6	83.4	69.3	81.8	5.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.6	106.3	74.8	66.9	100.1	73.8	65.4	94.8	72.9	35.7	84.2	34.6	83.6	33.5	81.8	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 16.9	14.3	12.0		3.1	96.9	9.6	3.3	-3.8	99.3	-9.4	101.3	-14.8	103.1	-21.8	105.5	
(5)			DB	2.7	74.3	9.7	1.9	-4.3	75.6	-9.9	76.7	-15.4	77.8	-22.5	79.2	(p)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.6	33.2	36.3	44.6	54.4	62.9	69.1	72.6	72.2	63.3	53.8	44.6	34.9	(6)
	DBStd	15.79	8.35	9.46	8.15	6.83	6.62	6.21	5.39	5.62	6.33	7.66	7.75	8.10	(7)
	HDD50	1866	520	388	204	37	2	0	0	0	50	196	469		(8)
	HDD65	4910	985	805	633	321	120	29	7	9	106	351	611	933	(9)
	CDD50	3174	1	3	35	169	400	574	700	688	400	168	35	1	(10)
	CDD65	745	0	0	0	3	53	154	242	232	56	5	0	0	(11)
	CDH74	8025	0	0	1	72	585	1634	2644	2444	578	67	0	0	(12)
	CDH80	3102	0	0	0	10	144	589	1135	1056	165	3	0	0	(13)
	WSAvg	5.1	5.2	5.7	6.3	6.0	5.3	4.7	4.6	4.1	4.2	4.5	5.0	5.3	(14)
	PrecAvg	24.9	1.4	1.5	1.3	1.7	2.6	2.9	2.7	2.2	2.5	2.2	2.0	1.9	(15)
(16) Precipitation	PrecMax	38.5	3.0	3.5	3.9	4.2	8.7	8.2	6.3	5.7	5.6	5.2	5.1	4.1	(16)
	PrecMin	11.4	0.2	0.1	0.1	0.0	0.7	0.5	0.8	0.2	0.6	0.2	0.1	0.0	(17)
	PrecStd	5.6	0.8	0.9	0.9	0.9	1.7	1.7	1.3	1.2	1.5	1.4	1.1	1.1	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.7	63.6	71.5	81.3	88.2	93.3	96.4	97.6	89.1	79.7	68.8	56.6	(19)
		MCWB	49.5	49.7	53.7	60.6	64.7	70.5	70.5	70.0	65.7	61.7	56.3	49.8	(20)
	2%	DB	51.3	58.0	66.8	75.2	84.0	90.1	92.7	93.3	84.7	75.6	63.9	51.9	(21)
		MCWB	46.0	47.6	51.7	56.8	63.6	69.0	69.1	68.7	64.0	59.8	54.6	47.7	(22)
	5%	DB	47.3	53.3	62.4	71.6	80.6	86.8	89.7	89.7	80.8	72.0	59.9	48.2	(23)
		MCWB	43.5	45.8	49.8	55.0	62.1	67.9	68.6	67.3	62.6	58.3	53.1	45.0	(24)
	10%	DB	44.0	48.9	58.0	68.1	76.8	83.4	86.5	86.2	76.7	67.7	56.2	45.1	(25)
		MCWB	41.5	43.9	47.9	53.8	60.6	66.2	67.1	66.5	61.1	56.9	51.2	42.7	(26)
	0.4%	WB	50.0	51.6	55.0	61.7	67.4	73.7	73.4	73.4	68.1	64.2	58.5	51.0	(27)
		MCDB	54.6	58.7	66.9	76.7	80.1	86.0	86.6	86.5	80.2	74.6	64.9	55.1	(28)
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	46.7	48.8	53.0	59.0	65.7	71.4	71.9	71.5	66.4	61.9	55.9	47.9	(29)
		MCDB	50.5	55.8	63.9	70.4	78.3	83.7	84.6	85.3	78.2	71.5	61.5	51.7	(30)
	5%	WB	43.9	46.7	51.0	57.0	64.1	69.8	70.6	70.0	64.8	60.0	53.7	45.4	(31)
		MCDB	46.6	51.8	60.0	67.5	75.9	81.8	83.5	83.3	75.0	68.5	58.9	47.8	(32)
	10%	WB	41.7	44.6	49.1	55.2	62.6	68.2	69.3	68.5	63.3	57.9	51.5	43.0	(33)
		MCDB	44.0	48.6	56.8	65.0	73.0	80.0	81.9	81.0	72.6	65.6	56.0	44.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	14.0	17.8	19.6	20.0	20.4	21.7	22.8	20.4	19.3	14.4	9.9	(35)
		MCDBR	16.8	22.4	25.5	27.2	26.7	26.4	28.0	29.2	27.9	26.0	21.0	15.2	(36)
		MCWBR	11.4	13.0	12.6	11.3	9.6	8.4	8.1	8.6	9.4	11.7	11.9	10.8	(37)
	5% WB	MCDBR	15.6	19.0	22.2	23.0	23.0	23.0	24.0	24.9	22.8	22.8	18.9	14.2	(38)
		MCWBR	11.2	12.0	11.8	10.4	9.2	8.5	8.0	8.7	8.7	11.3	11.5	10.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.340	0.364	0.398	0.453	0.440	0.437	0.443	0.447	0.429	0.394	0.361	0.340	(40)
	taud		2.361	2.289	2.229	2.081	2.183	2.227	2.203	2.198	2.218	2.310	2.357	2.366	(41)
	Ebn at Noon		237	253	261	255	264	265	261	254	247	239	226	223	(42)
	Edh at Noon		24	31	38	49	45	43	44	43	38	30	24	22	(43)
(44) All-Sky Solar Radiation	RadAvg		378	637	1032	1464	1778	1945	1954	1744	1215	824	473	301	(44)
	RadStd		56	92	131	136	156	155	145	173	137	85	43	44	(45)