

NOVI SAD RIMSKI SANCEVI, Serbia

WMO: 131680

Lat: 45.333N

Lon: 19.850E

Elev: 87

StdP: 100.28

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.1	-8.2	-13.2	1.2	-10.3	-10.5	1.5	-7.6	9.7	1.0	8.5	1.5	1.9	290	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	33.8	21.9	32.1	21.7	30.4	21.1	23.5	30.8	22.5	30.0	21.7	28.9	2.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	16.0	27.2	20.1	15.0	25.8	19.3	14.2	24.9	70.3	30.8	66.5	30.0	63.7	29.1	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
8.5	7.4	6.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-15.3	36.1	4.9	1.9	-18.8	37.5	-21.7	38.6	-24.5	39.7	-28.1	41.1		
			-15.6	24.8	4.8	1.2	-19.0	25.6	-21.9	26.3	-24.6	26.9	-28.1	27.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.2	0.8	2.6	7.2	12.7	17.3	20.7	22.4	22.5	17.7	12.5	7.2	1.9	(6)
(7)		DBStd	8.83	4.96	5.51	4.82	4.02	3.72	3.61	3.14	3.24	3.75	4.44	4.70	4.84	(7)
(8)		HDD10.0	1019	287	211	111	20	1	0	0	0	26	109	254	(8)	
(9)		HDD18.3	2678	544	442	344	171	65	18	4	5	57	185	333	510	(9)
(10)		CDD10.0	1809	1	3	25	102	226	320	384	387	231	104	26	2	(10)
(11)		CDD18.3	428	0	0	0	3	32	88	131	133	37	4	0	0	(11)
(12)		CDH23.3	4362	0	0	1	49	298	884	1369	1367	351	43	0	0	(12)
(13)		CDH26.7	1650	0	0	0	8	61	314	570	593	103	2	0	0	(13)
(14)	Wind	WSAvg	2.6	2.7	2.9	3.1	3.0	2.5	2.2	2.2	2.0	2.2	2.5	2.8	2.7	(14)
(15)	Precipitation	PrecAvg	645	37	35	38	45	69	84	69	55	57	58	51	47	(15)
(16)		PrecMax	989	70	66	80	138	194	209	194	141	159	139	131	128	(16)
(17)		PrecMin	285	5	1	4	1	19	27	7	4	10	1	1	1	(17)
(18)		PrecStd	167	19	19	21	30	40	43	44	40	34	38	29	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.6	17.7	22.2	27.8	30.5	34.0	35.9	36.7	32.6	26.6	21.1	15.5	(19)
(20)		MCWB	10.4	11.0	13.2	17.2	19.2	22.1	22.8	22.2	20.7	18.0	14.9	11.5	(20)	
(21)		2%	DB	11.6	14.9	19.8	24.4	28.3	32.0	33.6	34.1	29.5	24.5	18.5	12.8	(21)
(22)		MCWB	8.7	9.8	12.1	15.2	18.8	22.0	22.4	21.6	19.5	17.2	13.6	9.8	(22)	
(23)		5%	DB	9.2	12.5	17.5	22.1	26.6	30.2	31.8	32.2	27.2	22.2	16.3	10.4	(23)
(24)		MCWB	7.1	8.7	11.1	14.0	18.2	21.5	22.0	21.4	18.3	16.0	12.3	8.2	(24)	
(25)		10%	DB	7.3	10.3	15.0	20.1	24.8	28.4	30.0	30.1	25.0	20.1	14.1	8.1	(25)
(26)		MCWB	5.9	7.4	9.8	13.1	17.3	20.6	21.3	20.8	17.8	15.0	11.2	6.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	11.7	14.0	17.6	20.6	24.5	24.7	24.6	21.5	18.9	15.4	11.7	(27)
(28)		MDCB	14.0	16.1	20.3	26.2	27.3	31.0	31.9	31.8	30.0	24.9	20.1	14.6	(28)	
(29)		2%	WB	8.9	10.2	12.5	16.0	19.6	22.9	23.6	23.2	20.2	17.6	13.9	9.9	(29)
(30)		MDCB	11.4	14.3	18.5	23.2	26.5	29.7	31.0	31.0	27.4	23.5	17.9	12.2	(30)	
(31)		5%	WB	7.3	8.9	11.4	14.8	18.8	21.9	22.6	22.2	19.2	16.5	12.6	8.4	(31)
(32)		MDCB	9.0	12.1	16.7	20.7	25.3	28.7	30.0	29.9	25.8	21.4	15.8	10.2	(32)	
(33)		10%	WB	6.0	7.5	10.2	13.7	17.8	21.0	21.8	21.3	18.2	15.3	11.3	6.7	(33)
(34)		MDCB	7.3	9.9	14.6	19.0	23.7	27.4	28.8	28.5	23.7	19.5	14.0	8.1	(34)	
(35)	Mean Daily Temperature Range	MDBR	5.6	7.4	9.4	10.3	10.4	10.7	11.6	12.0	10.6	9.9	7.4	5.4	(35)	
(36)		5% DB	MCDBR	9.0	11.5	13.3	14.0	13.3	13.6	14.6	15.4	14.2	13.2	10.9	8.9	(36)
(37)		MCWBR	6.5	7.4	7.2	6.5	5.5	5.5	5.6	5.4	5.6	6.7	6.5	6.5	(37)	
(38)		5% WB	MCDBR	8.7	10.7	12.2	12.4	12.3	12.5	13.3	13.4	12.8	12.5	10.1	8.5	(38)
(39)		MCWBR	6.3	7.1	6.7	6.0	5.5	5.4	5.5	5.3	5.4	6.6	6.2	6.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.345	0.370	0.402	0.459	0.445	0.441	0.447	0.452	0.434	0.398	0.363	0.343	(40)	
(41)		taud	2.346	2.269	2.218	2.069	2.172	2.219	2.195	2.183	2.203	2.299	2.355	2.357	(41)	
(42)		Ebn at Noon	745	794	819	801	828	832	821	799	777	752	716	704	(42)	
(43)		Edh at Noon	79	102	123	155	144	138	140	137	123	98	78	71	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.21	2.03	3.29	4.59	5.59	6.16	6.21	5.53	3.85	2.64	1.55	0.99	(44)	
(45)		RadStd	0.17	0.28	0.41	0.44	0.49	0.52	0.47	0.54	0.43	0.28	0.14	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.88	N/A	N/A	+1.07	+0.60	+0.70	N/A	N/A	N/A	N/A	(46)
(47)	Regional (47 neighbors)	+0.68	N/A	N/A	N/A	+0.38	N/A	-117	-184	+110	+58	(47)

Nomenclature: See separate page