

KIKINDA, Serbia

WMO: 131740

Lat: 45.850N

Lon: 20.467E

Elev: 82

StdP: 100.34

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.9	-8.2	-13.4	1.2	-9.9	-11.0	1.5	-7.2	10.3	1.0	9.1	2.7	2.5	0	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	33.9	21.3	32.3	21.0	30.6	20.4	22.7	30.4	21.8	29.7	21.1	28.6	3.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	15.1	26.1	19.4	14.3	24.9	18.7	13.6	23.9	67.1	30.5	64.1	29.7	61.4	28.6	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.3	6.3	-14.4	36.0	4.5	1.8	-17.6	37.3	-20.3	38.4	-22.8	39.4	-26.1	40.8		
(5)			-14.8	24.2	4.4	1.6	-17.9	25.4	-20.5	26.3	-22.9	27.1	-26.1	28.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.1	0.4	2.3	6.9	12.7	17.2	20.9	22.7	22.7	17.8	12.3	7.1	1.6		
	DBStd	8.97	4.64	5.35	4.65	3.93	3.74	3.65	3.18	3.29	3.74	4.35	4.47	4.65		
	HDD10.0	1052	298	218	117	19	1	0	0	0	0	27	110	262		
	HDD18.3	2726	556	449	355	172	67	17	4	4	55	189	338	519		
	CDD10.0	1812	0	2	21	100	224	326	392	393	233	99	22	1		
	CDD18.3	445	0	0	0	3	32	93	138	138	38	3	0	0		
	CDH23.3	4554	0	0	1	39	307	951	1455	1427	343	32	0	0		
	CDH26.7	1744	0	0	0	5	62	348	611	619	98	1	0	0		
(14) Wind	WSAvg	3.0	3.2	3.3	3.5	3.5	3.1	2.7	2.6	2.5	2.7	2.8	3.2	3.0		
(15) Precipitation	PrecAvg	569	33	31	33	41	60	71	62	49	53	48	43	45		
	PrecMax	898	57	66	116	108	181	185	169	135	137	114	109	101		
	PrecMin	245	5	2	1	2	8	15	14	5	6	2	0	1		
	PrecStd	146	17	19	24	28	37	42	35	29	28	31	24	28		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	16.9	21.5	27.2	30.6	34.2	35.6	36.6	32.3	26.2	20.2	13.3		
		MCWB	9.7	10.7	12.3	16.3	19.0	21.5	21.6	21.3	19.9	17.5	14.4	10.4		
	2%	DB	10.0	13.9	19.0	24.0	28.4	32.4	33.6	34.2	29.2	24.1	17.5	11.2		
		MCWB	7.9	9.4	11.3	14.6	18.3	21.2	21.6	21.0	18.6	16.2	13.1	9.0		
	5%	DB	8.2	11.6	16.6	21.9	26.8	30.5	31.9	32.3	27.1	22.0	15.5	9.3		
		MCWB	6.5	8.2	10.4	13.7	17.8	20.7	21.3	20.7	17.9	15.5	11.9	7.5		
	10%	DB	6.7	9.5	14.3	20.0	24.9	28.7	30.2	30.2	25.0	19.7	13.6	7.6		
		MCWB	5.4	6.9	9.2	12.7	17.0	19.9	20.4	20.3	17.2	14.4	10.7	6.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	11.1	13.7	16.8	20.2	23.6	23.7	24.0	20.9	18.5	15.0	10.8		
		MCDB	12.4	15.5	19.8	25.6	27.9	31.2	31.5	31.3	30.2	24.5	19.2	12.5		
	2%	WB	8.1	9.8	12.1	15.4	19.2	22.3	22.6	22.5	19.5	17.0	13.4	9.1		
		MCDB	9.7	13.3	17.6	22.4	26.6	29.4	30.5	30.5	27.0	22.4	16.8	11.0		
	5%	WB	6.7	8.5	10.9	14.4	18.4	21.3	21.9	21.5	18.6	15.9	12.2	7.7		
		MCDB	7.9	11.2	15.9	20.5	25.2	28.4	29.8	29.6	25.2	20.7	15.0	9.1		
	10%	WB	5.5	7.1	9.7	13.4	17.5	20.5	21.1	20.8	17.7	14.8	11.0	6.4		
		MCDB	6.6	9.3	14.0	18.8	23.7	27.4	28.6	28.3	23.5	19.1	13.5	7.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	7.2	9.3	10.3	10.6	10.9	11.6	12.0	10.6	9.8	7.3	5.0		
		MCDBR	7.2	10.9	12.8	13.5	13.4	13.7	14.1	14.9	13.9	13.0	9.9	7.2		
	5% WB	MCWBR	5.5	7.0	6.8	6.1	5.5	5.0	4.8	4.9	5.4	6.4	6.0	5.4		
		MCWBR	7.0	9.9	11.5	11.9	12.1	12.2	12.7	12.9	12.2	11.7	9.3	6.8		
(40) Clear-Sky Solar Irradiance	taub	taub	0.342	0.367	0.401	0.457	0.442	0.437	0.448	0.453	0.432	0.394	0.362	0.341		
		taud	2.343	2.278	2.215	2.067	2.179	2.226	2.192	2.182	2.209	2.306	2.349	2.357		
	Ebn at Noon	Ebn at Noon	742	794	817	801	830	834	818	797	776	752	709	698		
		Edh at Noon	78	100	122	155	143	137	140	137	122	96	77	70		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.16	2.00	3.27	4.63	5.62	6.18	6.15	5.50	3.83	2.60	1.53	0.92		
	RadStd	RadStd	0.13	0.28	0.42	0.44	0.51	0.50	0.47	0.51	0.42	0.27	0.13	0.14		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.62	N/A	N/A	N/A	+0.40	N/A	N/A	N/A	N/A	N/A
(47) Regional (48 neighbors)		+0.70	N/A	N/A	N/A	+0.39	N/A	-115	-179	+114	+60

Nomenclature: See separate page