

LOZNICA, Serbia

WMO: 132620

Lat: 44.550N

Lon: 19.233E

Elev: 122

StdP: 99.87

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.8	(c) -6.8	(d) -12.1	(e) 1.3	(f) -9.3	(g) -9.2	(h) 1.7	(i) -6.0	(j) 5.4	(k) 7.3	(l) 4.4	(m) 5.8	(n) 0.5	(o) 90	(p) 0.397

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	34.0	21.9	32.2	21.6	30.5	21.1	23.4	30.8	22.6	29.8	21.7	28.8	1.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	16.0	27.1	20.2	15.1	26.2	19.4	14.3	25.1	70.2	31.0	67.0	30.1	63.9	29.1	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 4.5	(b) 3.6	(c) 3.1	(e) -13.3	(f) 36.7	(g) 3.4	(h) 2.3	(i) -15.8	(j) 38.3	(k) -17.8	(l) 39.7	(m) -19.7	(n) 40.9	(o) -22.2	(p) 42.6		
(a) 4.5	(b) 3.6	(c) 3.1	(e) -13.7	(f) 25.0	(g) 3.4	(h) 1.0	(i) -16.1	(j) 25.7	(k) -18.1	(l) 26.3	(m) -20.0	(n) 26.8	(o) -22.4	(p) 27.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.6	1.8	3.5	7.8	12.8	17.3	20.8	22.6	22.7	17.8	13.0	7.9	2.9		
	DBStd	8.51	4.90	5.19	4.77	3.95	3.60	3.60	3.04	3.11	3.73	4.31	4.72	4.62		
	HDD10.0	903	257	186	99	19	1	0	0	0	0	21	94	226		
	HDD18.3	2531	514	414	327	170	63	17	4	4	54	171	313	479		
	CDD10.0	1859	2	5	31	103	226	325	392	393	235	113	31	4		
	CDD18.3	446	0	0	1	3	30	92	138	139	39	4	1	0		
	CDH23.3	4377	0	0	4	53	313	921	1371	1311	342	59	2	0		
	CDH26.7	1689	0	0	1	9	72	349	576	570	107	5	0	0		
(14) Wind	WSAvg	1.0	0.9	1.0	1.2	1.2	1.1	1.1	1.1	1.0	0.9	0.8	0.8	0.9		
(15) Precipitation	PrecAvg	866	59	53	63	66	90	103	78	70	72	73	71	68		
	PrecMax	1233	102	94	154	172	303	224	199	210	241	200	117	174		
	PrecMin	516	13	13	10	11	27	38	8	4	2	0	12	2		
	PrecStd	165	23	21	36	34	58	48	48	49	48	48	31	38		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.7	19.5	23.4	28.0	30.9	34.2	36.2	37.1	33.1	27.3	23.2	19.2		
		MCWB	10.7	11.3	13.1	16.2	19.6	22.4	22.2	22.0	20.3	18.1	14.8	12.1		
	2%	DB	13.4	16.4	20.7	24.6	28.7	32.3	33.8	34.2	29.6	25.1	20.4	15.0		
		MCWB	8.9	10.0	11.9	15.0	18.8	21.9	22.1	21.6	19.2	17.0	13.7	10.2		
	5%	DB	10.6	13.9	18.4	22.5	26.8	30.6	31.9	32.0	27.0	22.8	17.7	11.7		
		MCWB	7.4	8.9	11.2	13.9	18.2	21.5	21.9	21.3	18.5	16.2	12.4	8.2		
	10%	DB	8.2	11.2	15.9	20.4	24.9	28.7	29.9	29.9	24.8	20.3	15.1	8.9		
		MCWB	6.1	7.6	10.1	13.1	17.4	20.4	21.2	20.8	17.7	15.2	11.4	7.0		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	11.8	14.0	17.3	21.0	24.4	24.4	24.7	21.6	19.2	15.4	12.7		
		MCDB	16.2	17.4	21.0	25.8	27.9	31.3	31.7	32.1	29.3	25.0	21.4	18.3		
	2%	WB	9.3	10.3	12.5	15.8	19.8	23.1	23.2	23.3	20.3	17.8	14.2	10.2		
		MCDB	12.8	15.6	18.9	22.7	26.8	30.1	31.1	30.2	27.1	23.1	19.3	14.2		
	5%	WB	7.7	9.1	11.5	14.7	18.8	22.0	22.5	22.3	19.3	16.7	12.9	8.5		
		MCDB	10.1	13.3	17.4	20.5	25.6	29.1	30.2	29.3	25.1	21.4	16.8	11.1		
	10%	WB	6.3	7.9	10.4	13.7	17.8	21.0	21.7	21.4	18.4	15.6	11.6	7.0		
		MCDB	8.1	10.9	15.5	19.0	23.7	27.3	28.8	28.2	23.5	19.7	15.0	8.8		
(36) Mean Daily Temperature Range	5% DB	MDBR	6.4	8.1	9.6	10.5	10.8	10.7	11.4	11.7	10.5	10.2	8.2	6.2		
		MCDBR	11.1	13.8	14.5	15.0	14.6	14.5	15.3	15.8	14.6	14.3	12.8	11.4		
	5% WB	MCWBR	7.0	8.1	7.3	6.7	6.1	5.6	5.6	5.5	5.6	7.0	7.0	7.0		
		MCWBR	10.4	12.4	13.0	12.9	13.1	13.3	13.6	13.4	12.8	12.9	11.5	10.3		
(40) Clear-Sky Solar Irradiance	taub		0.340	0.369	0.405	0.462	0.453	0.448	0.449	0.454	0.435	0.396	0.355	0.337		
	taud		2.352	2.247	2.199	2.062	2.143	2.204	2.200	2.186	2.209	2.311	2.376	2.363		
	Ebn at Noon		762	800	820	801	822	827	820	800	781	761	737	723		
	Edh at Noon		80	105	126	157	149	141	140	137	124	98	78	72		
(44) All-Sky Solar Radiation	RadAvg		1.28	2.04	3.25	4.36	5.38	5.96	6.13	5.48	3.81	2.64	1.60	1.07		
	RadStd		0.18	0.28	0.40	0.50	0.51	0.56	0.48	0.57	0.44	0.31	0.15	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)		+0.67	N/A	N/A	N/A	+0.40	+0.48	-117	-184	+116	N/A

Nomenclature: See separate page