

NEGOTIN, Serbia

WMO: 132950

Lat: 44.233N

Lon: 22.550E

Elev: 144

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.5	16.6	6.2	7.6	11.6	11.8	10.1	18.1	18.7	30.0	16.6	34.2	2.5	110	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.3	93.6	71.1	90.8	70.3	88.0	69.6	73.6	87.8	72.1	86.4	70.8	84.7	4.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.9	106.6	80.4	67.4	101.3	78.9	66.1	96.6	77.4	37.1	87.6	35.9	86.8	34.7	84.8	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.0	13.8	11.8	DB	3.2	97.7	8.6	3.5	-2.9	100.2	-8.0	102.2	-12.8	104.1	-19.0	106.7	(4)
(5)			WB	2.6	76.3	8.4	1.3	-3.4	77.2	-8.3	78.0	-13.0	78.7	-19.1	79.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.6	32.5	36.7	45.3	55.6	64.0	71.2	75.1	74.7	65.5	54.2	44.0	35.1		
	DBStd	16.58	8.74	9.72	8.42	6.25	5.67	5.62	4.58	4.96	6.28	7.21	7.04	7.93		
	HDD50	1843	545	378	190	20	0	0	0	0	0	40	205	465		
	HDD65	4771	1009	792	611	286	88	13	1	3	70	339	631	928		
	CDD50	3520	1	6	44	189	434	637	778	767	466	172	24	2		
	CDD65	973	0	0	0	5	57	200	314	305	86	6	0	0		
	CDH74	9647	0	0	3	82	541	1992	3202	3007	755	65	0	0		
	CDH80	3788	0	0	0	12	100	744	1375	1317	231	9	0	0		
(14) Wind	WSAvg	3.7	3.7	4.0	4.4	4.0	3.8	4.0	3.9	3.6	3.6	3.2	3.0	3.6		
(15) Precipitation	PrecAvg	23.7	1.7	1.6	1.6	2.0	2.2	2.5	2.1	1.6	2.2	2.1	2.0	2.3		
	PrecMax	43.3	3.3	5.1	3.4	4.8	5.1	10.2	4.5	6.5	8.5	6.2	4.3	5.9		
	PrecMin	12.6	0.3	0.0	0.2	0.0	0.8	0.4	0.2	0.0	0.2	0.2	0.0	0.0		
	PrecStd	6.3	0.9	1.2	1.0	1.0	1.1	2.0	1.3	1.5	1.8	1.6	1.2	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.2	64.7	72.7	81.7	86.2	94.7	98.1	97.7	91.0	81.0	68.9	58.7		
		MCWB	48.8	51.7	54.8	62.5	67.1	71.9	70.9	71.4	68.2	64.4	56.9	49.6		
	2%	DB	53.2	59.1	67.8	75.7	82.8	90.7	93.4	93.7	85.9	74.8	62.2	52.5		
		MCWB	45.7	49.0	53.4	59.3	65.8	71.2	71.2	70.9	66.4	61.4	53.8	46.0		
	5%	DB	48.1	54.5	63.0	71.4	80.2	87.5	90.6	90.6	82.0	70.5	57.8	47.9		
		MCWB	42.6	46.6	50.6	57.3	64.6	70.0	70.6	69.9	65.0	59.9	52.3	43.0		
	10%	DB	44.0	49.8	59.0	68.0	76.9	84.5	87.6	87.4	78.1	66.5	54.5	44.9		
		MCWB	40.2	43.8	48.8	55.6	63.2	68.9	69.8	69.1	63.6	58.0	50.7	41.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.6	53.1	56.6	63.8	70.0	75.3	74.5	75.6	70.1	66.2	58.0	49.9		
		MCDB	58.7	61.5	68.7	77.5	83.8	88.6	89.9	90.1	84.8	77.5	65.3	57.1		
	2%	WB	46.0	49.7	54.0	61.1	67.5	73.3	73.2	73.0	68.0	63.0	55.5	46.7		
		MCDB	52.2	57.4	65.5	72.0	79.7	86.0	88.3	87.5	80.8	71.8	60.1	51.7		
	5%	WB	43.2	47.0	51.8	58.9	65.8	71.5	72.0	71.4	66.4	60.8	53.4	44.1		
		MCDB	47.2	53.3	61.4	69.0	77.3	84.7	86.6	86.1	78.6	69.3	56.7	47.2		
	10%	WB	40.7	44.6	49.5	56.9	64.1	69.8	70.8	70.1	64.8	58.6	51.1	41.8		
		MCDB	44.0	49.2	57.8	65.9	74.8	82.4	84.7	84.3	75.6	65.6	54.4	44.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	13.0	16.4	18.6	19.2	20.4	21.3	21.8	19.4	16.6	11.6	10.1		
		MCDBR	19.6	22.1	25.2	26.4	25.8	26.2	27.4	28.1	26.5	24.7	19.6	16.4		
		MCWBR	13.4	14.5	13.6	12.7	11.4	10.3	9.8	9.7	10.7	13.3	12.2	11.2		
	5% WB	MCDBR	17.3	20.5	23.4	23.0	23.0	23.9	23.9	24.6	23.1	22.6	15.8	14.9		
		MCWBR	12.4	13.9	13.3	11.9	11.1	10.1	9.2	9.3	10.3	12.8	10.4	10.7		
(40) Clear-Sky Solar Irradiance	taub		0.348	0.378	0.417	0.479	0.459	0.451	0.463	0.482	0.451	0.408	0.376	0.347		
	taud		2.267	2.177	2.155	2.006	2.126	2.193	2.164	2.108	2.155	2.263	2.296	2.299		
	Ebn at Noon		237	250	257	249	259	262	256	246	243	237	225	224		
	Edh at Noon		28	36	42	53	48	45	46	47	42	33	27	24		
(44) All-Sky Solar Radiation	RadAvg		435	688	1068	1446	1762	1989	1996	1774	1260	819	473	372		
	RadStd		62	99	144	166	156	174	136	165	114	116	68	55		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+1.48	N/A	N/A	+1.51	+0.90	+0.97	N/A	N/A	N/A
(47) Regional (58 neighbors)		+1.12	N/A	N/A	N/A	+0.63	N/A	-288	+200	+103

Nomenclature: See separate page