

PLJEVLJA, Montenegro

WMO: 133630

Lat: 43.350N

Lon: 19.350E

Elev: 2585

StdP: 13.37

Time Zone: 1.00 (EUC)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.2	11.2	2.8	7.0	7.4	7.3	8.8	12.4	19.3	50.8	16.4	48.2	1.0	290	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	25.8	88.8	66.1	85.6	65.6	82.4	64.7	68.5	83.5	67.0	81.6	65.6	79.4	6.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.4	96.1	74.2	61.9	91.1	72.4	60.7	87.1	70.8	34.3	83.6	33.0	82.0	31.9	79.6	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.9	12.7	9.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	30.3	32.3	40.8	48.3	56.5	63.2	66.2	67.2	59.4	51.2	40.9	33.3
	DBStd	14.85	9.22	9.14	7.64	5.79	6.18	6.48	5.29	4.61	6.16	7.39	8.55	9.26
	HDD50	2407	610	497	289	93	16	3	0	0	7	77	292	523
	HDD65	6015	1075	917	749	501	266	105	51	31	185	429	722	984
	CDD50	2126	0	0	5	41	218	400	503	533	288	114	20	4
	CDD65	260	0	0	0	0	4	52	89	99	16	0	0	0
	CDH74	3715	0	0	0	12	164	733	1133	1290	368	15	0	0
	CDH80	1207	0	0	0	0	20	226	396	461	104	0	0	0
Wind	WSAvg	3.1	2.6	3.1	3.9	4.0	3.1	3.4	3.0	3.4	2.9	1.9	2.8	2.9
Precipitation	PrecAvg	37.2	2.4	2.8	2.6	3.1	3.3	3.1	2.8	2.3	3.6	3.7	3.9	3.5
	PrecMax	46.6	6.9	5.5	7.1	6.8	5.7	5.9	5.0	5.5	8.5	6.9	6.2	8.9
	PrecMin	27.3	0.4	0.8	0.1	0.7	1.1	1.0	1.0	0.4	0.7	0.0	0.8	0.7
	PrecStd	5.3	1.4	1.3	1.6	1.4	1.2	1.3	1.3	1.3	1.9	1.8	1.5	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.3	58.0	66.9	74.8	83.5	89.8	93.0	93.5	87.9	76.2	67.3	59.0
		MCWB	46.6	46.3	50.3	55.4	62.6	68.4	67.5	66.6	62.7	61.9	55.1	51.7
	2%	DB	50.6	52.5	62.3	68.0	78.4	85.7	88.1	89.3	83.1	71.7	62.3	55.1
		MCWB	44.9	44.1	48.5	52.3	60.9	66.1	66.8	66.1	62.9	59.3	53.4	48.6
	5%	DB	46.8	49.0	58.3	64.2	75.3	82.0	84.9	85.2	78.0	67.0	58.0	51.1
		MCWB	42.8	42.6	46.9	51.0	59.9	64.6	66.3	65.5	61.3	56.8	50.7	46.0
	10%	DB	42.8	45.1	54.8	60.8	71.9	78.1	80.9	81.4	73.0	63.1	54.3	46.8
		MCWB	39.7	40.2	45.7	49.6	58.1	63.4	64.7	64.7	60.0	55.0	48.6	43.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.1	47.8	51.8	55.7	64.4	69.5	70.6	69.8	65.4	62.8	56.6	52.0
		MCDB	53.0	55.4	62.8	71.5	77.2	85.4	86.3	85.6	80.1	73.5	65.1	58.1
	2%	WB	45.1	44.9	49.6	53.6	62.6	67.3	68.7	68.1	63.7	60.0	54.1	49.2
		MCDB	50.2	51.3	59.6	64.4	76.7	82.0	83.5	83.0	78.6	70.4	61.2	54.2
	5%	WB	42.9	42.9	47.9	52.0	60.7	65.7	67.0	66.7	62.2	57.6	51.4	46.4
		MCDB	46.6	48.2	57.3	61.5	73.1	79.1	81.4	81.6	76.0	65.4	56.9	51.0
	10%	WB	40.0	40.4	46.0	50.5	58.9	64.0	65.4	65.3	60.5	55.6	48.9	43.4
		MCDB	42.4	44.6	54.2	59.5	70.3	76.2	78.7	79.4	71.7	62.3	53.8	46.5
Mean Daily Temperature Range	5% DB	MDBR	14.3	17.2	20.6	20.5	22.6	22.6	23.7	25.8	22.5	20.1	17.0	11.5
		MCDBR	18.2	22.8	29.6	29.4	30.8	31.4	32.4	34.6	33.8	26.7	23.3	15.0
		MCWBR	12.5	14.7	16.9	15.4	15.2	13.8	13.3	13.8	15.0	15.4	14.6	10.4
	5% WB	MCDBR	17.0	20.4	26.2	25.2	28.2	28.6	29.6	29.7	28.9	24.6	19.8	14.1
MCWBR		11.9	13.4	15.3	13.5	14.0	12.9	12.9	12.8	13.5	14.6	12.9	10.2	
Clear-Sky Solar Irradiance	taub	0.299	0.326	0.370	0.422	0.420	0.409	0.410	0.415	0.392	0.356	0.322	0.298	
	taud	2.401	2.302	2.242	2.142	2.203	2.278	2.272	2.256	2.307	2.403	2.444	2.434	
	Ebn at Noon	265	274	274	267	271	274	272	266	264	260	253	253	
	Edh at Noon	24	32	38	46	45	42	42	41	36	29	23	22	
All-Sky Solar Radiation	RadAvg	480	721	1081	1346	1650	1895	1963	1782	1246	881	556	409	
	RadStd	67	81	135	174	148	171	149	152	128	104	68	69	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (33 neighbors)		+1.06	N/A	N/A	N/A	N/A	N/A	N/A	-214	+187	N/A	

Nomenclature: See separate page