

PLJEVLJA, Montenegro

WMO: 133630

Lat: 43.350N

Lon: 19.350E

Elev: 788

StdP: 92.21

Time Zone: 1.00 (EUC)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.3	-11.6	-16.2	1.0	-13.7	-13.7	1.3	-10.9	8.6	10.4	7.3	9.0	0.5	290	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.3	31.5	19.0	29.8	18.7	28.0	18.2	20.3	28.6	19.4	27.5	18.7	26.3	2.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.4	13.7	23.5	16.6	13.0	22.5	15.9	12.4	21.5	61.9	28.7	58.9	27.8	56.2	26.4	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	5.7	4.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	-0.9	0.1	4.9	9.0	13.6	17.3	19.0	19.6	15.2	10.6	5.0	0.7		
	DBStd	8.25	5.12	5.08	4.24	3.22	3.43	3.60	2.94	2.56	3.42	4.11	4.75	5.15		
	HDD10.0	1337	339	276	161	52	9	2	0	0	4	43	162	291		
	HDD18.3	3342	597	509	416	278	148	58	28	17	103	238	401	547		
	CDD10.0	1181	0	0	3	23	121	222	279	296	160	63	11	2		
	CDD18.3	144	0	0	0	0	2	29	49	55	9	0	0	0		
	CDH23.3	2064	0	0	0	7	91	407	629	717	204	8	0	0		
	CDH26.7	671	0	0	0	0	11	126	220	256	58	0	0	0		
(14) Wind	WSAvg	1.4	1.2	1.4	1.7	1.8	1.4	1.5	1.3	1.5	1.3	0.8	1.3	1.3		
(15) Precipitation	PrecAvg	944	60	70	67	80	85	80	72	59	91	93	99	89		
	PrecMax	1183	174	140	181	172	144	151	126	139	215	176	158	227		
	PrecMin	693	10	20	2	19	29	26	25	10	17	0	20	17		
	PrecStd	135	36	34	41	36	31	33	32	34	47	45	37	47		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	14.4	19.4	23.8	28.6	32.1	33.9	34.2	31.1	24.6	19.6	15.0		
		MCWB	8.1	8.0	10.1	13.0	17.0	20.2	19.7	19.2	17.0	16.6	12.8	10.9		
	2%	DB	10.3	11.4	16.8	20.0	25.8	29.8	31.1	31.8	28.4	22.1	16.8	12.9		
		MCWB	7.2	6.7	9.2	11.3	16.1	18.9	19.3	18.9	17.2	15.2	11.9	9.2		
	5%	DB	8.2	9.5	14.6	17.9	24.1	27.8	29.4	29.6	25.6	19.4	14.5	10.6		
		MCWB	6.0	5.9	8.3	10.6	15.5	18.1	19.1	18.6	16.3	13.8	10.4	7.8		
	10%	DB	6.0	7.3	12.7	16.0	22.1	25.6	27.2	27.4	22.8	17.3	12.4	8.2		
		MCWB	4.3	4.6	7.6	9.8	14.5	17.5	18.2	18.2	15.5	12.8	9.2	6.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.4	8.8	11.0	13.2	18.0	20.8	21.5	21.0	18.5	17.1	13.7	11.1		
		MCDB	11.7	13.0	17.1	21.9	25.1	29.7	30.2	29.8	26.7	23.1	18.4	14.5		
	2%	WB	7.3	7.2	9.8	12.0	17.0	19.6	20.4	20.1	17.6	15.5	12.3	9.6		
		MCDB	10.1	10.7	15.3	18.0	24.8	27.8	28.6	28.3	25.9	21.3	16.2	12.3		
	5%	WB	6.1	6.1	8.8	11.1	16.0	18.7	19.5	19.3	16.8	14.2	10.8	8.0		
		MCDB	8.1	9.0	14.0	16.4	22.8	26.2	27.4	27.6	24.4	18.6	13.8	10.6		
	10%	WB	4.4	4.7	7.8	10.3	14.9	17.8	18.6	18.5	15.8	13.1	9.4	6.4		
		MCDB	5.8	7.0	12.3	15.3	21.3	24.6	25.9	26.3	22.1	16.9	12.1	8.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	9.5	11.4	11.4	12.5	12.5	13.2	14.3	12.5	11.2	9.5	6.4		
		MCDBR	10.1	12.7	16.5	16.4	17.1	17.5	18.0	19.2	18.8	14.8	12.9	8.4		
		MCWBR	7.0	8.2	9.4	8.5	8.4	7.6	7.4	7.7	8.3	8.5	8.1	5.8		
		MCDBR	9.4	11.3	14.6	14.0	15.7	15.9	16.5	16.5	16.0	13.7	11.0	7.9		
	5% WB	MCWBR	6.6	7.4	8.5	7.5	7.8	7.2	7.2	7.1	7.5	8.1	7.2	5.7		
(40) Clear-Sky Solar Irradiance	taub		0.299	0.326	0.370	0.422	0.420	0.409	0.410	0.415	0.392	0.356	0.322	0.298		
	taud		2.401	2.302	2.242	2.142	2.203	2.278	2.272	2.256	2.307	2.403	2.444	2.434		
	Ebn at Noon		834	863	863	843	854	864	857	840	831	819	798	799		
	Edh at Noon		77	100	121	146	141	131	131	129	113	91	74	68		
(44) All-Sky Solar Radiation	RadAvg		1.51	2.27	3.41	4.24	5.20	5.97	6.19	5.62	3.93	2.78	1.75	1.29		
	RadStd		0.21	0.25	0.42	0.55	0.47	0.54	0.47	0.48	0.40	0.33	0.21	0.22		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (33 neighbors)	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	-119	+104	N/A

Nomenclature: See separate page