

ZLATIBOR, Serbia

WMO: 133670

Lat: 43.733N

Lon: 19.717E

Elev: 3376

StdP: 12.99

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.8	12.3	4.4	7.8	7.8	9.1	9.9	13.1	16.9	43.6	14.5	40.7	3.6	230	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.9	84.3	64.6	81.0	64.0	78.1	63.2	67.4	78.6	65.8	77.0	64.4	75.4	4.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.4	99.3	73.4	61.8	93.5	71.6	60.2	88.4	69.7	33.9	78.8	32.5	77.1	31.3	75.4	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.8	11.4	9.5	DB	2.9	88.9	4.7	3.8	-0.4	91.6	-3.2	93.8	-5.8	95.9	-9.2	98.7	(4)
(5)			WB	2.4	70.6	4.7	1.6	-1.0	71.7	-3.7	72.6	-6.3	73.5	-9.7	74.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.6	29.3	31.5	37.9	47.0	54.9	61.5	65.1	65.7	56.9	49.0	40.8	30.9		
	DBStd	15.35	9.56	10.06	9.16	8.16	7.35	7.24	6.42	6.57	7.68	8.91	9.58	8.89		
	HDD50	2779	641	519	384	146	37	6	0	1	24	131	296	594		
	HDD65	6583	1106	938	841	542	317	148	80	71	259	497	726	1058		
	CDD50	1915	0	1	8	54	190	352	467	488	233	100	21	1		
	CDD65	242	0	0	0	0	6	44	82	92	17	1	0	0		
	CDH74	1745	0	0	0	2	43	312	613	664	108	3	0	0		
	CDH80	382	0	0	0	0	2	43	139	179	19	0	0	0		
(14) Wind	WSAvg	4.3	4.7	4.6	4.6	4.6	4.2	3.9	3.7	3.6	3.8	3.9	4.8	4.9		
(15) Precipitation	PrecAvg	37.4	2.6	2.3	2.4	3.0	4.1	4.3	4.0	2.8	3.3	2.7	3.3	2.9		
	PrecMax	45.6	5.2	4.9	4.3	5.3	6.1	9.4	6.6	5.2	8.7	6.9	5.6	5.7		
	PrecMin	28.8	0.6	0.7	0.6	0.4	2.3	1.7	1.6	0.7	0.7	0.4	1.0	0.4		
	PrecStd	4.7	1.5	1.2	1.1	1.1	1.2	1.8	1.3	1.4	2.2	1.7	1.3	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.0	57.8	64.0	72.6	78.7	84.3	88.5	89.3	83.0	72.4	65.0	54.5		
		MCWB	43.7	46.1	48.9	54.5	59.7	66.2	64.3	64.7	61.8	58.1	52.5	47.5		
	2%	DB	48.1	51.9	58.9	67.0	74.2	80.6	83.9	84.9	76.9	68.7	59.8	50.0		
		MCWB	41.8	42.9	46.5	52.0	59.2	65.2	65.0	64.3	60.3	56.2	50.1	44.1		
	5%	DB	45.1	48.5	55.1	62.8	70.7	77.7	80.5	81.0	72.3	64.9	56.5	46.7		
		MCWB	40.0	41.2	44.5	49.8	57.3	64.0	64.6	63.3	59.5	54.8	48.2	41.9		
	10%	DB	42.0	45.0	51.2	59.1	67.3	74.5	77.1	77.4	68.6	61.3	53.4	43.2		
		MCWB	38.0	39.3	42.9	48.2	56.0	62.5	63.6	62.8	57.8	53.3	46.9	39.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.5	46.8	49.8	55.9	62.7	69.3	69.3	69.0	64.1	59.8	54.0	48.0		
		MCDB	50.6	55.6	61.7	68.9	74.1	80.0	80.5	80.9	76.6	69.9	62.7	53.1		
	2%	WB	42.3	43.8	47.4	53.1	60.3	66.8	67.3	66.8	61.9	57.5	51.2	44.5		
		MCDB	47.3	51.1	56.9	65.1	70.9	77.6	78.7	78.2	73.3	65.9	58.1	49.2		
	5%	WB	40.4	41.7	45.4	50.9	58.5	64.9	65.7	65.2	60.3	55.6	49.2	42.2		
		MCDB	44.6	47.7	53.8	60.6	68.8	75.3	77.1	76.7	70.7	63.3	55.5	46.5		
	10%	WB	38.3	39.6	43.3	49.0	56.7	63.1	64.3	63.7	58.6	53.9	47.2	39.7		
		MCDB	41.7	44.5	50.7	57.1	66.0	73.2	75.3	74.9	67.2	60.5	52.6	42.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	12.4	13.9	14.7	15.8	16.4	16.9	16.9	14.7	14.2	12.2	10.1		
		MCDBR	13.5	17.0	20.0	20.3	20.9	21.0	21.5	21.8	20.2	18.6	16.1	13.9		
		MCWBR	8.7	10.2	11.0	10.3	10.3	10.4	9.6	9.1	9.5	9.7	9.6	9.5		
	5% WB	MCDBR	12.5	15.8	18.2	17.7	18.9	19.2	19.2	18.6	18.0	17.0	14.5	13.2		
		MCWBR	8.5	9.7	10.4	9.9	10.4	10.5	9.8	9.4	9.4	9.5	9.1	9.3		
(40) Clear-Sky Solar Irradiance	taub		0.290	0.315	0.351	0.399	0.396	0.388	0.390	0.396	0.376	0.341	0.308	0.289		
	taud		2.431	2.345	2.312	2.211	2.263	2.318	2.308	2.290	2.337	2.439	2.478	2.455		
	Ebn at Noon		267	278	280	274	278	280	278	272	269	265	259	257		
	Edh at Noon		23	30	36	43	42	40	40	39	35	28	22	21		
(44) All-Sky Solar Radiation	RadAvg		456	705	1069	1353	1654	1873	1934	1753	1222	862	543	385		
	RadStd		65	79	128	169	156	181	152	161	132	104	62	62		

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		+1.44	N/A	N/A	+2.16	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (41 neighbors)		+1.12	N/A	N/A	N/A	+0.65	N/A	N/A	-214	+180	N/A	(47)

Nomenclature: See separate page